

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F.6/DFS/MS/SZ/EH/2016/ 147

Dated: 20/01/16

**FIRE SAFETY CERTIFICATE**

Certified that the Qla (Qla Qutab Entertainment Pvt. Ltd.)(Formerly Blue Frog) located at 4A, Kalka Das Marg, Mehrauli, New Delhi-110030 comprised of ground floor only owned/occupied by Qla Qutab Entertainment Pvt. Ltd was granted FSC by this department vide letter No.F6/DFS/MS/EH/2013/420 dated 05/06/2013. The premises was re-inspected by the officer concerned of this department on 07/01/16 in the presence of Mr. Rajender Sharma and found that the said premises have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class Group - D Assembly Building (**Restaurant**) with effect from 20/01/16 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010.

Issued ----- 20/01/16 ----- at New Delhi by.

  
**(Dr. G. C. Misra)**  
**Chief Fire Officer**  
Tel: 011-23414333

Dr. G. C. Misra

Copy to: -

(1) Dy. Health Officer,  
SDMC, South Zone,  
Aurbindo Marg, Green Park New Delhi.

(2) Mr. Parteek Arora  
4 A, Kalka Das Marg, Mehrauli, New Delhi-110030

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J" [ sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

**INSPECTION REPORT**

1. Name & address of the building:- Qla (Qla Qutab Entertainment Pvt. Ltd.), (Formerly Blue Frog Restaurant) located at 4A, Kalka Das Marg, Mehrauli, New Delhi- 110030
2. Type of occupancy:- Assembly Building, Group – D, Restaurant
3. Type of case:- Renewal
4. Details of previous NOC:- F6/MS/DFS/EH/2013/420 dated 05/06/2013
5. Fire safety directives No.- Nil
6. Date of inspection:- 07/01/2016
7. Name of the inspecting officer:- D.B.Mukherjee, A.D.O.(BCP),
8. Name & designation of officer From the building side:- Mr. Rajender Sharma
9. Year of construction:- 2002
10. Applicant's letter No:-No.DHO/SZ/2015/D-2258 dated: 10/12/15
11. Composition of building:- ground floor only (restaurant is running in two separate adjacent halls)  
(Old Case)

Sl.No	Minimum Standards on fire Prevention and fire safety U/R 33	BBL/NBC Requirement	Provided at site	Remarks MR/NMR
1.	<b>Access to Building</b>			
	1) Road width	12mtrs	Provided	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
2.	<b>Number, Width Type &amp; Arrangement of Exits</b>			
	A. Number of staircases			
	1. Upper floors	N/A	N/A	N/A
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	N/A	N/A	N/A
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	N/A	N/A	N/A
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	1.5 m	1.89m, 1.66m, 1.66m, 1.91m & 1.88m	MR
3.	<b>Compartmentation</b>			
	1) Fire check door	Required	Provided	MR
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	<b>Smoke Management System</b>			
	1) Basements	30 a/c per hour	N/A	N/A
	2) Upper floors	12 a/c per hour	Natural Ventilation	MR
5.	<b>Fire Extinguishers</b>			
	1) Total numbers	ISI Marked	15Nos.	MR
	2) Types		ABC, Co2, Foam	MR
	3) ISI marking		Yes	MR

Ej

<b>6.</b>	<b>First-Aid Hose Reel</b>			
	1) Total number of each floor	02nos	Provided	MR
	2) Length of hose reel hose	30m	Provided	MR
	3) Nozzle diameter	5mm	Provided	MR
<b>7.</b>	<b>Automatic Fire Detection &amp; Alarming System</b>			
	1) Type of detectors	NR	Provided(Smoke & Heat)	MR
	2) Location of main panel	NR	Provided in kitchen	MR
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	NR	Battery Back Up	MR
	5) Hooter's Location	NR	Provided	MR
<b>8.</b>	<b>MOEFA</b>	Required	Provided	MR
<b>9.</b>	<b>Public Address System</b>	Required	Provided	MR
<b>10.</b>	<b>Automatic Sprinkler System</b>			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
<b>11.</b>	<b>Internal Hydrants</b>			
	1) Size of down-comer	Required	Provided	MR
	2) Number of hydrants per floor	02no	Provided	MR
	3) Hose box	02no	Provided	MR
<b>12.</b>	<b>Yard Hydrants</b>			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
<b>13.</b>	<b>Pumping Arrangement</b>			
	1) Ground level			
	a) Discharge of main pump	450Lpm	450LPM	MR
	b) Head of main pump	40mtr	40mtr	MR
	c) Number of main pump	01no	Provided	MR
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	Required	Provided	MR
	2) Terrace level			
	a) Discharge of pump	N/A	N/A	N/A
	b) Head of pump	N/A	N/A	N/A
	c) Power supply	N/A	N/A	N/A
	d) Auto starting of pump	N/A	N/A	N/A
<b>14.</b>	<b>Captive Water Storage for Fire Fighting</b>			
	1) Underground tank capacity	10,000ltr	Provided 20,000ltr	MR
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	N/A	N/A	N/A
<b>15.</b>	<b>Exit Signage.</b>	Required	Provided	MR
<b>16.</b>	<b>Provision of Lifts.</b>			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A

2/12

17.	Standby Power Supply	Required	Provided	MR
18.	Refuge Area			
	Total area	N/A	N/A	N/A
	location	N/A	N/A	N/A
19.	Fire Control Room			
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

Keeping in view of the compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, renewal of the FSC issued vide letter No. F6/MS/DFS/EH/2013/420 dated 05/06/2013, under rules 35 of the Delhi Fire Service Rules 2010 is recommended.

Accordingly DFA is prepared and put up please.

*[Handwritten Signature]*  
18/1/16

Signature of the inspecting officer  
Name :- D.B. Mukherjee.  
Designation :- Assitt. Divisional Officer(BCP)

*[Handwritten Signature]*  
19/1/16

*[Handwritten Signature]*  
19/1/16  
CF/ South  
*[Handwritten Signature]*  
19/1/16

