

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6 / DFS / MS / 2016 / *Schal/wr/221*

Dated: *05/02/2016*

FIRE SAFETY CERTIFICATE

Certified that the Mata Sunder Kaur Public School at 1631, Sohan Ganj, Delhi, located on Ground Floor of a premise comprised of Ground + one upper floor owned/ occupied by Mata Sunder Kaur Public School Management was issued Fire Safety Certificate vide this office letter no. F6/DFS/MS/2012/school/856 dated 07.03.2012. The premises was re-inspected by the officer concerned of this department on 05.01.2016 in the presence of Mr. Inderpreet Singh, Chairman and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have therefore, deemed complied with the requirements in accordance with the circular issued by the Director of Education letter no 3298-3398 dated 01.03.2011 and the building is fit for occupancy Group B Educational with effect from *05/02/16* for a period of three years, subject to the conditions mentioned below:

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'F' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules, 2010. The form is available on WWW.dfs.Delhigovt.nic.in
8. The number of students in the class rooms shall not be more than 45 as there are single exit door in class room.

Issued on *05/02/16* at New Delhi



(Santokh Singh)
Chief Fire Officer
Ph:-011-23414250

Copy to :-

1. The Director, Education, Government of N.C.T of Delhi, Old Sectt, Delhi - 54.
2. The Chairman, Mata Sunder Kaur Public School, 1631, Sohan Ganj, Delhi-110047.

2/19,

INSPECTION REPORT

1. Name & address of the building : Mata Sunder Kaur Public School, 1631/32, Sohan Ganj, Delhi-110007.
 2. Type of Occupancy : Educational (Ground & First floor only school at GF only)
 3. Type of Case : Renewal
 4. Details of previous NOC : F6/DFS/MS/2012/School/856 dated 07/03/12
 5. Fire Safety directives letter No : Director of Education Circular dated 01.03.2011
 6. Date of inspection : 05/01/2016
 7. Name of the Inspecting Officers : ADO (RN)
 8. Name and designation of officers
from the building side : Mr. Inderpreet Singh/ Chairman
 9. Year of Construction : 1965
 10. Applicant's letter No. : Nil dated 28/10/2015
- Plot Area-450 sq yards Covered Area:250 sq. yards, Class rooms -08 nos No. of Student - 300

	Minimum Standards on fire prevention and fire safety U/R 33	Circular of Director of Education	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	3.0m	Old Case
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	NA	02	NA
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	NA	1.20m 0.65m	NA
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
f. Door Size	1 m	1 m	MR	
3	Compartmentation.			
	• Fire check door	NA	NA	NA

2/10

	<ul style="list-style-type: none"> Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
4	Smoke Management System.			
	<ul style="list-style-type: none"> Basements Upper floors 	NA	NA	NA
		NA	NA	NA
5	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types ISI marking 	02nos	03 nos	MR
		ABC/Co2	ABC—3	MR
		ISI Marked	Yes	MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
8	MOEFA	NA	NA	NA
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer 	NA	NA	NA

AK

17	Standby power supply	N/A	Inverter	N/A
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

Note:- General requirements as per director of Education letter dated 01.03.2015

- | | |
|---|--------------------------------|
| 1. Escape route—clear | 2. LPG cylinder in Lab---NA |
| 2. Electric wiring—concealed | 4. ELCB/MCB—provided |
| 5. Electric meter board—not under staircase | 6. Emergency Tel Nos—Displayed |
| 7. Generator set ----- No | 8. Basement use as per BBL--NA |

The fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in director of education Circular dated 01.03.2011, fire safety certificate is recommended.

DO / N/A

Rajesh
15/1/16

RK
23/11
Signature of the Inspecting Officer
Name: - Rajesh Kumar
Designation: - ADO/RN

2011/12/16/16