

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110 001

NO. F6/DFS/MS/2016/Club/52/210

Dated: 04/02/16

FIRE SAFETY CERTIFICATE

Certified that M/S The Chiragh Club, located at Central Park, Chirag Enclave, New Delhi-110048, comprised of ground plus two upper floors, owned/occupied by The Chiragh Club, was granted Fire Safety Certificate by this department vide letter No. F6/DFS/MS/2012/Club/3300, dated 10-09-12. The premises was re-inspected by the officer concerned of this department on 29-01-2016 in the presence of Sh. Ramniwas Yadav, Manager and found that the said club premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class Assembly (Club Building) with effect from 04/02/2016 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules, 2010.

Issued on 04/02/2016 at New Delhi by



(Dr.G.C.Misra)

Chief Fire Officer

T.No.011-23414333

Copy to:- Hony Secretary, M/S The Chiragh Club, located at Central Park, Chirag Enclave,
New Delhi-110048.

Conditions for the validity of fire safety certificate are as under:-

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. The employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All fire fighting equipments shall be maintained in perfect working condition all time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate, six month prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : M/S The Chiragh Club, located at Central Park, Chirag Enclave, New Delhi-110048.
2. Building is comprised of : Ground plus two Upper floors.
3. Type of Occupancy : Club Building (Assembly Occupancy i.e. Eating House).
4. Type of Case : Renewal.
5. Details of Previous NOC : No.F6/DFS/MS/Club/2012/3300, dated 10.09.2012.
6. Fire Safety direction letter No : Nil.
7. Date of Inspection : 29.01.2016.
8. Name of the Inspecting Officers: : Vedpal (ADO)
9. Name and designation of Officer from the building side : Sh. Ramniwas Yadav (Manager).
10. Year of Construction : 2005.
11. Applicant's letter No : No.Nil, Dated 07.01.16.

S.No	Minimum Standards on fire prevention and fire safety U/R33	Requirements	Provided at Site	Remarks
1	Access to building			
	Road width	9m	9 m	MR
	Gate width	N.A.	N.A.	N.A.
	Width of internal road	N.A.	N.A.	N.A.
2	Number, Width, Type and Arrangement of Exits.			
a. Number of Staircases Upper Floor Basement B. Width of Staircases Upper Floor Basement c. Protection of exits Fire check door Pressurization e. No. of continuous staircases to terrace g. Width of Corridor h. Door Size				
	02nos.	02nos.	MR	
	N.A.	N.A.	N.A.	
	1.5m/1m	1.32m & 90cm	MR(old case)	
	N.A.	N.A.	N.A.	
	N.A.	N.A.	N.A.	
	N.A.	N.A.	N.A.	
	N.A.	N.A.	N.A.	
	01no.	01no.	MR	
	N.A.	N.A.	N.A.	
1m	1m	MR		
3	Compartmentation			
Fire check door Sealing of electrical shafts Fire rating of shaft door Water curtain Fire Dampers	N.A.	N.A.	N.A.	
	Required	Provided	MR	
	N.A.	N.A.	N.A.	
	N.A.	N.A.	N.A.	
	N.A.	N.A.	N.A.	
4	Smoke Management System.			
Basement Upper floor	30a/c per hour	N.A	N.A	
	12 a/c per hour	N.A.	N.A.	
5	Fire Extinguisher			
Total numbers types IS marking	06 nos.	12 nos.	MR	
	CO ₂ & ABC	CO ₂ & ABC	MR	
	ISI marked	ISI marked	MR	
6	First-aid-Hose Reels.			
Total numbers on each floor Length of hose reel hose Nozzle diameter	01no.	Provided	MR	
	30m.	Provided	MR	
	5mm	Provided	MR	
7	Automatic fire detection and alarming system.			

9	Public address System.	N.A.	N.A.	N.A.
10	Automatic Sprinkler System.			
	Basement	N.A.	N.A.	N.A.
	upper floor	N.A.	N.A.	N.A.
	sprinkler above false ceiling	N.A.	N.A.	N.A.
11	Internal Hydrants			
	size of riser/down-comer	100mm	100mm	MR
	Number of hydrants per floor	01no.	01no.	MR
	Hose Box	01no.	01no.	MR
12	Yard Hydrants.			
	Total number of hydrants	N.A.	N.A.	N.A.
	Hose Box	N.A.	N.A.	N.A.
13	Pumping Arrangements.			
	• Ground Level	N.A.	N.A.	N.A.
	➤ Discharge of main Pump	N.A.	N.A.	N.A.
	➤ Head of Main Pump	N.A.	N.A.	N.A.
	➤ Number of main pumps	N.A.	N.A.	N.A.
	➤ Jockey pump out put	N.A.	N.A.	N.A.
	➤ Jockey pump head	N.A.	N.A.	N.A.
	➤ Standby pump out put	N.A.	N.A.	N.A.
	➤ Standby pump Head	N.A.	N.A.	N.A.
	➤ Auto Starting /Manual stopping	N.A.	N.A.	N.A.
	➤ Pump House Access	N.A.	N.A.	N.A.
	• Terrace Level	Required	Provided	MR
	➤ Discharge of pump	450LPM	Provided	MR
	➤ Head of the Pump	40m	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	On ground tank capacity	N.A.	N.A.	N.A.
	Draw-off connection	N.A.	N.A.	N.A.
	Fire service inlet	Required	Provided	MR
	Access to tank	N.A.	N.A.	N.A.
	Overhead Tank capacity	10000Liters.	10000Liters	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	Pressurization of Lift Shaft	N.A.	N.A.	N.A.
	Pressurization of Lift lobby	N.A.	N.A.	N.A.
	Communication in lift car	N.A.	N.A.	N.A.
	Firemen's grounding switch	N.A.	N.A.	N.A.
	Lift Signage	N.A.	N.A.	N.A.
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	Total area	N.A.	N.A.	N.A.
	Location	N.A.	N.A.	N.A.
19	Fire Control Room			
	Detector system panel	N.A.	N.A.	N.A.
	Flow switch panel	N.A.	N.A.	N.A.
	PA system panel	N.A.	N.A.	N.A.
	Batter backup	N.A.	N.A.	N.A.
	Building Floor Plans	N.A.	N.A.	N.A.
20	Special Fire Protection systems for of special Risks, if any:	N.A.	N.A.	N.A.


M/S: The Chiragh Club, Central Park, Chirag Enclave, N. Delhi-48


The fire protection systems provided in the building were test checked at random and found functional at the time of inspection. In view of the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules the FSC issued vide letter No.F.6/DFS/MS/Club/2012/3300, dated 10.09.2012 renewal under rule 35 of the Delhi Fire Service Rule 2010 is recommended.


29/11/16

Signature of the Inspecting Officer
Name : Vedpal
Designation: Assistant Divisional Officer

D.O (South)


11/11/16

~~D.O (S)~~

11/11/16

~~CB/South~~


29/11/16