

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI


No. F-6/DFS/MS/ *School/2016/W2/241*

Dated: *11/02/2016*

FIRE SAFETY CERTIFICATE

Certified that the **ADARSH SHIV SHAKTI SHIKSKA SAMITI** (Regd) 64 ChanderLok Enclave, Pitam Pura, Delhi – 34 comprised of Basement + Ground + Three Upper Floors owned/ occupied by **ADARSH SHIV SHAKTI SHIKSKA SAMITI (Regd)** have complied with the fire prevention and fire safety requirements in accordance with the Director of Education Circular No-F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 and verified by the officers concerned of Fire Service on 01-01-2016 in the presence of **Sh Kanahiya (Caretaker)** and that the building / premises is fit for the occupancy class "Educational" Group B with effect from*11/02/16*..... for a period of three years subject to compliance of the conditions mentioned below:-

Issued on*11/02/16*..... at New Delhi by.


(Santokh Singh)
Chief Fire Officer,
Ph: - 011-23414250
11/02/16

Copy to:

The Principal, ADARSH SHIV SHAKTI SHIKSKA SAMITI, 64 Chander Lok Enclave, Pitam Pura, Delhi -34.

Condition for the validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained firefighting staff should be available round the clock.
4. Any deviations with regard to construction etc shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. There shall be no more than 45 students in class rooms in any case.

INSPECTION REPORT

1. Name & address of the building: Adarsh Shiv Shiksha Samiti (Regd.), 64, Chanderlok Enclave, Pitampura, New Delhi-110034.
2. Type of Occupancy : Educational
3. Type of Case : New (Basement + Ground Floor + 3 Upper Floors + Tin Shed at terrace)
4. Details of previous NOC : Nil
5. Fire Safety directives Letter No. : DOE Circular Dated 1/3/2011
6. Date of inspection : 01/01/2016
7. Name of the Inspecting Officer : A.D.O. (Wazirpur)
8. Name and designation of Officer from the building side : Sh. Kanahiya (Care Taker)
9. Year of Construction : 2008 ✓
10. Applicant's letter No. : Nil dated 16/12/2015

No. of Students – 444
No. of Class Rooms – 24
Total Area – 815 m2 (Aprox.)
Covered Area – 2760 m2 (Aprox.)

S No	Minimum standards on fire prevention and fire safety U/R 33	DOE Circ. Dt.1/3/2011 Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Accessible	Provided ✓	MR
	• Gate width	Accessible	Provided ✓	MR
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	1	Provided	MR
	• Basements	1	Provided	N/A
	b. Width of staircases			
	• Upper floors	1 X 1.50 Mtr.	1 x 1.35 Mtr & 1 x 1.25 Mtr. ✓	MR
	• Basements	1 X 1.50 Mtr.	2 x 1.35 Mtr. ✓	MR
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	1	Provided	MR
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	1.00 Mtr.	Provided including door frame	MR
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers			
4.	Smoke managements System			
	• Basements	Required	Provided (Exhaught Fan)	MR
	• Upper floors	N/A	N/A	N/A
5.	Fire Extinguishers			
	• Total numbers	10	10	

(> 45 students) 4/10

N/2				
6.	First – Aid Hose Reels			
	• Total numbers on each floor	1	Provided	MR
	• Length of hose reel hose	30 Mtr.	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detector	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	MOEFA	N/R	Provided	NR
9.	Public Address System	N/R	Provided	NR
10.	Automatic Sprinkler System			
	• Basements	Required	Provided ✓	MR ✓
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down-comer	N/A	Provided	N/A
	• Number of hydrants per floor	N/A	One Provided	N/A
	• Hose Box	N/A	One Provided	N/A
12.	Yard Hydrants			
	• Total number of hydrants	Not Required	N/P	N/R
	• Hose Box	Not Required	N/P	NR
13.	Pumping Arrangements			
	• Ground Level			
	• Discharge of main pump	N/A	N/A	
	➤ Head of main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	450 LPM X 2 ✓	Provided	MR ✓
	➤ Head of the pump	40 Meter Head ✓	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting			
		N/A	N/A	N/A


		Required	Provided	MR
15	Exit Signage			
16.	Provision of Lifts	<i>Running from Ground Floor to 6 Fls.</i>		
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	N/A	<i>Provided</i>	N/A
18.	Refuge Area	N/A	N/A	
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire control room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Battery backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of special Risks, if any;	N/A	N/A	N/A

Note:-General requirements for schools as per Director of Education circular dated 01/03/2011.

1. Escape route:- Clear
2. LPG cylinders in laboratories :- Nil
3. Electric wiring:- Conduit Wiring MCB and ELCB.....
Electric circuit:- MCB Provided
4. Electric meter board / switch board panel.:-Not Under the staircase
5. Basement use as per BBL 1983 :
6. Emergency telephone no. board :- Displayed *2260*
7. Generator set :- at the terrace

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules, it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.



60/83
20/1/16
21/1/16
1/2/16

16
21/01/2016
Signature of the Inspecting Officer

Name : Udaivir Singh

Designation : A.D.O. (Wazir Pur)