

NO.

FG/DFS/MS/Auditorium/2016/52/231

DATED:

10/02/16

**FIRE SAFETY CERTIFICATE**

Certified that **M/S Air Force Auditorium at Subroto Park, Delhi Cantt, New Delhi-110010**, comprised of basement, ground plus one upper floor, Auditorium at ground floor only without balcony & basement is totally separate, owned/occupied by **Indian Air Force** was granted Fire Safety Certificate by this department vide letter no. **F6/DFS/MS/2013/Audi/210**, dated **25.04.2013**. The premises re-inspected by the officer concerned of this department on **04.02.2016** in the presence of Wing Commander A Kapur and found that the building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building is fit for **Occupancy Class-D Assembly Building(Auditorium)** with effect from.....10/02/2016 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on .....10/02/2016.....2016 at New Delhi by



(Dr.G.C.Misra)

Chief Fire Officer

T.No.011-23414333



Copy To:- 1. Joint C.P.Licensing, PS Defence Colony, New Delhi.  
2. M/S Air Force Auditorium at Subroto Park, Delhi Cantt, New Delhi-110010.

**Conditions for the validity of fire safety certificate**

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate in form J, six month prior to its expiry.



**INSPECTION REPORT**

1	Name & address of the building	M/S Air Force Auditorium at Subroto Park, Delhi Cantt, New Delhi-110010.		
2	Type of Occupancy	Group "D" Assembly Building.		
3	Building Comprised of	Basement, ground plus one upper floor. (Auditorium at ground floor only without balcony & basement is totally separate)		
4	Type of case	Renewal		
5	Details of previous NOC	F6/DFS/MS/Audi/2013/210, dated 25.04.2013.		
6	Fire safety directives letter No	N/A		
7	Date of inspection	04.02.2016.		
8	Name of the inspecting Officers	ADO Vedpal		
9	Name and designation of officers from the building side	Wing Commander A.Kapur, Director Auditorium.		
10	Year of construction	1990		
11	Applicant's letter No.	804-07/Joint C.P/Lic (Amst.), Dated 19.01.2016		
<b>S. NO.</b>	<b>Minimum Standards on fire prevention and fire safety U/R 33</b>	<b>NBC Requirement</b>	<b>Provided at site</b>	<b>Remarks MR / NMR</b>
1	<b>Access to building</b>			
	1) Road width	09 Mtr	Provided	MR
	2) Gate width	5m	5m	MR
	3) Width of internal road	N/A	N/A	N/A
2	<b>Number, width Type &amp; arrangement of exits</b>			
	<b>a. Number of staircases</b>			
	1. Upper floors	04nos.	04nos.for seats at higher level.	MR
	2. Basements	N/A	N/A	N/A
	<b>b. Width of staircase</b>			
	1. Upper floors	1.5m(each)	1.7m,1.7m,1m & 1m	MR(old case)
	2. basements	N/A	N/A	N/A
	<b>c. Protection of exits</b>			
	1. Fire check door	Required	Provided	MR
	2. Pressurization	N/A	N/A	N/A
	<b>d. No. of continuous staircase to terrace</b>	N/A	N/A	N/A
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	1m	1m=14Exit gates	MR(old case)
3	<b>Compartmentation.</b>			
	1. Fire check door	Required	Provided in basement	MR
	2. Sealing of electrical shafts	Required	Provided	MR
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
4	<b>Smoke Management system.</b>			
	Basement	30 a/c per hour	N/A	N/A
	Upper floors	12 a/c per hour	Exhaust Fans Provided	MR
5	<b>Fire Extinguishers</b>			
	Total numbers		38 Nos. Provided	MR
	Types		ABC, W CO2 & CO2	MR
	ISI marking	ISI	Provided	MR
6	<b>First-Aid Hose Reels.</b>			
	Total numbers on each floor	05nos.	05nos. Total	MR
	Length of Hose reel hose	30 Mtr	Provided	MR
	Nozzle Diameter	5mm	Provided	MR
7	<b>Automatic fire detection and alarming system</b>			
	Type of detectors	Required	Somke Detector Provided	MR
	Location of Main Panel	Required	Fire Control Room	MR
	Location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	Required	Battery Backup Provided	MR
	Hooter's location	In all areas	Provided	MR
8	<b>MOEFA</b>	Required	Provided	MR

*(Handwritten signature)*

N/47

INSPECTION REPORT

9	<b>Public Address System.</b>	Required	Provided	MR
10	<b>Automatic Sprinkler System.</b>			
	Basement	N/A	N/A	N/A
	Upper floors	Required	Provided at stage only	MR
	sprinkler above false ceiling	N/A	N/A	N/A
11	<b>Internal Hydrants</b>			
	Size of riser/down-corner	N/A	N/A	N/A
	Number of Hydrants per floor	N/A	N/A	N/A
	hose Box	N/A	N/A	N/A
12	<b>Yard Hydrants.</b>			
	total number of hydrants	08nos.	08nos.	MR
	house box	08nos.	08nos.	MR
13	<b>Pumping arrangements</b>			
	<b>1. Ground level</b>			
	a. Discharge of main Pump	1620 LPM	1620 LPM	MR
	b. Head of main pump	70Mtrs.	70 Mtr	MR
	c. Number of main pumps	01no.	01no.	MR
	d. jockey pump out put	240LPM	240 LPM	MR
	e. jockey pump head	70Mtrs.	70 Mtr	MR
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	Required	Provided	MR
	pump house access	Required	Provided	MR
	<b>2. Terrace level</b>		Old Case	
	a. Discharge of pump	N/A	N/A	N/A
	b. head of the pump	N/A	N/A	N/A
	c. Power supply	N/A	N/A	N/A
	d. Auto starting of pump	N/A	N/A	N/A
14	<b>Captive water storage for fire fighting</b>			
	1. Underground tank capacity	100,000 ltr	100,000 Ltr Provided	MR
	a. Draw-off connection	Required	Provided	MR
	b. fire service inlet	Required	Provided	MR
	c. Access to tank	Required	Provided	MR
	Over head tank Capacity	10,000 ltr	10,000 ltr Provided	MR
15	<b>Exit Signage.</b>	Required	Provided	MR
16	<b>Provision of lifts.</b>			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A
17	<b>Standby power supply</b>	Required	Provided	MR
18	<b>Refuge Area.</b>			
	total area	N/A	N/A	N/A
	location	N/A	N/A	N/A
19	<b>Fire control room</b>			
	a. Detector system Panel	Required	Provided	MR
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	Required	Provided	MR
	d. Batter backup	Required	Provided	MR
	e. Building floor plans	N/A	N/A	N/A



N/48


### INSPECTION REPORT

20	Special Fire Protection systems for protection of special risks, if any: N/A
----	--


The fire protection systems provided in the building were checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules the FSC issued vide letter No.F.6/MS/DFS/2013/Audi/210, dated 25.04.2013 renewal under rule 35 of the Delhi Fire Service Rule 2010 is recommended.

Accordingly DFA is put up for your approval and signature please.

  
 Signature of the Inspecting Officer  
 Name Vedpal  
 Designation : ADO

D.O. (South)

  
5/2/16

~~2/MS/DFS/2013/Audi/210~~  
8/2/16

~~CFD/South~~  
8/2