

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No.F6/MS/DFS/School/2016/ *52/235*

Dated: *10/02/16*

FIRE SAFETY CERTIFICATE

Certified that Delhi Public School located at E-9, Vasant Vihar, New Delhi-110057, comprised of basement, ground plus one upper floor owned/occupied by Delhi Public School was issued FSC by this department vide letter no.F6/DFS/MS/School/2012/3706 dated 09/10/2012. The school building was re-inspected by the officer concerned of this department on 20/01/2016 in presence of Mrs. Archana Pental and found that the school have complied with the fire prevention and fire safety requirements in accordance with the Circular No-F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01-03-2011 issued by the Directorate of Education dated 01-03-2011 and that the school building is fit for occupancy class "Educational"(School) with effect from the date of issue*10/02/16*.... of this certificate for a period of three years, subject to compliance of the below mentioned conditions.

Issued on *10/02/16* at New Delhi by.


(Dr. G. C. Misra)
Chief Fire Officer
Tel: 011-23414333

Copy to: -

The Principal,
Delhi Public School
E-9, Vasant Vihar, New Delhi-110057.

9/2 

Conditions for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk & responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The basement shall be used as per the provisions of NBC
6. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in form 'K' Provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J" [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building:- Delhi Public School, E-9, Vasant Vihar, New Delhi-110057
2. Type of occupancy:- Educational (School)
3. Type of case: - Renewal
4. Details of previous NOC: - F6/DFS/MS/School/2012/3706 dated 09/10/12
5. Fire safety directives No.- Nil
6. Date of inspection:- 20/1/2016
7. Name of the inspecting officer:- D.B.Mukherjee, A.D.O.(BCP)
8. Name & designation of officer From the building side: - Mrs. Archana Pental
9. Year of construction:- 1996
10. Applicant's letter No:- DPSR/DFS/FF/NOC/10-15 dated 23/10/2015
11. Composition of building: - Basement, Ground Plus One Upper Floor.

Sl.No	Minimum Standards on fire Prevention and fire safety U/R 33	BBL/NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	Required	Approachable	MR
	2) Gate width	Required	3mtrs.	MR
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	01no.	Provided 01 no	MR
	2. Basements	02 nos.	Provided 02nos	MR
	B. Width of staircase			
	1. Upper floors	1.50m	1.50m	MR
	2. Basements	1.50m	150m & 0.90m	MR
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	Required	01 nos.	MR
	E. Width of corridor	1.5m	Provided	MR
	F. Door size	1mtr	Provided	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	30 a/c per hour	N/A	N/A
	2) Upper floors	12 a/c per hour	N/A	N/A
5.	Fire Extinguishers			
	1) Total numbers	ISI Marked	24Nos	MR
	2) Types		ABC, Co2	MR
	3) ISI marking		Yes	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	01no.	Provided	MR
	2) Length of hose reel hose	30m	Provided	MR
	3) Nozzle diameter	5mm	Provided	MR

7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location			
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	1) Basement	Required	Provided	MR
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	N/A	N/A	N/A
	2) Number of hydrants per floor	N/A	N/A	N/A
	3) Hose box	N/A	N/A	N/A
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	Required	450LPM,450LPM & 180LPM Provided	MR
	b) Head of pump	Required	Provided 45mtr	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	1) Underground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	5,000ltr	Provided 5,000ltr	MR
15.	Exit Signage.	Required	Provided	MR

5/8

16. Provision of Lifts.			
a) Pressurization of lift shaft	N/A	N/A	N/A
b) Pressurization of lift lobby	N/A	N/A	N/A
c) Communication in lift car	N/A	N/A	N/A
d) Fireman's switch	N/A	N/A	N/A
e) Lift signage	N/A	N/A	N/A
17. Standby Power Supply	Required	D.G.Set	MR
18. Refuge Area	N/A	N/A	N/A
Total area location	N/A	N/A	N/A
19. Fire Control Room	N/A	N/A	N/A
a) Detector system panel	N/A	N/A	N/A
b) Flow switch panel	N/A	N/A	N/A
c) PA system panel	N/A	N/A	N/A
d) Battery backup	N/A	N/A	N/A
e) Building floor plan	N/A	N/A	N/A
20. Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection systems provided in the school building were checked and found functional at the time of inspection.

Keeping in view of the compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, renewal of the FSC issued vide letter No. F6/DFS/MS/School/2012/3706 dated 09/10/2012, under rules 35 of the Delhi Fire Service Rules 2010 is recommended.

Accordingly DFA is put up for sign pl.

D.B. Mukherjee
25/11/2016

Signature of the inspecting officer
Name: - D.B.Mukherjee.
Designation:- Assistant Divisional Officer (BCP)

~~DO (South)~~

what about gate security

[Handwritten signature]