

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

No. *FB/DFSS/Ms/School/2016/ND2/251*

Dated: *12/02/16*

FIRE SAFETY CERTIFICATE

Certified that the EDMC Co-Ed School at Samaspur Jagir, Delhi-91, comprised of ground plus first floor only owned/occupied by EDMC Co-Ed School have complied with the fire prevention and fire safety requirements in accordance with the circular no-F-16/Estate/CC/FireSafety/2011/3298 to 3398 dated 01/03/11 issued by the Director of Education and verified by the officer concerned of this department on 27/01/16 in the presence of Mrs.Anupam Gupta Principal of the school and found that the school building is fit for occupancy class B 'Educational Building' for ground floor only with effect from *12/02/16* for a period of three years, subject to conditions printed overleaf.

Issued on.....*12/02/16*.....at New Delhi by



(Dr.G.C.Misra)
Chief Fire Officer
Ph.011-23414333

9/02/16

To,

The Principal,
EDMC Co-Ed School,
at Samaspur Jagir, Delhi-91

Copy to:-

The Director of Education, EDMC,
Udyog Sadan, Plot No.419, FIE,
Patparganj Industrial Area, Delhi-110092.

CONDITIONS :

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This NOC may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

1. Name & address of the building : EDMC Co-Ed School at Samaspur Jagir, Delhi-91
 2. Building is comprised of : Ground floor only
 3. Type of Occupancy : Educational
 4. Type of Case : Renewal
 5. Details of Previous FSC : F6/DFS/MS/School/2012/4836 dated 31/12/2012
 6. Fire Safety direction letter No : F.16/Estate/CC/Fire safety/2011/3298 to 3398 dated 01.03.11
 7. Date of Inspection : 27/01/16
 8. Name of the Inspecting Officers: : R.K. Yadav (ADO)
 9. Name of the designation of Officer from the building side : Mrs. Anupam gupta (Principal)
 10. Year of Construction : 2004
 11. Applicant's letter No : dated 14/11/2015

S. No	Minimum Standards on fire safety requirements as per circular no. 3298 to 3398 Dated. 01.03.11	Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	Road width	6 m	6 m	MR
	Gate width	N.A	N.A	N.A
	Width of internal road	N.A	N.A	N.A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	Upper Floor	N.A	N.A	N.A
	Basement	N.A	N.A	N.A
	B. Width of Staircases			
	Upper Floor	N.A	N.A	N.A
	Basement	N.A	N.A	N.A
	c. Protection of exits			
	Fire check door	N.A	N.A	N.A
	Pressurization	N.A	N.A	N.A
	e. No. of continuous staircases to terrace	N.A	N.A	N.A
	g. Width of Corridor	N.A	N.A	N.A
	h. Door Size	N.A	N.A	N.A
3	Compartmentation.			
	Fire check door	N.A	N.A	N.A
	Sealing of electrical shafts	N.A	N.A	N.A
	Fire rating of shaft door	N.A	N.A	N.A
	Water curtain	N.A	N.A	N.A
	Fire Dampers	N.A	N.A	N.A
4	Smoke Management System.			
	Basement	N.A	N.A	N.A
	Upper floor	N.A	N.A	N.A
5.	Fire Extinguisher			
	Total numbers	02no.	4no.	MR
	types	CO ₂ & ABC	CO ₂ & ABC	MR
	IS marking	ISI marked	ISI marked	MR

6	First-aid-Hose Reels.			
	Total numbers of each floor	N.A	N.A	N.A
	Length of hose reel hose	N.A	N.A	N.A
	Nozzle diameter	N.A	N.A	N.A
7	Automatic fire detection and alarming system.			
	Type of detectors	N.A	N.A	N.A
	Location of main panel	N.A	N.A	N.A
	Location of repeater panel	N.A	N.A	N.A
	Alternate source of power	N.A	N.A	N.A
	Hooters	N.A	N.A.	N.A.
8	MOEFA	N.A	N.A	N.A
9	Public address System.	N.A	N.A	N.A
10	Automatic Sprinkler System.			
	basement	N.A	N.A	N.A
	upper floor	N.A	N.A	N.A
	sprinkler above false ceiling	N.A	N.A	N.A
11	Internal Hydrants			
	size of riser/down-comer	N.A	N.A	N.A
	Number of hydrants per floor	N.A	N.A	N.A
	Hose Box	N.A	N.A	N.A
12	Yard Hydrants.			
	Total number of hydrants	N.A	N.A	N.A
	Hose Box	N.A	N.A	N.A
13	Pumping Arrangements.			
	Ground Level	N.A	N.A	N.A
	Discharge of main Pump	N.A	N.A	N.A
	Head of Main Pump	N.A	N.A	N.A
	Number of main pumps	N.A	N.A	N.A
	Jockey pump out put	N.A	N.A	N.A
	Jockey pump head	N.A	N.A	N.A
	Standby pump out put	N.A	N.A	N.A
	Standby pump Head	N.A	N.A	N.A
	Auto Starting /Manual stopping	N.A	N.A	N.A
	Pump House Access			
	Terrace Level	N.A	N.A	N.A
	Discharge of pump	N.A	N.A	N.A
	Head of the Pump	N.A	N.A	N.A
	Power supply	N.A	N.A	N.A
	Auto Starting of pump	N.A	N.A	N.A
		N.A	N.A	N.A
14	Captive Water Storage for Fire Fighting.			
	Underground tank capacity	N.A	N.A	N.A
	Draw-off connection	N.A	N.A	N.A
	Fire service inlet	N.A	N.A	N.A
	Access to tank	N.A	N.A	N.A
	Overhead Tank capacity	N.A	N.A	N.A

15	Exit Signage.	N.A	N.A	N.A
16	Provision of Lifts.			
	Pressurization of Lift Shaft	N.A	N.A	N.A
	Pressurization of Lift lobby	N.A	N.A	N.A
	Communication in lift car	N.A	N.A	N.A
	Firemen's grounding switch	N.A	N.A	N.A
	Lift Signage	N.A	N.A	N.A
17	Standby power supply	N.A	N.A	N.A
18	Refuge Area.			
	Total area	N.A	N.A	N.A
	Location	N.A	N.A	N.A
19	Fire Control Room			
	Detector system panel	N.A	N.A	N.A
	Flow switch panel	N.A	N.A	N.A
	PA system panel	N.A	N.A	N.A
	Batter backup	N.A	N.A	N.A
	Building Floor Plans	N.A	N.A	N.A
20	Special Fire Protection systems for protection of special Risks, if any:	N.A	N.A	N.A

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules. The FSC issued vide letter no. F6/DFS/MS/School/2012/4836 dated 31/12/2012 renewal under the circular no. F.16/Estate/CC/Fire safety/2011/3298 to 3398 dated 01.03.11 is recommended.

Signature of the Inspecting Officer

Name- R.K. Yadav

Designation- ADO(LN)

DO(ED)

Submitted for approval please.

Dy CFO (NDW)

11/11/16
5/2/16

