

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.

E-mail:- cfohq.dlfire@nic.in

No. F.6/DFS/MS/FH/2016/SZ

1223

Fax: - 011-23412593

Dated:

09/02/16

FIRE SAFETY CERTIFICATE

Certified that the **Mittal Farm House**, K.H. No. 47/16, 48/19, 48/20, 48/21, 48/22 & 48/26, Village Paprawat, Najafgarh, New Delhi-110043, is comprised of Ground floor only (Two rooms & toilet) was inspected by the officers concerned of this department on 19.01.2016 in the presence of Sh. Surender (In-charge) and found that the said farm house have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premises is fit for occupancy class Group D "Assembly" building w.e.f. the date of issue of this certificate for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed overleaf.

Issued on.....09/02/16.....at New Delhi.



(DR. G.C. MISRA)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE

OK Sam
05/02/16

Copy to:-

1. The Executive Engineer (Bldg.),
South Delhi Municipal Corporation,
Building Deptt. Najafgarh Zone,
Najafgarh, New Delhi-110043
2. Smt. Sunita Mittal (Owner),
Mittal Farm House, K.H. No. 47/16, 48/19, 48/20, 48/21, 48/22 & 48/26,
Village Paprawat, Najafgarh, New Delhi 110043.

Ground floor only (two rooms & toilet)
(Mittal Farm House, K.H. No. 47/16, 48/19, 48/20, 48/21, 48/22 & 48/26, Village Paprawat,
Najafgarh, New Delhi-110043)

INSPECTION REPORT

1. Name & address of the building : Mittal Farm House, K.H. No. 47/16, 48/19, 48/20, 48/21, 48/22 & 48/26, Village Paprawat, Najafgarh, New Delhi-110043.
2. Type of Occupancy : Group D "Assembly"
3. Type of Case : Renewal
4. Details of Previous NOC : F.6/DFS/MS/FH/2013/459 dated 01.02.2013.
5. Fire Safety directives letter No : N/A
6. Date of inspection : 19.01.2016
7. Name of Inspecting Officer : D.O S.K.Tomar & A.D.O. Sandeep Duggal
8. Name and designation of officers
From the building side : Sh. Surender (In-charge)
9. Year of Construction : 2012
10. Applicant's letter No. : Letter No. Nil dated 06.01.2016

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	Accessible 05 mtrs. —	18 mtrs 05 mtrs. 05 mtrs.	M/R M/R M/R
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	N/A	N/A	Ground Floor Only
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basements 	N/A	N/A	Ground Floor Only
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	N/A	N/A	N/A
		N/A	N/A	N/A
	d. No. of continuous staircases to terrace	N/A	N/A	N/A
	e. Width of Corridor	N/A	N/A	N/A
	f. Door Size	N/A	150 cms X 205 Cms	N/A
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
4.	Smoke Management System			
	<ul style="list-style-type: none"> • Basements 	N/A	N/A	No basement

Sam

Ground floor only (two rooms & toilet)
(Mittal Farm House, K.H. No. 47/16, 48/19, 48/20, 48/21, 48/22 & 48/26, Village Paprawat,
Najafgarh, New Delhi-110043)

	• Upper floors	N/A	N/A	Ground Floor Only
5.	Fire Extinguishers			
	• Total numbers	06 no's	Provided	M/R
	• Types	ABC/CO2 type	Provided	M/R
	• IS marking	ISI marked	ISI marked	M/R
6.	First-Aid Hose Reels			
	• Total numbers on each floor	One	Provided	M/R
	• Length of hose reel hose	30 mtrs	Provided	M/R
	• Nozzle diameter	5 mm	Provided	M/R
7.	Automatic fire detection and alarming system			
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	Required	Provided	M/R
	• Hooters' Location	N/A	N/A	N/A
8.	MOEFA	Required	Provided	M/R
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	• Basement	N/A	N/A	N/A
	• Ground Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down-comer	100 mm	100 mm	M/R
	• Number of hydrants per floor	One	One	M/R
	• Hose Box	One	One	M/R
12.	Yard Hydrants			
	• Total number of hydrants	Four	Four	M/R
	• Hose Box	Two	Two	M/R
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/Manual Stopping	N/A	N/A	N/A
		N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A

500

Ground floor only (two rooms & toilet)
(Mittal Farm House, K.H. No. 47/16, 48/19, 48/20, 48/21, 48/22 & 48/26, Village Paprawat,
Najafgarh, New Delhi-110043)

	<ul style="list-style-type: none"> • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	450 LPM	450 LPM	M/R
		40 mtrs	40 mtrs	M/R
		Required	Provided	M/R
		Required	Provided	M/R
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	N/A	N/A	N/A
		N/A	N/A	N/A
		—	Provided	M/R
		N/A	N/A	N/A
		10000 ltrs	10000 ltrs	M/R
		Required	Provided	M/R
15.	Exit Signage.			
16.	Provision of Lifts.			(No Lift)
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17.	Standby power supply	Required	DG Set 125 KVA	M/R
18.	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	N/A	N/A	N/A
		N/A	N/A	N/A
19.	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Battery backup • Building Floor Plans 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A

San

Ground floor only (two rooms & toilet)
(Mittal Farm House, K.H. No. 47/16, 48/19, 48/20, 48/21, 48/22 & 48/26, Village Paprawat,
Najafgarh, New Delhi-110043)

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter number F.6/DFS/MS/FH/2013/459 dated 01.02.2013 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Note: - The Farm House building having two rooms with toilet and one pump house comprised of ground floor only.

S.K. Tomar

Signature of Inspecting Officer

Name:- S.K. Tomar

Designation:- Divisional Officer

Sandeep
21/1/2016

Signature of Inspecting Officer

Name:- Sandeep Duggal

Designation:- Asstt. Divisional Officer

Dy. C.F.O (South Zone)

Abhijit
25/1/16

Cfo South

29/1

