GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE NEW DELHI-110 001.

E-mail:- cfohq.dlfire@nic.in
No. F6/DFS/MS/ Petel 2016/52/238

Fax: - 011-23412593
Dated: / 0/@2/16

FIRE SAFETY CERTIFICATE

Certified that the **Sher Service Station**, Indian Oil Corporation Limited Petrol Pump, Block C, Commercial Centre, Pankha Road, Janakpuri, New Delhi-110058, is comprised of ground floor only. The Petrol Pump was inspected by the officer concerned of this department on 09.01.2016 in the presence of Sh. Nooruddin (Manager) and found that the owner have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises **(Only petrol pump)** is fit for occupancy class Group J Hazardous Building (Retail Outlet) w.e.f. the date of issue of this certificate for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed below.

(DR. G.C. MISRA) CHIEF FIRE OFFICER DELHI FIRE SERVICE

Copy to:-

1. The Manager,
Sher Service Station, Indian Oil Corporation Limited Petrol Pump, Block C,
Commercial Centre, Pankha Road, Janakpuri New Delhi-110058.

Following fire safety directives must be adhered to –

- 1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
- 2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
- 3. The trained staff should be available round the clock.
- 4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
- 5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
- 6. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
- 7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

Comprised of ground floor only. (Six rooms having offices, servicing area & stores etc. are on ground & first floor). Sher Service Station, Indian Oil Corporation Limited Petrol Pump, Block C, Commercial Centre, Pankha Road, Janakpuri New Delhi-110058.

INSPECTION REPORT

1. Name & address of the building: Sher Service Station, Indian Oil Corporation Limited Petrol Pump,

Block C, Commercial Centre, Pankha Road, Janakpuri New Delhi-58

2. Type of Occupancy : Group J (Hazardous Building)

3. Type of Case : New
4. Details of Previous NOC : N/A
5. Fire Safety directives letter No : N/A
6. Date of inspection : 09.01.2016

7. Name of Inspecting Officer : A.D.O. Sandeep Duggal

8. Name and designation of officers

From the building side : Sh. Nooruddin (Manager)

9. Year of Construction : Before 2010 10. Applicant's letter No. : Nil dated Nil

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR			
1.	Access to building						
	Road width	Accessible	12 mtrs	M/R			
	Gate width		Open	_			
	Width of internal road		_				
2.	Number, Width, Type & Arrangement of Exits						
	a. Number of staircases						
	Upper Floors	N/A	N/A	Petrol pump is on			
	Basements	N/A	N/A	ground floor No basement			
	b. Width of staircases	IN/A	IN/A	140 bascificht			
	Upper Floor	27/4	- DT/A	Petrol pump is on			
	Basements	N/A	N/A	ground floor			
	c. Protection of exits	N/A	N/A	No basement			
	Fire check door						
	Pressurization	N/A	N/A	N/A			
		N/A	N/A	N/A			
	d. No. of continuous staircases to		117 (0), 104(0)				
	terrace	N/A	N/A	N/A			
	e. Width of Corridor	N/A	N/A	N/A			
	f. Door Size	N/A	N/A	N/A			
3.	Compartmentation		8				
	Fire check door	N/A	N/A	N/A			
	 Sealing of electrical shafts 	N/A	N/A	N/A			
	Fire Rating of shaft door	N/A	N/A	N/A			
	Water Curtain	N/A	N/A	N/A			
	Fire Dampers	N/A	N/A	N/A			
ļ.	Smoke Management System						
	Basements	N/A	N/A	No basement			



Comprised of ground floor only. (Six rooms having offices, servicing area & stores etc. are on ground & first floor). Sher Service Station, Indian Oil Corporation Limited Petrol Pump, Block C, Commercial Centre, Pankha Road, Janakpuri New Delhi-110058.

N/A N/A N/A Upper floors Fire Extinguishers 5. 17 no's M/R 10 no's Total numbers Provided ABC/CO2/Foam Types M/R type Provided IS marking M/R ISI marked ISI marked **First-Aid Hose Reels** 6. N/A N/A N/A Total numbers on each floor N/A N/A N/A Length of hose reel hose N/A N/A N/A Nozzle diameter Automatic fire detection and alarming system 7. N/A N/A N/A Type of detectors N/A N/A N/A Location of Main Panel N/A N/A Location of Repeater Panel N/A Alternate source of power N/A N/A N/A N/A Hooters' Location N/A N/A N/A N/A N/A 8. **MOEFA** N/A N/A N/A **Public Address System** 9. Automatic Sprinkler System 10. N/A N/A N/A Basement N/A N/A N/A **Ground Floor** N/A N/A N/A Sprinkler above false ceiling **Internal Hydrants** 11. N/A N/A N/A Size of riser/down-comer N/A N/A N/A Number of hydrants per floor N/A N/A N/A Hose Box 12. **Yard Hydrants** N/A N/A N/A Total number of hydrants N/A N/A N/A **Hose Box Pumping Arrangements** 13. **Ground Level** N/A N/A N/A Discharge of main Pump N/A > Head of Main pump N/A N/A > Number of main pumps N/A N/A N/A > Jockey Pump out put N/A N/A N/A > Jockey pump head N/A N/A N/A > Standby Pump out put N/A N/A N/A N/A N/A Standby Pump Head N/A > Auto Starting/Manual Stopping N/A N/A N/A



Comprised of ground floor only. (Six rooms having offices, servicing area & stores etc. are on ground & first floor). Sher Service Station, Indian Oil Corporation Limited Petrol Pump, Block C,

Commercial Centre, Pankha Road, Janakpuri New Delhi-110058.

		N/A N/A	N/A N/A	N/A N/A		
			N/A	N/A		
		N/A	N/A	N/A		
		N/A	N/A	N/A		
Fire Control Roo	m	1	er er			
> Total Area > Location		N/A N/A	N/A	N/A		
Keluge Alea.		NT/A	N/A	N/A		
	ippiy					
Gt. II.	nnly	N/A	Provided DG Set 62.5 KVA	N/A		
Lift Signage	e	N/A	N/A	N/A		
		N/A	N/A	N/A		
		N/A	N/A	N/A		
		N/A	N/A	N/A		
	ion of Lift Shaft	N/A		N/A		
Previous of Lifts No Lift						
Exit Signage.		14/71				
Overneda				N/A		
		1		N/A		
The second of th				N/A		
The state of the s				N/A		
				N/A		
Captive Water Storage for fire fighting						
> Auto St	arting of pump	N/A	IV/A	11111		
				N/A		
> Head of	the pump			N/A		
The second secon		10003818.001 101		N/A N/A		
Terrace leve	ouse Access		27/4	N/A		
	Dischard Head of Power S Auto St Captive Water Sto Undergroun Draw-o Fire ser Access Overhead T Exit Signage. Provision of Lifts. Pressurizat Pressurizat Communic Fireman's Lift Signage Standby power st Refuge Area. Total Area Location Fire Control Roo Detector S Flow Swite PA System	 Discharge of pump Head of the pump Power Supply Auto Starting of pump Underground tank capacity Draw-off connection Fire service inlet Access to tank Overhead Tank capacity Exit Signage. Provision of Lifts. Pressurization of Lift Shaft Pressurization of Lift Car Fireman's Grounding Switch Lift Signage Standby power supply Refuge Area. Total Area Location Fire Control Room Detector System Panel Flow Switch Panel PA System Panel 	Discharge of pump Head of the pump N/A Power Supply Auto Starting of pump Underground tank capacity Fire service inlet Access to tank Overhead Tank capacity Pressurization of Lift Shaft Pressurization of Lift Car Fireman's Grounding Switch Lift Signage Provision of Lift Signage Provision of Lift Signage Provision of Lift Signage Provision of Lift Signage N/A N/A Standby power supply Refuge Area. Detector System Panel Flow Switch Panel PA System Panel PA System Panel N/A	Discharge of pump Head of the pump N/A		



Comprised of ground floor only. (Six rooms having offices, servicing area & stores etc. are on ground & first floor). Sher Service Station, Indian Oil Corporation Limited Petrol Pump, Block C, Commercial Centre, Pankha Road, Janakpuri New Delhi-110058.

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the above substantial compliance of the minimum standards of fire prevention and fire safety measures as required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

Note:- Sand buckets 16 no.'s & no smoking boards are provided in the premises.

Signature of Inspecting Officer

Signature of Inspecting Officer

Name:- Sandeep Duggal

Name:-

Designation: - Asstt.Divisional Officer

Designation:-

D.O. (South West)

1