

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

No.

FG/DFS/ms/school/2016/^{MD21}253

Dated:

12/02/16

FIRE SAFETY CERTIFICATE

Certified that the The Neev School is running at ground plus one floor of a building comprising of ground plus three upper floors at B-7 Mandawali, I.P.Extn.Patparganj, Delhi-92 owned/occupied by The Neev School have complied with the fire prevention and fire safety requirements in accordance with the circular no. F-16/Estate/CC/FS/2011/3298 to 3398 dated 01/03/11 issued by the Director of Education and verified by the officer concerned of this department on 25/01/16 in the presence of Mrs.Anshu Goel (Principal) of the school and found that the GF+FF of building is fit for occupancy class B 'Educational Building' for with effect from12/02/16 for a period of **three** years, subject to conditions printed overleaf.

Issued on.....12/02/16.....at New Delhi by



(Dr.G.C.Misra)
Chief Fire Officer
Ph.011-23414333

To,

Principal,
The Neev School, B-7 Mandawali,
I.P.Extn.Patparganj, Delhi-92,

Copy:-

The Director of Education,
Udyog Sadan, Plot No.419, FIE,
Patparganj Industrial Area, Delhi-110092.

q/c
KS

- Conditions -

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in good working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety certificate can not be treated in any case for regularizations of unauthorized construction if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
7. "The owner /occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form'J'[sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry"

1. Name & address of the building : The Neev School, D-7 Main Road,
I.P.Extn.Patparganj, Delhi-92.
2. Building is comprised of : G+3 Upper floors.
(school is running on ground & 1st floor only)
- 3.Type of Occupancy : Educational
- 4.Type of Case : New
- 5.Details of Previous NOC letter : Nil
- 6.Fire Safety direction letter No : F.16/Estate/CC/Fire Safety/2011/3298 to
3398 dtd. 01/03/11
- 7.Date of Inspection : 27/01/16 & 08/02/16
- 8.Name of the Inspecting officers : ADO R.K.Yadav
- 9.Name and designation of Officer
from the building side : Mrs.Anshu Goel (Principal)
- 10.Year of Construction : 1996
- 11.Applicant's letter no. : 01/01/16

| S. N O. | Minimum Standards on fire prevention and fire safety U/R33 | Circular Requirement | Provided at Site | Remarks MR/NMR |
|---------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------|-----------------------------|----------------|
| 1 | Access to building | 06 mtr. | 06mtr. | MR |
| | <ul style="list-style-type: none"> Road width Gate width Width of internal road | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| 2 | Number, Width, Type and Arrangement of Exits | | | |
| | a. Number of Staircases | 01 Nos. | 02 Nos. | MR |
| | <ul style="list-style-type: none"> Upper Floor Basement | N/A | N/A | N/A |
| | B. Width of Staircases | 1.5 M | 2 Nos. (1.04 M & 1.07 M) | MR |
| | <ul style="list-style-type: none"> Upper Floor Basement | N/A | N/A | N/A |
| | c. Protection of exits | N/A | N/A | N/A |
| | <ul style="list-style-type: none"> Fire check door Pressurization | N/A | N/A | N/A |
| | d. No. of continuous staircases to terrace | N/A | N/A | N/A |
| | e. Width of Corridor | 1.5 M | 2.5 M | MR |
| | f. Door Size | 1 M | 1 M | MR |
| 3 | Compartmentation. | N/A | N/A | N/A |
| | <ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire rating of shaft door Water curtain Fire Dampers | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| 4 | Smoke Management System. | N/A | N/A | N/A |
| | <ul style="list-style-type: none"> Basement Upper floor | N/A | N/A | N/A |
| 5. | Fire Extinguishers | 02 nos. | 06 nos. | MR |
| | <ul style="list-style-type: none"> Total numbers types | ABC /CO ₂ | ABC /CO ₂ | MR |
| | | | | MR |

| | | | | |
|----|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----|-----|-----|
| 6 | First-aid-Hose Reels. | | | |
| | Total numbers of each floor | N/A | N/A | N/A |
| | <ul style="list-style-type: none"> Length of hose reel hose Nozzle diameter | N/A | N/A | N/A |
| 7 | Automatic fire detection and alarming system. | | | |
| | <ul style="list-style-type: none"> Type of detectors Location of main panel Location of repeater panel Alternate source of power Hooter's location | N/A | N/A | N/A |
| 8 | MOEFA | N/A | N/A | N/A |
| 9 | Public address System. | N/A | N/A | N/A |
| 10 | Automatic Sprinkler System. | | | |
| | <ul style="list-style-type: none"> Basement upper floor sprinkler above false ceiling | N/A | N/A | N/A |
| 11 | Internal Hydrants | | | |
| | <ul style="list-style-type: none"> size of riser/down-comer Number of hydrants per floor Hose Box | N/A | N/A | N/A |
| 12 | Yard Hydrants. | | | |
| | <ul style="list-style-type: none"> Total number of hydrants Hose Box | N/A | N/A | N/A |
| 13 | Pumping Arrangements. | | | |
| | <ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main Pump Number of main pumps Jockey pump out put Jockey pump head Standby pump out put Standby pump Head Auto Starting /Manual stopping Pump House Access Terrace Level <ul style="list-style-type: none"> Discharge of pump Head of the Pump Power supply Auto Starting of pump | N/A | N/A | N/A |
| 14 | Captive Water Storage for Fire Fighting. | | | |
| | <ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity | N/A | N/A | N/A |
| 15 | Exit Signage. | N/A | N/A | N/A |

| | | | | |
|----|--------------------------------------------------------------------------|-----|-----|-----|
| 16 | Provision of Lifts. | | | |
| | • Pressurization of Lift Shaft | N/A | N/A | N/A |
| | • Pressurization of Lift lobby | N/A | N/A | N/A |
| | • Communication in lift car | N/A | N/A | N/A |
| | • Firemen's grounding switch | N/A | N/A | N/A |
| | • Lift Signage | N/A | N/A | N/A |
| 17 | Standby power supply | N/A | N/A | N/A |
| 18 | Refuge Area. | | | |
| | • Total area | N/A | N/A | N/A |
| | • Location | N/A | N/A | N/A |
| 19 | Fire Control Room | | | |
| | • Detector system panel | N/A | N/A | N/A |
| | • Flow switch panel | N/A | N/A | N/A |
| | • PA system panel | N/A | N/A | N/A |
| | • Battery backup | N/A | N/A | N/A |
| | • Building Floor Plans | N/A | N/A | N/A |
| 20 | Special Fire Protection systems for protection of special Risks, if any: | N/A | N/A | N/A |

The fire protection systems provided in the building were tested/checked at the time of inspection.

Keeping in view the compliance of the minimum standards on fire prevention and fire safety required under the circular no. F16/Estate/CC/FireSafety/2011/3298 to 3398 dated 01/03/11, it is recommended to grant Fire Safety Certificate.

DO/ED)

R.K. Yadav
10/21/2016

Signature of the Inspecting officer

Name- R.K. Yadav

Designation- ADO

Submitted for approval please.

Dy CFO (NO2)

Kind
10/21/16

The bldg is GF+03
School is running only
at GF+FF.