

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001**

No.F6/DFS/MS/2016/ NDZ/ 254

Dated :-----12/02/16

**FIRE SAFETY CERTIFICATE**

Certified that the **Videsh Sanchar Bhawan** located at **Bangla Sahib Road, New Delhi** comprised of **Basement + Ground + 7 Upper floor** was granted FSC by this department vide letter No.F6/DFS/MS/2012/2087 dated 07/06/12. The premises was re-inspected by the officer concerned of this department on 06/02/16 in the presence of **Sh. Sanjay Sharma (Asstt. Manager) & Sh. Ashutosh Kumar** and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class Business, Sub Division-E with effect from -----12/02/16----- for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued -----12/02/16-----at New Delhi by.

  
(Dr. G. C. Misra)  
Chief Fire Officer  
Ph-011-23414333

Copy to:-

1. Sh. Ashutosh Kumar,  
Videsh Sanchar Bhawan,  
Bangla Sahib Road, New Delhi.

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".

### INSPECTION REPORT

1. Name & address of the building : Videsh Sanchar Bhawan, Bangla Sahib Road, New Delhi.
2. Type of occupancy : Business Building  
(B + Gr. + 07 Upper floors)
3. Type of case:- : Renewal
4. Details of previous FSC : F.6/DFS/MS/2012/2087 dated 07/06/2012
5. Fire safety directives No. : NA
6. Date of inspection:- 06/02/16
7. Name of the inspecting officer : Sh. Gurmukh Singh DO/CD,  
Sh. M.K. Sharma ADO/CC
8. Name & designation of officer  
From the building side : Sh. Sanjay Sharma (Asth. Manager) &  
Sh. Ashutosh Kumar
9. Year of construction : 1976
10. Applicant's letter No : Nil Dated 25/01/2016

Old Case

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement Existing	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	06 mtr.	06 mtr.	MR
	2) Gate width	05 mtr.	05 mtr. (TwoNos.)	MR
	3) Width of internal road	06 mtr.	06 mtr.	MR
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	02 No.	02 No.	MR
	2. Basements	02 No	02 No.& 01 Ramp	MR
	B. Width of staircase			
	1. Upper floors	1.25 & 0.80 mtr.	1.35 & 1.15 mtr.	MR
	2. Basements	1.25 mtr.	1.35 & 1.15 mtr. 01 ramp 3.5 mtr.	MR
	C. Protection of exits			
	1. Fire check door	Required	Provided	MR
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	01 No	01 No	MR
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	1 Mtr.	1 Mtr.	MR
3.	Compartmentation			
	1) Fire check door	Required	Provided	MR
	2) Sealing of electrical shafts	Required	Provided	MR
	3) Fire rating of shaft door	Required	Provided	MR
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	Required	Provided	MR
4.	Smoke Management System			
	1) Basements	30 ACPH	Provided	MR
	2) Upper floors	12 ACPH	Provided	MR

h-

mesb.

5.	Fire Extinguishers			
	1) Total numbers	215 Nos.	219 Nos.	MR
	2) Types	ABC & CO2	ABC, CO2 & W.CO2	MR
	3) ISI marking	Required	Provided	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	01 No.	01 No.	MR
	2) Length of hose reel hose	30 m	30 m	MR
	3) Nozzle diameter	5 mm	5 mm	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	Required	Provided	MR
	2) Location of main panel	Gr. Floor	Provided	MR
	3) Location of repeater panel	Required	Provided 4 <sup>th</sup> floor	MR
	4) Alternate source of power	Required	Provided	MR
	5) Hooter's Location	Required	Provided Every floor Near S/case	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	1) Basement	Required	Provided	MR
	2) Upper floors	Required	Provided	MR
	3) Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	1) Size of riser/down-comer	150 MM	150 MM	MR
	2) Number of hydrants per floor	01	01	MR
	3) Hose box each floor	01	01	MR
12.	Yard Hydrants			
	1) Total number of hydrants	04	04	MR
	2) Hose box	04	04	MR
13.	Pumping Arrangement			
	1) Ground level			
	a) Discharge of main pump	2850 LPM	2850 LPM	MR
	b) Head of main pump	80 mtr.	80 mtr.	MR
	c) Number of main pump	01	01	MR
	d) Jockey pump out put (2 Nos.)	220 LPM	220 LPM	MR
	e) Jockey pump head	80 mtr.	80 mtr.	MR
	f) Stand by pump output	2800 LPM	2800 LPM	MR
	g) Stand by pump head	80 mtr.	80 mtr.	MR
	h) Auto starting/Manual stopping	Required	Provided	MR
	2) Terrace level			
	a) Discharge of pump	N/A	N/A	N/A
	b) Head of pump	N/A	N/A	N/A

h

MR

	c) Power supply	N/A	N/A	N/A
	d) Auto starting of pump	N/A	N/A	N/A
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	1,00,000 ltr.	1,00,000 ltr.	MR
	a) Draw-off connection	Required	Provided	MR
	b) Fire service inlet	Required	Provided	MR
	c) Access to tank	Required	Provided	MR
	d) Over head tank capacity	20,000 Ltrs.	20,000 Ltr.	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	Required	Provided	MR
	d) Fireman's switch	Required	Provided	MR
	e) Lift signage	Required	Provided	MR
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area			
	Total area location	N/A	N/A	N/A
19.	Fire Control Room			
	a) Detector system panel	Required	Provided	MR
	b) Flow switch panel	Required	Provided	MR
	c) PA system panel	Required	Provided	MR
	d) Battery backup	Required	Provided	MR
	e) Building floor plan	NA	NA	NA
20.	Special Fire Protection System for Protection of special Risk, if any:			MR

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

Shortcomings communicated vide letter No. F6/DFS/MS/2015/1466 & 2662 dated 06/07/2015 & 22/12/015 have been rectified.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter no.F.6/DFS/MS/2012/2087 dated 07/06/2012 renewal under rule 35 of the Delhi Fire Service rules 2010, is recommended.

Signature of the Inspecting Officer

Name :- G.S Chauhan  
Designation :- DO (CD)

Signature of the Inspecting Officer

Name :- M.K. Sharma  
Designation :- ADO (CC)



By CPO (NDZ)

*[Handwritten signatures and initials]*