

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. FD/DF/MS/Enroll/2016/ND2/259

Dated: 16/02/16


FIRE SAFETY CERTIFICATE

Certified that the Plot No.377,FIE, Patpargang Industrial Area, Delhi-92,comprised of basement, stilt, ground plus two upper floors owned/occupied by Mr.Lalit Kumar Tomar & Anil Kumar Sharma have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of this department on 25/01/16 in the presence of Mr.Lalit Tomar and that the building is fit for occupancy Group G-1 (Industrial Building), with effect from 16/2/16 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed overleaf.

Issued on 16/02/16 at New Delhi by



(Dr.G.C.Misra)
Chief Fire Officer
Ph.011-23414333



To,

The Excutive Engineer (Bldg.)HQ,
East Delhi Municipal Corporation,
Udyog Sadan, Patpargang, Industrial Area Delhi-92.

Copy to:-

Mr..Lalit Kumar Tomar & Anil Kumar Sharma,
Plot No.377,FIE Patpargang,
Industrial Area Delhi-92.

Conditions

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
7. "The owner /occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form'J'[sub rule(1) of rule 37] along with a copy of this certificate, six Months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : Plot No. 377, FIE Industrial area , Delhi-92.
2. Building is comprised of : B+ stilt +G+2 upper floor
3. Type of Occupancy : Industrial Building
4. Type of Case : New Case
5. Details of Previous NOC : Nil
6. Fire Safety direction letter No : F.6/DFS/MS/BP/2013/221 dated:06.08.2013
7. Date of Inspection : 25/01/16
8. Name of the Inspecting Officers: : R.K.Yadav (ADO)
9. Name of the designation of Officer
from the building side : Mr. Lalit Tomar
10. Year of Construction : 2015
11. Applicant's letter No : Dated 13/01/16

S.No	Minimum Standards on fire prevention and fire safety U/R33	Directives Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	Road width	9 m	25 m	MR
	Gate width	4.5 m	4.5 m	MR
	Width of internal road	N.A	N.A	N.A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	Upper Floor	2 Nos.	2 Nos.	MR
	Basement	2 Nos.	2 Nos.	MR
	B. Width of Staircases			
	Upper Floor	1.5 M	1.5 M each	MR
	Basement	1.5 M	1.5 M each	MR
	c. Protection of exits			
	Fire check door	Required	Provided	MR
	Pressurization	N.A	N.A	N.A
	d. No. of continuous staircases to terrace	01 no.	2 Nos.	MR
e. Width of Corridor	N.A	N.A	N.A	
f. Door Size	1 m	1 m	MR	
3	Compartmentation.			
	Fire check door	Required	Provided	MR
	Sealing of electrical shafts	Required	Provided	MR
	Fire rating of shaft door	2 hrs.	Provided	MR
	Water curtain	N.A	N.A	N.A
	Fire Dampers	N.A	N.A	N.A
4	Smoke Management System.			
	Basement	Required	Provided	MR
	Upper floor	Required	Provided	MR

5.	Fire Extinguisher			
	Total numbers	10 no.	Provided	MR
	types	CO ₂ & ABC	Provided	MR
	IS marking	ISI marked	Provided	MR
6	First-aid-Hose Reels.			
	Total numbers of each floor	01 no.	Provided	MR
	Length of hose reel hose	30 m	Provided	MR
	Nozzle diameter	5 mm	Provided	MR
7	Automatic fire detection and alarming system.			
	Type of detectors	Smoke	Provided	MR
	Location of main panel	Required	Provided	MR
	Location of repeater panel	Required	Provided	MR
	Alternate source of power	N.A	N.A	N.A
	Hooters's location	Staircase	Provided	MR
8	MOEFA	Required	Provided	MR
9	Public address System.	N.A	N.A	N.A
10	Automatic Sprinkler System.			
	Basement	Required	Provided	MR
	upper floor	Required	Provided	MR
	sprinkler above false ceiling	N.A	N.A	N.A
11	Internal Hydrants			
	size of riser/Wet riser	100 mm	Provided	MR
	Number of hydrants per floor	1 no.	Provided	MR
	Hose Box	1 no.	Provided	MR
12	Yard Hydrants.			
	Total number of hydrants	04 Nos.	Provided	MR
	Hose Box	04 Nos.	Provided	MR
13	Pumping Arrangements.			
	• Ground Level	Required	Provided	MR
	➤ Discharge of main Pump	2280 LPM	Provided	MR
	➤ Head of Main Pump	70 M	Provided	MR
	➤ Number of main pumps	1 No.	Provided	MR
	➤ Jockey pump out put	180 LPM	Provided	MR
	➤ Jockey pump head	70 M	Provided	MR
	➤ Standby pump out put	2280 LPM	Provided	MR
	➤ Standby pump Head	70 M	Provided	MR
	➤ Auto Starting /Manual stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace Level	Required	Provided	MR
	➤ Discharge of pump	900 LPM	900 LPM	MR
	➤ Head of the Pump	40 M	40 M	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR

14	Captive Water Storage for Fire Fighting.			
	Underground tank capacity	75,000 Ltrs.	Provided	MR
	Draw-off connection	Required	Provided	MR
	Fire service inlet	Required	Provided	MR
	Access to tank	Required	Provided	MR
	Overhead Tank capacity	20000 Liters	20000 Liters	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	Pressurization of Lift Shaft	N.A	N.A	N.A
	Pressurization of Lift lobby	N.A	N.A	N.A
	Communication in lift car	N.A	N.A	N.A
	Firemen's grounding switch	N.A	N.A	N.A
	Lift Signage	N.A	N.A	N.A
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	Total area	N.A	N.A	N.A
	Location	N.A	N.A	N.A
19	Fire Control Room			
	Detector system panel	N.A	N.A	N.A
	Flow switch panel	N.A	N.A	N.A
	PA system panel	N.A	N.A	N.A
	Batter backup	N.A	N.A	N.A
	Building Floor Plans	N.A	N.A	N.A
20	Special Fire Protection systems for protection of special Risks, if any:	N.A	N.A	N.A

The fire extinguishers provided in the building were tested/checked and found functional at the time of inspection.

Keeping in view the compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.

R.K. Yadav

Signature of the Inspecting Officer
Name: R.K.Yadav
Designation: ADO (LN)

DO(ED)