

FORM 'H' : FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[SEE SUB-RULE (1) OF RULE 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F6/DFS/MS/EH/WZ/2016/ 26 /

Dated: 18/02/16

FIRE SAFETY CERTIFICATE

Certified that the Cavendish Banquets at D-4, Udyog Nagar, New Delhi-110041 comprised of Basement, ground floor, first floor & second floor owned/occupied by Cavendish Banquets, **running on ground floor & first floor only** was issued NOC/FSC vide this office letter No. F6/DFS/MS/EH/2011/2888 dated 04/11/2011. The premises was re-inspected by the officer concerned of this department on 28/01/2016 in presence of Sh. Uttam Dutta (GM) and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have therefore, deemed complied with the requirement under Rule 33 of the Delhi Fire Service Rule 2010 and the building/premises is fit for **Class-D Assembly** occupancy with effect from.....18/02/16...for a period of three year in accordance with rule 36 unless renewed under 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under 38 of the Delhi Fire Service Rule 2010.

Issued on 18/02/16 at New Delhi by.


(Santokh Singh)
Chief Fire Officer
Delhi Fire Service
Tel. -011-23414250

Copy to :-

1. Mr. Uttam Dutta (GM), Cavendish Banquets at D-4, Udyog Nagar, New Delhi -110041.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provision of building bye laws.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction.
7. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
8. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

2. Type of Occupancy : Assembly (Banquet Hall)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/EH/2011/2888 dated 04/11/2011
5. Fire Safety directives Letter No. : F6/DFS/MS/BP/2011/1338 dated 30/06/2011
6. Date of inspection : 28/01/2016
7. Name of the Inspecting Officer : A.D.O. (JWP)
8. Name and designation of Officer
from the building side : Mr. Uttam Dutta (GM)
9. Year of Construction : 1996
10. Applicant's letter No. : -Nil dated 10/12/2015

| S No | Minimum standards on fire prevention and fire safety U/R 33 | BBL Requirements | Provided at site | Remarks MR/NMR |
|------|---|--------------------------------|------------------------------|----------------|
| 1. | Access of building | | | |
| | • Road width | 06 mtr | Provided | MR |
| | • Gate width | 4.5 mtr | Provided | MR |
| | • Width of internal road | Required | Provided | MR |
| 2. | Number, width, Type & Arrangements of exits | | | |
| | a. Number of staircases | | | |
| | • Upper floors | 2 | Provided | MR |
| | • Basements | 2 | Provided | MR |
| | b. Width of staircases | | | |
| | • Upper floors | Old Case | Old Case | Old Case |
| | • Basements | Old Case | Old Case | Old Case |
| | c. Protection of exits | | | |
| | • Fire check door | Required | Provided | MR |
| | • Pressurization | N/A | N/A | N/A |
| | d. No of continuous staircase to terrace | 2 | Provided | MR |
| | e. Width Of Corridor | NR | NR | NR |
| | f. Door Size | 2.00mtr | Provided | MR |
| 3. | Compartmentation | | | |
| | • Fire check door | Required | Provided | MR |
| | • Sealing of electrical shafts | Required | Provided | MR |
| | • Fire Rating of shaft door | Required | Provided | NR |
| | • Water Curtain | NR | NR | NR |
| | • Fire Dampers | Required | Only split A.C. are provided | NR |
| 4. | Smoke managements System | | | |
| | • Basements | Required | Not Provided | NMR |
| | • Upper floors | Required | Provided | MR |
| 5. | Fire Extinguishers | | | |
| | • Total numbers | 20 | 20 | MR |
| | • Types | ISI marked ABC/CO ₂ | Provided | MR |

| | | | | |
|-----|--|-------------|-----------------------|-----|
| | each floor | | Provided | MR |
| | • Length of hose reel hose | 30Mtr. | Provided | MR |
| | • Nozzle diameter | 5mm. | Provided | MR |
| 7. | Automatic fire detection and alarming system | | | |
| | • Type of detector | NR | NR | NR |
| | • Location of Main Panel | NR | NR | NR |
| | • Location of Repeater | NR | NR | NR |
| | • Alternate source of power | NR | NR | NR |
| | • Hooters' Location | NR | NR | NR |
| 8. | MOEFA | Required | Provided | MR |
| 9. | Public Address System | Required | Provided | MR |
| 10. | Automatic Sprinkler System | | | |
| | • Basements | Required | Provided | MR |
| | • Upper Floor | Required | Provided | MR |
| | • Sprinkler above false ceiling | Required | Provided | MR |
| 11. | Internal Hydrants | | | |
| | • Size of riser/down-comer | 150 mm | Provided | MR |
| | • Number of hydrants per floor | One | Provided | MR |
| | • Hose Box | Required | Provided | MR |
| 12. | Yard Hydrants | | | |
| | • Total number of hydrants | NR | NR | NR |
| | • Hose Box | NR | NR | NR |
| 13. | Pumping Arrangements | | | |
| | • Ground Level | | | |
| | • Discharge of main pump | NR | NR | NR |
| | ➤ Head of main pump | NR | NR | NR |
| | ➤ Number of main pumps | NR | NR | NR |
| | ➤ Jockey pump out put | NR | NR | NR |
| | ➤ Jockey pump head | NR | NR | NR |
| | ➤ Standby Pump out put | NR | NR | NR |
| | ➤ Standby Pump Head | NR | NR | NR |
| | ➤ Auto Starting/Manual stopping | NR | NR | NR |
| | ➤ Pump House Access | NR | NR | NR |
| | • Terrace level | | | |
| | ➤ Discharge of pump | 900 LPM | Provided | MR |
| | ➤ Head of the pump | 40 MH | Provided | MR |
| | ➤ Power supply | Required | Provided | MR |
| | ➤ Auto starting of pump | Required | Provided | MR |
| 14. | Captive water Storage for fire fighting | | | |
| | • Underground tank capacity | NR | Provided (50,000 ltr) | NR |
| | ➤ Draw of connection | Required | Provided | M/R |
| | ➤ Fire service inlet | Required | Provided | M/R |
| | ➤ Access to tank | Required | Provided | M/R |
| | • Overhead Tank capacity | 10,000 lts. | 20,000 Ltr. | M/R |

| 15 | Exit Signage | Required | Provided | M/R |
|-----|--|----------|----------|-----|
| 16. | Provision of Lifts | | | |
| | ➤ Pressurization of Lift Shaft | NR | NR | NR |
| | ➤ Pressurization of lift lobby | NR | NR | NR |
| | ➤ Communication in lift Car | NR | NR | NR |
| | ➤ Fireman's Grounding Switch | NR | NR | NR |
| | ➤ Lift Signage | NR | NR | NR |
| 17. | Standby power supply | Required | Provided | MR |
| 18. | Refuge Area | NR | NR | |
| | ➤ Total area | NR | NR | NR |
| | ➤ Location | NR | NR | NR |
| 19. | Fire control room | | | |
| | ➤ Detector system panel | NR | NR | NR |
| | ➤ Flow Switch Panel | NR | NR | NR |
| | ➤ PA System Panel | NR | NR | NR |
| | ➤ Battery backup | NR | NR | NR |
| | ➤ Building Floor Plans | NR | NR | NR |
| 20. | Special Fire Protection Systems for Protection of special Risks, if any; | NR | NR | NR |

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection. MCB and Conduit Metal Wiring has also been provided.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. F6/DFS/MS/EH/2011/2888 dated 04/11/2011 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Ashok Kumar Jaiswal
28/11/2016

Signature of the Inspecting Officer

Name : Ashok Kumar Jaiswal

Designation : A.D.O. (Jwala Puri)

D.O. / (w)

ah