

DUBLIIN SQUARE (A unit of aqua host. Pvt Ltd) Manglam Paradise Mall, Sector 3, Rohini.

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI

HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. FG/DFS/MS/SH/2016/WZ/259

Dated: 18/02/2016

FIRE SAFETY CERTIFICATE

Certified that DUBLIIN SQUARE (A unit of aqua host. Pvt Ltd) located in Mangalam Paradise Mall Plot no 8, Sector 3, Rohini, Delhi at 110 to 117 1st floor & 210 to 217 2nd floor in a premise comprised Basement, Ground + Five Upper Floors, owned/ occupied by Sh. Raman Gandotra have complied with the fire prevention & fire safety requirement in accordance with rule 33 of Delhi fire service rule 2010. The Manglam Paradise Mall has already been granted FSC by department letter no. FG/DFS/MS/2015/WZ/478 dated 21/03/2015 The premise was inspected by the officers concerned of this department on 18/01/2016 in presence of Sh. Raman Gandotra and found that the premises is fit for Assembly Building Div- D-5 occupancy with effect from 18/02/2016 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of Delhi Fire Service Rules, 2010.

1. Means of escape shall not be kept locked or bolted from outside and shall be easily open able by guests in an event of emergency.
2. All employees shall be acquainted with the use and maintenance of all the fire fighting installation/equipments.
3. The fire suppression / protection arrangements provided in the restaurant are to minimize losses, if maintained in good working condition. These systems cannot give any guarantee that there will be no fire or losses in the event of one.
4. Any loss of life and property due to non-functional of fire safety arrangements and other installations shall be the responsibility of the licensee.
5. This report may not in any way be treated as regularization of unauthorized construction, if any.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 18/02/16 at New Delhi by


(Santokh Singh)
Chief Fire Officer
Delhi Fire Service
Tel. -011-23414250

Copy to:

1. The Dy Health Officer, North Delhi Municipal Corporation, Health Department, Rohini Zone, Sector-V, Rohini, Delhi-110085 for information.
2. The Authority Signatory DUBLIIN SQUARE (A unit of aqua host. Pvt Ltd) at 110 to 117 1st floor & 210 to 217 2nd floor, Mangalam Paradise Mall Sec- 3, Rohini, Delhi.

INSPECTION REPORT

1. Name & address of the building: DUBLIIN SQUARE (A unit of aqua host. Pvt Ltd) at 110 to 117 Ist floor & 210 to 217 2nd floor, Manglam Paradise Mall Sector- 3, Rohini, Delhi 110085
2. Type of Occupancy : Assembly
3. Type of Case : New case
4. Details of previous NOC : F6/DFS/MS/2015/WZ/478 dated 21/03/2015 Mall NOC
5. Fire Safety directives letter No : nil
6. Date of inspection : 18 / 01 / 2016
7. Name of the Inspecting Officers : DCFO (WZ) & DO (NW)
8. Name and designation of officers
from the building side : Sh. Raman Gandotra
9. Year of Construction : 2008 / 2015
10. Applicant's letter No. : DHO/RZ/2015/888 Dated 30/09/2015.

	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	Accessible	M.R
	• Gate width	Accessible	Accessible	M.R
	• Width of internal road	---	---	---
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02 s/c	04 S/C GF to 5 th floor 01 S/C 1 st to 2 nd floor	M.R
	• Basements	N/A	N/A	N/A
	b. Width of staircases			
	• Upper Floors	150 cm each	P	M.R
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	R	P	M/R
	• Pressurization	--	--	--
	e. No. of continuous staircases to terrace	--	As per Mall	--
	g. Width of Corridor	--	--	--
	h. Door Size	2 mtr	2 mtr x 1 1.60 mtr x 1 1.20 mtr x 1	M/R
3	Compartmentation.			

DUBLIIN SQUARE (A unit of aqua host. Pvt Ltd) Manglam Paradise Mall, Sector 3, Rohini.

	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	R	P	M/R
		R	P	M/R
		R	As per Mall	M/R
		--	--	--
		--	--	--
4	Smoke Management System.	Exhaust Fan Provided		
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour	P	M/R
		12 a/c per hour	P	M/R
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	12 ISI marked	12 08 ABC & 04 Co2 Yes	M/R M/R M/R
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	03 30 m 5 mm	Provided with mall P P	M/R M/R M/R
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	Smoke Heat -- -- R each	P in Restaurant As per Mall As per Mall P P in Restaurant	M/R -- -- M/R M/R
8	MOEFA	R	P	M/R
9	Public Address System.	R	P	M/R
10	Automatic Sprinkler System.	Available with mall		
	<ul style="list-style-type: none"> • Basement • Upper Floor • Sprinkler above false ceiling 	-- R R	-- P in Restaurant P in Restaurant	-- M/R M/R
11	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 	6'' 3 3	Provided with Mall As per Mall As per Mall	M/R M/R M/R
12	Yard Hydrants.	Available with mall		
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 	05 05	As per Mall As per Mall	M/R M/R

DUBLIIN SQUARE (A unit of aqua host. Pvt Ltd) Manglam Paradise Mall, Sector 3, Rohini.

13	Pumping Arrangements.			
	<ul style="list-style-type: none"> • Ground Level ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 			
		2850 LPM	Provided with Mall	M/R
		60 m	Provided with Mall	M/R
		180 LPM	Provided with Mall	M/R
		60m	Provided with Mall	M/R
		2850 LPM	Provided with Mall	M/R
		60m	Provided with Mall	M/R
		R	P	M/R
		R	P	M/R
		--	--	--
		--	--	--
		--	--	--
		--	--	--
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	1,50,000 ltrs	Provided with Mall	M/R
		R	Provided with Mall	M/R
		R	Provided with Mall	M/R
		R	P	M/R
		10,000 ltr	Provided with Mall	M/R
15	Exit Signage.	R	P	M/R
16	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	R	Provided with Mall	M/R
		R	Provided with Mall	M/R
		R	Provided with Mall	M/R
		R	Provided with Mall	M/R
		R	Provided with Mall	M/R
17	Standby power supply	R	Provided with Mall	M/R
18	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	N/A	N/A	N/A
		--	--	--
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel 	R	P	M/R
		N/A	N/A	N/A

N-4

DUBLIIN SQUARE (A unit of aqua host. Pvt Ltd) Manglam Paradise Mall, Sector 3, Rohini.

	<ul style="list-style-type: none">• PA System Panel	R	P	M/R
	<ul style="list-style-type: none">• Batter backup	R	P	M/R
	<ul style="list-style-type: none">• Building Floor Plans	R	P	M/R
20	Special Fire Protection Systems for Protection of special Risks, if any:	--	--	--

Note:- One internal staircase of 1.5 mtr width is running from 1st floor to 2nd floor.

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

Signature of the Inspecting Officer

Signature of the Inspecting Officer

Name

Name

Designation

Designation

Guish
18/11/16

Area of restaurant for,

He
18/11

Doubt