

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI

HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110 001


NO. F6/DFS/MS/2016/School/276

Dated: 19.02.2016

FIRE SAFETY CERTIFICATE

Certified that M/S Kendriya Vidyalaya, Pragati Vihar, Lodhi Road, New Delhi-110003, comprised of ground plus two upper floors, owned/occupied by Kendriya Vidyalaya Sanghathan, was granted Fire Safety Certificate by this department vide letter No.F6/DFS/MS/School/2012/3534, dated 25.09.2012. The premises was re-inspected by the officer concerned of this department on 09-02-2016 in the presence of the Mrs. Shobha Sharma, Principal of the school and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rules 2010 and that the building is fit for occupancy class "Educational" with effect from .....19.02.2016 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules, 2010.

Issued on .....19.02.2016 at New Delhi by



(Dr.G.C.Misra)

Chief Fire Officer

T.No.011-23414333

etc

Copy to:-1. Director of Education, Old Secretariat, Civil Lines, Delhi-54.

2 .Principal, Kendriya Vidyalaya, Pragati Vihar, Lodhi Road, New Delhi-110003.

Conditions for the validity of fire safety certificate are as under:-

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. The employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All fire fighting equipments shall be maintained in perfect working condition all time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate, six month prior to its expiry.

### INSPECTION REPORT

1	Name & address of the building	M/S Kendriya Vidyalaya, Pragati Vihar, Lodhi Road, New Delhi-110003.
2	Type of Occupancy	Educational Building "B"
3	Type of case	Renewal
4	Details of previous NOC	No.F6/DFS/MS/School/2012/3534, Dated 25.09.2012.
5	Fire safety directives letter No	No.F6/DFS/MS/BP/99/2563, Dated 15.01.99.
6	Date of inspection	09.02.2016.
7	Name of the inspecting Officers	A.D.O. Vedpal.
8	Name and designation of officers from the building side	Mrs. Sobha Sharma, Principal of the School.
9	Building Comprised of	G+2 Upper floors.
9	Year of construction	2003
10	Applicant's letter No.	No.F.Fire Safety/KVP/2015-16/503, Dated 29.01.2016.

S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement	Provided at site	Remarks MR / NMR
1	<b>Access to building</b>			
	1) Road width	6m	12m	MR
	2) Gate width	Required	5m Provided	MR
	3) Width of internal road	N/A		N/A
2	<b>Number, width Type &amp; arrangement of exits</b>			
	<b>a. Number of staircases</b>			
	1. Upper floors	03nos.	03nos.	MR
	2. basements	N/A	N/A	N/A
	<b>b. Width of staircase</b>			
	1. Upper floors	1.5m(Each)	1.5m(Each)	MR
	2. basements	N/A	N/A	N/A
	<b>c. Protection of exits</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	<b>d. No. of continuous staircase to terrace</b>	1no.	01no.	MR
	e. Width of corridor	1.5m	1.5m	MR
	f. Door size	1 Mtr	Provided	MR
3	<b>Compartmentation.</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
4	<b>Smoke Management system.</b>			
	basement	30 a/c per hour	N/A	N/A
	upper floors	12 a/c per hour	N/A	N/A
5	<b>Fire Extinguishers</b>			
	total numbers	13nos.	13nos.	MR
	Types		ABC & Water CO2	MR
	ISI marking		ISI Mark	MR
6	<b>First-Aid Hose Reels.</b>			
	Total numbers on each floor	03nos.	03nos.	MR
	Length of Hose reel hose	30 m	30m	MR
	Nozzle Diameter	5 mm	5mm	MR
7	<b>Automatic fire detection and alarming system</b>			
	Type of detectors in audi only	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A

A


8	MOEFA	N/A	N/A	N/A
9	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	basement	N/A	N/A	N/A
	upper floors	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	Size of riser/down-corner	N/A	100mm	N/A
	Number of Hydrants per floor	N/A	03nos.	N/A
	hose Box	N/A	03nos.	N/A
12	Yard Hydrants.			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
13	Pumping arrangements			
	1. Ground level	N/A	N/A	N/A
	a. Discharge of main Pump	N/A	N/A	N/A
	b.Head of main pump	N/A	N/A	N/A
	c.Number of main pumps	N/A	N/A	N/A
	d.jockey pump out put	N/A	N/A	N/A
	e.jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g.Stanby Pump head	N/A	N/A	N/A
	h.Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	2.Terrace level			
	a. Discharge of pump	450LPM	450LPM(Two nos.)	MR
	b. head of the pump	40m	40m	MR
	c. Power supply	Required	Provided	MR
	d. Auto starting of pump	Required	Provided	MR
14	Captive water storage for fire fighting			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	N/A
	c.Access to tank	N/A	N/A	N/A
	Over head tank Capacity	5000 Ltr.	10000Liters	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of lifts.			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.		Not Required	
	total area	N/A	N/A	N/A
	location	N/A	N/A	N/A
19	Fire control room			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A

N/11

20 Special Fire Protection systems for protection of special risks, if any: N/A

The fire protection systems provided in the building were test checked randomly and found functional at the time of inspection. In view of the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules the FSC issued vide letter No.F.6/DFS/MS/School/2012/3534, dated 25.09.2012 renewal under rule 35 of the Delhi Fire Service Rule 2010 is recommended.

Accordingly DFA is put up for your approval and signature please.


 10/2/16


Signature of the inspecting officer

Name: Vedpal

Designation : ADO

D.O. (South)

 15/2/16

 16/2/16