

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001**

E-mail:- cfohq.dlfire@nic.in

Fax:- 011-23412593


No: F.6/DFS/MS/School/2016/ 52/301

Dated: 23/02/16

FIRE SAFETY CERTIFICATE

Certified that the building of **M.C. Primary School, Rameshwari Nehru Nagar**, Karol Bagh, New Delhi-110005 is comprised of ground floor only was issued NOC by this department vide letter No.F.6/DFS/MS/2013/School/403 dated 28.01.2013. The School building was re-inspected by the officer concerned of this department on 06.02.2016 in the presence of Parveen Shakkarwal (Incharge) and found that the school management (M.C.D North) have deemed complied with the fire prevention and fire safety requirements in accordance with the Circular No- F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.11 issued by the Director of Education and that the school building is fit for occupancy class "Educational" with effect from the date of issue of this certificate for a period of three years, subject to compliance of the conditions printed overleaf.

Issued on 23/02/16at New Delhi



(DR. G.C. MISRA)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE
Ph: 011-23414333

Copy to: -

1. The Incharge,
M.C. Primary School,
Rameshwari Nehru Nagar, Karol Bagh, N.D-05
2. Director of Education,
North Delhi Municipal Corporation
23rd floor, Dr. S.P.M Civic Centre,
Minto Road, New Delhi-110002.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner/ occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

N/11

Ground Floor only

INSPECTION REPORT

1. Name & address of the building: M.C. Primary School, Rameshwari Nehru Nagar, Kaxol Bagh, N.D.O.S. Educational (School)
2. Type of Occupancy: New Case/Renewal
3. Type of Case: Letter No. F.G/NFS/MS/2013/School/403 Dated 28.01.2013
4. Details of Previous NOC: _____
5. Fire Safety directives letter No: _____
6. Date of inspection: 06.02.2016
7. Name of Inspecting Officer: A.D.O P.S. Dahiya
8. Name and designation of officers from the building side: Smt Parveen Shakkarwal (Incharge)
9. Year of Construction: 2012-2013
10. Applicant's letter No.: Nil dated 28.01.2016

Minimum Standards on fire prevention and fire safety U/R 33	Dir. Of Edu. Circular dt. 01.03.2011	Provided at site	Remarks MR/NMR
Access to building	Accessible	0.5 mtr 190 cms	MR, Old Case MR, Old Case
• Road width	-	-	-
• Gate width	-	-	-
• Width of internal road	-	-	-
Number, Width, Type & Arrangement of Exits			
a. Number of staircases			
• Upper Floors	-	-	Ground Floor only
• Basements	-	-	No Basement
b. Width of staircases			
• Upper Floor	-	-	Ground Floor only
• Basements	-	-	No Basement
c. Protection of exits			
• Fire check door	-	-	-
• pressurization	-	-	-
d. No. of continuous staircases to terrace	-	-	-
e. Width of Corridor	-	-	Ground Floor only
f. Door Size	-	83cms x 205cms	MR, 02 Doors.
Compartmentation			
• Fire check door	-	-	-
• Sealing of electrical shafts	-	-	-
• Fire Rating of shaft door	-	-	-
• Water Curtain	-	-	-
• Fire Dampers	-	-	-
Smoke Management System			
• Basements	30 a/c per hour	-	No Basement
• Upper floors		Natural Ventilation	MR

		12 a/c per hour	-	-
5.	Fire Extinguishers			
	• Total numbers	02 Nos	Provided	MR
	• Types	ABC	- do -	MR
	• IS marking	ISI marked	ISI Marked	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	-	-	-
	• Length of hose reel hose	30 m	-	-
	• Nozzle diameter	5 mm	-	-
7.	Automatic fire detection and alarming system			
	• Type of detectors	-	-	-
	• Location of Main Panel	-	-	-
	• Location of Repeater Panel	-	-	-
	• Alternate source of power	-	-	-
	• Hooters' Location	-	-	-
8.	MOEFA			
9.	Public Address System			
		-	Provided	-
10.	Automatic Sprinkler System			
	• Basement	-	-	No Basement
	• Upper Floor	-	-	-
	• Sprinkler above false ceiling	-	-	-
11.	Internal Hydrants			
	• Size of riser/down-comer	-	-	-
	• Number of hydrants per floor	-	-	-
	• Hose Box	-	-	-
12.	Yard Hydrants			
	• Total number of hydrants	-	-	-
	• Hose Box	-	-	-
13.	Pumping Arrangements			
	• Ground Level	-	-	-
	➤ Discharge of main Pump	-	-	-
	➤ Head of Main pump	-	-	-
	➤ Number of main pumps	-	-	-
	➤ Jockey Pump out put	-	-	-
	➤ Jockey pump head	-	-	-
	➤ Standby Pump out put	-	-	-
	➤ Standby Pump Head	-	-	-
	➤ Auto Starting/Manual stopping	-	-	-
		-	-	-

N/13

M.C. Primary School,
Rameshwari Nehru Nagar, Karol Bagh, N.D-05.

	<ul style="list-style-type: none"> ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	-	-	-
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	-	-	-
15.	Exit Signage.	-	Provided	-
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	-	-	No Lift
		-	-	- do -
		-	-	- do -
		-	-	- do -
		-	-	- do -
17.	Standby power supply	-	-	-
18.	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	-	-	-
		-	-	-
19.	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	-	-	-
		-	-	-
		-	-	-
		-	-	-
		-	-	-
20.	Special Fire Protection System for Protection of special Risks, if any:	-	-	-

10

N/14.

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F.6/DFS/MS/2013/School/403 dated 28.01.2013 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.



P.S. Dahiya
08/02/16

Signature of Inspecting Officer

Name P.S. Dahiya

Designation Asstt. Divisional Officer.

Signature of Inspecting Officer

Name

Designation