

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI-110001**


No.F6/DFS/MS/EH/2016/ *N021 274*

Dated :-----*19/02/16*

FIRE SAFETY CERTIFICATE

Certified that the **Mc Donald's Restaurant** located at **Property No.4964-64/1,Plot No. E-25, Netaji Subhash Marg,Darya Ganj,New Delhi.** comprised of **Basement ground + 3 upper floors but restaurant is running at ground floor only** was granted FSC by this department vide letter No.F6/DFS/MS/EH/2013/264 dated **06/05/13**. The premises was re-inspected by the officer concerned of this department on **09/02/16** in the presence of **Mr. Gobind Bisht** and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class **Assembly Building Group D (Restaurant at ground floor only)** with effect from -----*19/02/16* for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, mentioned below.

Issued -----*19/02/16*-----at New Delhi by.


(Dr. G.C.Misra)
Chief Fire Officer
Delhi Fire Service
Ph. 011-23414333

- Copy to:- (1) Dy. Health Officer, Central Zone, South Delhi Municipal Corporation,
Health Department, Jal Vihar, Lajpat Nagar, New Delhi.
- (2) Mc Donald's Restaurant. Property No.4964-64/1, Plot No. E-25,Netaji Subhash Marg,Darya Ganj,New Delhi.

Conditions:-

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six month prior to its expiry".

- N/5 -

INSPECTION REPORT

1. Name & address of the building:- Mc Donald's Restaurant, Property No. 4964-64/1, Plot No. E-25, Netaji Subhash Marg, Darya Ganj, New Delhi.
2. Type of occupancy:- Group - D Assembly Building (Restaurant) Basement, Ground+ 3 Upper Floors (Restaurant at ground floor only).
3. Type of case:- Renewal
4. Details of previous NOC:- No. F6/DFS/MS/EH/2013/264 dated 06/05/13
5. Fire safety directives No.- N/A
6. Date of inspection:- 09/02/16
7. Name of the inspecting officer:- D.O. Gurmukh Singh
8. Name & designation of officer From the building side:- Mr. Gobind Bisht Old.
9. Year of construction:- Nil.
10. Applicant's letter No:- Dairy dated 04/02/16

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement Existing	Provided at site	Remarks MR/NMR	Old Case
1.	Access to Building				
	1) Road width	6 mtr.	18 mtr.	MR	
	2) Gate width	N/A	N/A	N/A	
	3) Width of internal road	N/A	N/A	N/A	
2.	Number, Width Type & Arrangement of Exits				
	A. Number of staircases				
	1. Upper floors	N/A	N/A	N/A	
	2. Basements	01 No.	01 No.	MR	
	B. Width of staircase				
	1. Upper floors	N/A	N/A	N/A	
	2. Basements	1.25 mtr.	1.30 mtr.	MR	
	C. Protection of exits				
	1. Fire check door	N/A	N/A	N/A	
	2. Pressurization	N/A	N/A	N/A	
	D. No. of continuous staircase to terrace				
	E. Width of corridor	N/A	N/A	N/A	
	F. Door size	2 mtr.	1.15 mtr., 2 mtr., & 2.10 mtr.	MR	
3.	Compartmentation				
	1) Fire check door	N/A	N/A	N/A	
	2) Sealing of electrical shafts	N/A	N/A	N/A	
	3) Fire rating of shaft door	N/A	N/A	N/A	
	4) Water curtain	N/A	N/A	N/A	
	5) Fire Dampers	N/A	N/A	N/A	
4.	Smoke Management System				
	1) Basements	30 a/c per hour	Exhaust fan	MR	

h.

	2) Upper floors	12 a/c per hour	Provided	MR
5.	Fire Extinguishers			
	1) Total numbers	05 No.	05 No.	MR
	2) Types	ABC & CO2	ABC & CO2	MR
	3) ISI marking	Required	Provided	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	01 no.	01 no.	MR
	2) Length of hose reel hose	30 m	30 m	MR
	3) Nozzle diameter	5 mm	5 mm	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	Provided	N/A
	2) Location of main panel	N/A	Provided	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	Provided	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	MOEFA	Required	Provided	MR
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	100 mm.	100 mm.	MR
	2) Number of hydrants per floor	01 no.	01 no.	MR
	3) Hose box	01 no.	01 no.	MR
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	450 LPM & 180 LPM	450 LPM & 180 LPM	MR
	b) Head of pump	30 mtr.	30 mtr.	MR
	c) Power supply	Required	Provided	MR

	d) Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	10,000 Ltrs.	10,000 Ltrs.	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area			
	Total area location	N/A	N/A	N/A
19.	Fire Control Room			
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection system provided in the restaurant were tested, checked at random and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. F6/DFS MS/EH/2013/264 dated 06/05/13, renewal under rule 35 of the Delhi Fire Service rules 2010, is recommended.

Dy CRO (NDZ)

Gurmukh Singh
12/2/16
Gurmukh Singh
Divisional Officer