

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. FG/DFS/MS/2016/W2/315

Dated: 26/02/16

FIRE SAFETY CERTIFICATE

Certified that the **Community/ Recreational Hall & Senior Citizen Recreational Room** located at **DLF Residential Complex in Flatted Factory Complex, Plot No. 15, Shivaji Marg, New Delhi - 110015** comprised of **Ground Floor only** owned/ occupied by **DLF Home Developers Limited** have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and verified by the officer concerned of this department on 23-02-2016 in the presence of Mr. S S Kaushik (Fire Advisor) and found that the building/ premises is fit for occupancy class "Assembly" Group D with effect from 26/02/16 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on26/02/16..... at New Delhi by.

Copy to:

1. The Authorized Signatory,
DLF Home Developers Ltd.
DLF Centre, Sansad Marg,
New Delhi - 110001.


(Santokh Singh)
Chief Fire Officer
Ph:-011-23414250



Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010; form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building: Community/ Recreational Hall & Senior Citizen Recreational Room at DLF Residential Complex in Flatted Factory Complex, Plot No. 15, Shivaji Marg, New Delhi – 110015.
2. Type of Occupancy : Assembly (Ground Floor Only) (Area=488.99m²)
3. Type of Case : New
4. Details of previous NOC : Nil
5. Fire Safety directives Letter No. : Letter No. F6/DFS/MS/BP/2011/751 dated 26-04-2011
6. Date of inspection : 23-02-2016
7. Name of the Inspecting Officer : DO (West) & ADO (MN)
8. Name and designation of Officer
from the building side : Sh. S S Kaushik (Fire Advisor)
9. Year of Construction : 2014-15
10. Applicant's letter No. : Nil Dated 15-02-2016

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building: For Complete Complex			
	• Road width	12 m	Provided	MR
	• Gate width	4.5 m	Provided	MR
	• Width of internal road	6 m	Provided	MR
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	NA	NA	NA
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	NA	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	1X2m & 1X1 m	Provided	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	Natural Ventilation	Provided	MR
5.	Fire Extinguishers			
	• Total number			

	<ul style="list-style-type: none"> floor Length of hose reel 	30 m	Provided	MR
	<ul style="list-style-type: none"> hose Nozzle diameter 	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors 	NR	Provided	NR
	<ul style="list-style-type: none"> Location of Main Panel 	NR	Provided	NR
	<ul style="list-style-type: none"> Location of Repeater Panel 	NR	Provided	NR
	<ul style="list-style-type: none"> Alternate source of power 	NR	Provided	NR
	<ul style="list-style-type: none"> Hooters' Location 	NR	Provided	NR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basements 	NA	NA	NA
	<ul style="list-style-type: none"> Upper Floor 	NR	Provided	NR
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	NA	Provided	NA
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer 	100 mm	Provided	MR ✓
	<ul style="list-style-type: none"> Number of hydrants per floor 	1	Provided	MR
	<ul style="list-style-type: none"> Hose Box 	Required	Provided	MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants 	NR	Provided	NR
	<ul style="list-style-type: none"> Hose Box 	NR	Provided	NR
13.	Pumping Arrangements: Common with the Complex			
	<ul style="list-style-type: none"> Ground Level Discharge of main pump 	NR	A.For Towers = 5500 lpm B.For Basement = 2850 lpm	NR
	➤ Head of main pump	NR	160 m for tower 75 m for basement	NR
	➤ Number of main pumps	NR	2	NR
	➤ Jockey pump out put	NR	2X280 lpm each for tower & basement	NR
	➤ Jockey pump head	NR	160 m for tower 75 m for basement	NR
	➤ Standby Pump out put	NR	A.For Towers = 5500 lpm B.For Basement = 2850 lpm	NR
	➤ Standby Pump Head	NR	160 m for tower 75 m for basement	NR
	➤ Auto Staring/Manual stopping	NR	Provided	NR
	➤ Pump House Access	NR	Provided	NR
	➤ Terrace level			

ive water Storage for fire fighting: **Common with the Complex**

	<ul style="list-style-type: none"> Under ground tank capacity 		5,40,000 litres (for residential towers), 3,00,000 litres for basement	MR
	<ul style="list-style-type: none"> ➤ Draw of connection 	NR	Provided	MR
	<ul style="list-style-type: none"> ➤ Fire service inlet 	NR	Provided	MR
	<ul style="list-style-type: none"> ➤ Access to tank 	NR	Provided	MR
	<ul style="list-style-type: none"> Overhead Tank capacity 	10000 litres	Provided	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	<ul style="list-style-type: none"> ➤ Pressurization of Lift Shaft 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Pressurization of lift lobby 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Communication in lift Car 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Fireman's Grounding Switch 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Lift Signage 	NA	NA	NA
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	<ul style="list-style-type: none"> ➤ Total area 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Location 	NA	NA	NA
19.	Fire control room			
	<ul style="list-style-type: none"> ➤ Detector system panel 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Flow Switch Panel 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ PA System Panel 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Battery backup 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Building Floor Plans 	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/issue ~~shortcomings as noted at serial numbers~~

Signature of the Inspecting Officer *Mukesh Verma 24/2/16*

Signature of the Inspecting Officer *[Signature] 25/2*

Name *Mukesh Verma*

Name

Designation *ASO (MN)*

Designation

060/182 *[Signature]*