

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/EH/2016 /w 2 /319

Dated 29/2/2016

FIRE SAFETY CERTIFICATE

Certified that the **McDonald Family Restaurant** Located at **Ground & First Floor, M2K Multiplex, Pitam Pura New Delhi -34** was issued FSC vide letter no. **F6/DFS/MS/EH/2012/2411 Dated 06-07-2012**. The premises was re inspected by the officers concerned of this department on 05/02/2016 in the presence of **Sh. Gourov, (Manager)** and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class "Assembly" Group D with effect from 29/02/16 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 29/02/16..... at New Delhi by.


(Santokh Singh)
Chief Fire Officer
PH 011-23414250

Copy to:

1. Sh. Gourov, (Manager), McDonald Family Restaurant ,Ground & First Floor, M2K Multiplex, Pitam Pura New Delhi -34

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building: **McDonald Family Restaurant Located at Ground & First Floor, M2K Multiplex, Pitam Pura New Delhi -34**
2. Type of Occupancy : Assembly (Restaurant) Building (Class-D) Located at Ground & 1st Floor in M2K Mall Rani Bagh ✓
3. Type of Case : Renewal
4. Details of previous NOC : F6/DMS/MS/2012/2441 Dated 06-07-2012
5. Fire Safety directives Letter No. :
6. Date of inspection : 05/02/2016
7. Name of the Inspecting Officer : Udaivir Singh ADO (WP)
8. Name and designation of Officer
from the building side : Sh. Gourov, (Manager)
9. Year of Construction :
10. Applicant's letter No. : CPRPL/FM/OM/NOC/2015-16/231 dated 21-01-2016

Sr. No	Minimum standards on fire prevention and fire safety U/R 33	NBC Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	9mtr	Provided	MR
	• Gate width	05 mtrs	Provided(In mall)	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits (Inside M2K Mall)			
	a. Number of staircases			
	• Upper floors	2	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1 X 1.5, 1 X 1m	Provided	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	Required	Provided	MR
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	Old Case	Old Case	Old Case

3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door 	NA	NA	NA
	<ul style="list-style-type: none"> • Sealing of electrical shafts 	NA	NA	NA
	<ul style="list-style-type: none"> • Fire Rating of shaft door 	NA	NA	NA
	<ul style="list-style-type: none"> • Water Curtain 	NA	NA	NA
	<ul style="list-style-type: none"> • Fire Dampers 	NA	NA	NA
4.	Smoke managements System			
	<ul style="list-style-type: none"> • Basements 	30 a/c per hr	NA	NA
	<ul style="list-style-type: none"> • Upper floors 	12 a/c per hr	NA	NA
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers 	02	Provided	MR
	<ul style="list-style-type: none"> • Types 	ABC / CO2	Provided	MR
	<ul style="list-style-type: none"> • IS marking 	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor 	1	Provided	MR
	<ul style="list-style-type: none"> • Length of hose reel 	30 m	Provided	MR
	<ul style="list-style-type: none"> • Nozzle diameter 	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> • Type of detectors 	NA	Provided	NA
	<ul style="list-style-type: none"> • Location of Main Panel 	NA	Provided	NA
	<ul style="list-style-type: none"> • Location of Repeater Panel 	NA	NA	NA
	<ul style="list-style-type: none"> • Alternate source of power 	NA	Provided	NA
	<ul style="list-style-type: none"> • Hooters' Location 	NA	Provided	NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> • Basements 	NA	NA	NA
	<ul style="list-style-type: none"> • Upper Floor 	NA	NA	NA
	<ul style="list-style-type: none"> • Sprinkler above false ceiling 	NA	NA	NA
11.	Internal Hydrants:			
	<ul style="list-style-type: none"> • Size of riser/down-comer 	150 mm	Provided	MR
	<ul style="list-style-type: none"> • Number of hydrants per floor 	1	Provided	MR
	<ul style="list-style-type: none"> • Hose Box 	1	Provided	MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> • Total number of hydrants 	NA	NA	NA
	<ul style="list-style-type: none"> • Hose Box 	NA	NA	NA


13.	Pumping Arrangements: (common with mall)			
	<ul style="list-style-type: none"> • . Ground Level • Discharge of main pump ➤ Head of main pump ➤ Number of main pumps ➤ Jockey pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Staring/Manual stopping ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power supply ➤ Auto starting of pump 	NA	Provided	NA
		NA	Provided	NA
		NA	Provided	NA
		NA	Provided	NA
		NA	Provided	NA
		NA	Provided	NA
		NA	Provided	NA
		450 lpm	Provided	MR
		40 m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14.	Captive water Storage for fire fighting: (common with)			
	<ul style="list-style-type: none"> • Under ground tank capacity ➤ Draw off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	NA	Provided	NA
		NA	Provided	NA
		NA	Provided	NA
		NA	Provided	NA
		10, 000 liters	Provided	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts(Common With M2K Mall)			
	➤ Pressurization of Lift Shaft	Required	Provided	MR
	➤ Pressurization of lift lobby	Required	Provided	MR
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA

N-16

19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/EH/2010/2411 dated 06-07-2012 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer

 Officer

Name
 Designation

Uday Vir Singh
 AD/WP

Signature of the Inspecting

Name
 Designation

