

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6 / DFS / MS / 2016 *Revised/w2/311*

Dated: *25/02/2016*

FIRE SAFETY CERTIFICATE

Certified that the Paradise Public School located at A Block, Indraprasth Colony, Amrit Vihar, Burari, Delhi comprised of Ground floor & First Floor was granted NOC by this department vide letter No F 6 / DFS / MS / 2007/1708 dated 27.06.2007. The premises was re-inspected by the officer concerned of this department on 13.11.2015 in the presence of Sh. Laltuna (Manager/Owner) and observed that the building is now comprised of ground and three floor (school at ground floor & First floor and owner residence at second & third floor). All the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy Group B Educational with effect from*25.02.16*... for a period of three years, subject to compliance of the conditions mentioned below:

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in
8. **The second and third floor of the building is restricted to residential purposes only.**

Issued on*25.02.16*..... at New Delhi


(Santokh Singh)
Chief Fire Officer
Ph:-011-23414250

Copy to: -

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 54.
2. The Principal/ Pardise Public School, A Block Indraprasth Amrit Vihar, Burari, Delhi.

N/V

INSPECTION REPORT

1. Name & address of the building : Paradise Public School, A Block Indraprasth Amrit Vihar, Delhi.
2. Type of Occupancy : Educational
3. Type of Case : Old case (Addition of 2nd & 3rd Floor for residential own occupied)
4. Details of previous NOC : F.6/DFS/MS/2007/ 1708 dated 27/06/2007
5. Fire Safety directives letter No : Director of Education Circular dated 17.01.2005
6. Date of inspection : 13/11/2015
7. Name of the Inspecting Officers : ADO (RN)
8. Name and designation of officers from the building side : Mr Laltuna Jha (Manager/ owner)
9. Year of Construction : 2007/ 2015 (Add/alt)
10. Applicant's letter No. : Nil dated 17/07/2015

Plot Area-235Syd, Covered Area:700 Syd, G+ 03 Floors (school at G & 1st Floor), Nos of student-300

	Minimum Standards on fire prevention and fire safety U/R 33	Circular of Director of Education	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	6m	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	02	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.50m	1.17m, 1.05m	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1 m	1 m	MR
	3	Compartmentation.		
• Fire check door		NA	NA	NA
• Sealing of electrical shafts		NA	NA	NA
• Fire Rating of shaft door		NA	NA	NA
• Water Curtain		NA	NA	NA
• Fire Dampers		NA	NA	NA
4	Smoke Management System.			
	• Basements	30 a/c per hour	NA	NA
	• Upper floors	12 a/c per hour	Natural Ventilated	MR

AC

5	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types ISI marking 	05nos	5 nos	MR ✓
		ABC/CO2	ABC—5 nos	MR ✓
		ISI Marked	Yes	MR ✓
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	R	01no	MR ✓
		30m	30m	MR ✓
		5mm	5mm	MR ✓
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
NA		NA	NA	
8	MOEFA			NA
9	Public Address System.			NA
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
NA		NA	NA	
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
NA		NA	NA	
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA	NA	NA
		NA	NA	NA
NA		NA	NA	
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
<ul style="list-style-type: none"> Terrace level 				

N/4

	➤ Discharge of pump	225lpm	225lpm	MR
	➤ Head of the pump	40m	40m	MR
	➤ Power Supply	R	P	MR
	➤ Auto Starting of pump	R	P	MR
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	2000ltrs	2000ltrs	MR
15	Exit Signage.	R	P	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

As per the earlier NOC issued vide this department letter of even no. 1708 dated 27.06.2007 the school premise was comprised of ground & first floor. Now at the time of inspection it has observed that the party has added two floors on the existing structure for residential purposes owned occupied by the school management.

The fire protection systems provided in the building were tested/ checked randomly and found in working condition.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in director of education Circular dated 17.01.2005, fire safety certificate is recommended.

RK
24/12/15
Signature of the Inspecting Officer
Name: - Rajesh Kumar
Designation: - ADO/RN

DO (N/S)
Rup
27/11/15

DO (N/S)

CPD
1/12

Are the staircase for residence independent from school staircase?

cho/2499
2/12/15

19/DO (N/S)
2/12/15