

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001**

No F 6 / DFS / MS / 2016 / *School 022 / 312*

Dated: *25/02/2016*

**FIRE SAFETY CERTIFICATE**

Certified that the Swastik Public School, Kh. No.44, Sushant Vihar, Main Road, Ibrahimpur, Delhi-110084 comprised of Ground and first floor was issued NOC by this department vide letter No F 6 / DFS / MS / 2008/2039 dated 21.07.2008. The premises was re-inspected by the officer concerned of this department on 04.02.2016 in the presence of Sh. P. C. Gupta/ Manager and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy Group B Educational with effect from *25/02/16* for a period of three years, subject to compliance of the conditions mentioned below:

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [WWW.dfs.Delhigovt.nic.in](http://WWW.dfs.Delhigovt.nic.in)

Issued on *25/02/16* at New Delhi.

*[Signature]*  
(Santokh Singh)  
Chief Fire Officer  
Ph:-011-23414250  
*OLN*

Copy to :-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 54.
2. The Manager, Swastik Public School, Kh. No.44, Sushant Vihar, Main Road, Ibrahimpur, Delhi-84.

4/7  
**INSPECTION REPORT**

1. Name & address of the building : Swastik Public School, Kh. No.44, Sushant Vihar, Main Road, Ibrahimpur, Delhi
2. Type of Occupancy : Educational
3. Type of Case : Renewal (Single block ---Ground + first floor )
4. Details of previous NOC : F.6/DFS/MS/2008/2039 dated 21/07/2008
5. Fire Safety directives letter No : Director of Education Circular dated 01.03.2011
6. Date of inspection : 04/02/2016
7. Name of the Inspecting Officers : ADO (RN)
8. Name and designation of officers  
from the building side : Mr P.C.Gupta (Manager)
9. Year of Construction : 2002
10. Applicant's letter No. : Nil dated 28/12/2015

Plot Area-1600 sqm      Covered Area:500 sq.m      Nos of student—350nos,      class rooms –21 nos

	Minimum Standards on fire prevention and fire safety U/R 33	Circular of Director of Education	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	Accessible	6m	MR ✓
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper Floors	02	02	MR ✓
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	Old case	1.0m each	Old case ✓
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	01	NA
	e. Width of Corridor	NA	NA	NA
f. Door Size	1 m	1 m	MR ✓	
3	<b>Compartmentation.</b>			



	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
4	<b>Smoke Management System.</b>			
	<ul style="list-style-type: none"> <li>• Basements</li> </ul>	30 a/c per hour	NA	NA
	<ul style="list-style-type: none"> <li>• Upper floors</li> </ul>	12 a/c per hour	Natural Ventilated	MR
5	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>• Total numbers</li> </ul>	06nos	12nos	MR ✓
	<ul style="list-style-type: none"> <li>• Types</li> </ul>	ABC/CO2	ABC-12 nos	MR ✓
	<ul style="list-style-type: none"> <li>• ISI marking</li> </ul>	ISI Marked	Yes	MR ✓
6	<b>First-Aid Hose Reels.</b>			
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> </ul>	01	P	MR ✓
	<ul style="list-style-type: none"> <li>• Length of hose reel hose</li> </ul>	30 m	P	MR ✓
	<ul style="list-style-type: none"> <li>• Nozzle diameter</li> </ul>	5 mm	P	MR ✓
7	<b>Automatic fire detection and alarming system.</b>			
	<ul style="list-style-type: none"> <li>• Type of detectors</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Location of Main Panel</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Location of Repeater Panel</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Alternate source of power</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Hooters' Location</li> </ul>	NA	NA	NA
8	<b>MOEFA</b>	NA	NA	NA
9	<b>Public Address System.</b>	NA	NA	NA
10	<b>Automatic Sprinkler System.</b>			
	<ul style="list-style-type: none"> <li>• Basement</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Upper Floor</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Sprinkler above false ceiling</li> </ul>	NA	NA	NA
11	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>• Size of riser/down-comer</li> </ul>	NA	NA	NA

N/10

17	Standby power supply	N/A	N/A	
18	<b>Refuge Area.</b>			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	<b>Fire Control Room</b>			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

Note:- General requirements as per director of Education letter dated 01.03.2015

- |   |                                |
|---|--------------------------------|
| 1. Escape route—clear                       | 2. LPG cylinder in Lab---NA    |
| 2. Electric wiring—concealed                | 4. ELCB/MCB—provided           |
| 5. Electric meter board—not under staircase | 6. Emergency Tel Nos—Displayed |
| 7. Generator set ----- No                   | 8. Basement use as per BBL--NA |

Accordingly, the fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in Director of Education Circular dated 17.01.2005 the FSC issued vide letter of even no 2039 dated 21.07.2008 renewal under rule 35 of the Delhi Fire Service Rules, 2010 is recommended

*Rajesh Kumar*  
15/2

Signature of the Inspecting Officer  
Name :- Rajesh Kumar  
Designation:- ADO/RN

*DO/NO*

*Rajesh Kumar*  
15/2/16

9301 D/O  
16/2/16