

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.

E-mail:- cfohq.dlfire@nic.in

No. F.6/DFS/MS/BANQ./2016/SZ/ 326


Fax: - 011-23412593

Dated: 01/03/16

FIRE SAFETY CERTIFICATE

Certified that the building of M/s Five Elements, B-1/631, Main Najafgarh Road, Janakpuri, New Delhi-110058, is comprised of Basement, stilt, ground plus two upper floors. But Banquet hall is running at ground floor only. The banquet hall is owned/occupied by the M/s Five Elements (a unit of Vijay Global Pvt. Ltd.). The banquet hall building was inspected by the officer concerned of this department on 10.02.2016 in the presence of Sh. Vivek Malhotra (Sr. V.P) and found that the owner have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premises (**Ground floor only**) is fit for occupancy class Group "D" Assembly building w.e.f. the date of issue of this certificate for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed overleaf.

Issued on.....01/03/16.....at New Delhi.


1/3
(DR. G.C. MISRA)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE

o/c Sam
28/2/16

Copy to:-

1. The Deputy Health Officer,
West Zone (SDMC), Public Health Department,
Vishal Enclave, New Delhi.
(Letter No. D-2697/HD/WZ dated 28.12.2015)
2. Sh. Vivek Malhotra (Sr. V.P),
M/s Five Elements, B-1/631,
Main Najafgarh Road, Janakpuri, New Delhi-110058.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per the building bye laws.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

Comprised of basement, stilt, ground plus two upper floors. Banquet hall is running at ground floor only
(M/s Five Elements, B-1/631, Main Najafgarh Road, Janakpuri, New Delhi-110058)

INSPECTION REPORT

1. Name & address of the building : M/s Five Elements, B-1/631, Main Najafgarh Road, Janakpuri, New Delhi-110058
2. Type of Occupancy : Group D "Assembly Building"
3. Type of Case : New
4. Details of Previous NOC : N/A
5. Fire Safety directives letter No : N/A
6. Date of inspection : 10.02.2016
7. Name of Inspecting Officer : D.O. S.K. Tomar & A.D.O. Sandeep Duggal
8. Name and designation of officers
From the building side : Sh. Vivek Malhotra (Sr. V.P)
9. Year of Construction : 2015
10. Applicant's letter No. : D-2697/HD/WZ dated 28.12.2015

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	12 mtrs N/A N/A	12 mtrs Open to road N/A	M/R N/A N/A
2.	Number, Width, Type & Arrangement of Exits	(Banquet hall is running at ground floor only)		
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basement 	02 No's 02 No's	03 No's 02 No's	M/R M/R
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basements 	200/150 cms 150 cms	200, 150 & 150 cms 150 cms each	M/R M/R
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire/smoke check door • Pressurization 	N/A N/A	N/A N/A	N/A N/A
	d. No. of continuous staircases to terrace	N/A	Two	N/A
	e. Width of Corridor	150 cms	Opening in Hall	N/A
	f. Door Size	200 cms	200 cms X 3	M/R
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
4.	Smoke Management System	(Banquet hall is running at ground floor only)		
	<ul style="list-style-type: none"> • Basements 	N/A	Exhaust fans are provided	N/A

Saw

N18

Comprised of basement, stilt, ground plus two upper floors. Banquet hall is running at ground floor only
(M/s Five Elements, B-1/631, Main Najafgarh Road, Janakpuri, New Delhi-110058)

	<ul style="list-style-type: none"> Upper floors 	N/A	Natural ventilation	M/R
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	20 No.'s ABC/CO ₂ type	Provided	M/R
			Provided	M/R
		ISI marked	ISI marked	M/R
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	01 No./Floor 30 mtrs 5 mm	Provided	M/R
			Provided	M/R
			Provided	M/R
7.	Automatic fire detection and alarming system (Banquet hall is running at ground floor only)			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	Smoke/Heat N/A N/A Required N/A	Provided Stilt floor N/A Provided At exits	M/R N/A N/A M/R N/A
8.	MOEFA	Required	Provided	M/R
9.	Public Address System	Required	Provided	M/R
10.	Automatic Sprinkler System (Banquet hall is running at ground floor only)			
	<ul style="list-style-type: none"> Basement Ground Floor & upper floor Sprinkler above false ceiling 	Required N/A N/A	Provided N/A N/A	M/R N/A N/A
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	Required Required Required	Provided One One	M/R M/R M/R
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	N/A N/A	One One	N/A N/A
13.	Pumping Arrangements (Banquet hall is running at ground floor only)			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping 	N/A N/A N/A N/A N/A N/A N/A N/A	2280 LPM 55 mtrs provided One 180 LPM 40 mtrs N/A N/A N/A	N/A N/A N/A N/A N/A N/A N/A N/A

Sam

2)9

Comprised of basement, stilt, ground plus two upper floors. Banquet hall is running at ground floor only
(M/s Five Elements, B-1/631, Main Najafgarh Road, Janakpuri, New Delhi-110058)

		Required	Provided	M/R
	<ul style="list-style-type: none"> ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 			
		900 LPM	Provided	M/R
		40 mtrs	Provided	M/R
		Required	Provided	M/R
		Required	Provided	M/R
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	N/A	52000 ltrs Provided	N/A
		N/A	N/A	N/A
		N/A	Provided	N/A
		N/A	Provided	N/A
		10000 ltrs	Provided	M/R
		Required	Provided	M/R
15.	Exit Signage.			
16.	Provision of Lifts.	(Lift is from stilt to upper floors)		
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		Required	Provided	M/R
		N/A	N/A	N/A
		N/A	250 & 125 KVA	N/A
17.	Standby power supply			
18.	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	N/A	N/A	N/A
		N/A	N/A	N/A
19.	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Battery backup • Building Floor Plans 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A

San

Comprised of basement, stilt, ground plus two upper floors. Banquet hall is running at ground floor only
(M/s Five Elements, B-1/631, Main Najafgarh Road, Janakpuri, New Delhi-110058)

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the above substantial compliance of the minimum standards of fire prevention and fire safety measures as required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.


S.K. Tomar
16/2/16

Signature of Inspecting Officer

Name:- S.K. Tomar

Designation:- Divisional Officer


Sandeep
15/2/16

Signature of Inspecting Officer

Name:- Sandeep Duggal

Designation:- Asstt.Divisional Officer

Dy.C.F.O. (South Zone)


16/2/16

