

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110 001.

E-mail:- [cfohq.dlfire@nic.in](mailto:cfohq.dlfire@nic.in)

No. F.6/DFS/MS/EH/2016/SZ 344

Fax: - 011-23412593

Dated: 03/03/16

FIRE SAFETY CERTIFICATE

Certified that the building of M/s V.M Enterprises (The Pindi), C-1/122, Ground floor, Janak Puri, New Delhi-110058, is comprised of ground plus three upper floors but restaurant is running at ground floor only. The restaurant is owned/occupied by M/s V.M. Enterprises. The restaurant building was inspected by the officer concerned of this department on 18.02.2016 in the presence of Sh. Vishal Saxena (Owner) and found that the owner have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premises (**Ground floor only**) is fit for occupancy class Group D assembly building w.e.f. the date of issue of this certificate for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed overleaf.

Issued on.....03/03/16.....at New Delhi.



(DR. G.C. MISRA)  
CHIEF FIRE OFFICER  
DELHI FIRE SERVICE

Dr. G.C. Misra  
02/03/16

Copy to:-

1. The Deputy Health Officer,  
West Zone (SDMC), Public Health Department,  
Vishal Enclave, New Delhi.  
(Letter No. D-2701/HD/WZ dated 03.12.2015)
2. Sh. Vishal Saxena (Owner),  
M/s V.M. Enterprises (The Pindi), C-1/122, Ground Floor,  
Janak Puri, New Delhi 110058.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

Building is comprised of ground plus three upper floors but restaurant is running at Ground floor only (M/s VM Enterprises (The Pindi), C-1/122, Ground Floor, Janak puri, New Delhi-110058)

**INSPECTION REPORT**

1. Name & address of the building : M/s VM Enterprises (The Pindi), C-1/122, Ground Floor, Janak puri, New Delhi-110058.
2. Type of Occupancy : Restaurant
3. Type of Case : New
4. Details of Previous NOC : N/A
5. Fire Safety directives letter No : N/A
6. Date of inspection : 18-02-2016
7. Name of Inspecting Officer : A.D.O Sandeep Duggal
8. Name and designation of officers  
From the building side : Sh. Vishal Saxena (Owner)
9. Year of Construction : 2015
10. Applicant's letter No. : Letter No. Ref 01 dated 05.02.2016

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	<p>Accessible</p> <p>--</p> <p>--</p>	<p>12 mtrs.</p> <p>—</p> <p>—</p>	<p>M/R</p> <p>—</p> <p>--</p>
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>	<b>Restaurant is running at ground floor only</b>		
	a. Number of staircases			
	<ul style="list-style-type: none"> <li>• Upper Floors</li> <li>• Basements</li> </ul>	<p>N/A</p> <p>N/A</p>	<p>N/A</p> <p>N/A</p>	<p>N/A</p> <p>N/A</p>
	b. Width of staircases			
	<ul style="list-style-type: none"> <li>• Upper Floor</li> <li>• Basements</li> </ul>	<p>N/A</p> <p>N/A</p>	<p>N/A</p> <p>N/A</p>	<p>N/A</p> <p>N/A</p>
	c. Protection of exits			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Pressurization</li> <li>•</li> </ul>	<p>N/A</p> <p>N/A</p> <p></p>	<p>N/A</p> <p>N/A</p> <p></p>	<p>N/A</p> <p>N/A</p> <p></p>
	d. No. of continuous staircases to terrace	N/A	N/A	N/A
	e. Width of Corridor	N/A	Open in hall	N/A
	f. Door Size	200 cms	200 cms	M/R
3.	<b>Compartmentation</b>			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>	<p>N/A</p> <p>N/A</p> <p>N/A</p> <p>N/A</p> <p>N/A</p>	<p>N/A</p> <p>N/A</p> <p>N/A</p> <p>N/A</p> <p>N/A</p>	<p>N/A</p> <p>N/A</p> <p>N/A</p> <p>N/A</p> <p>N/A</p>
4.	<b>Smoke Management System</b>			
	<ul style="list-style-type: none"> <li>• Basements</li> </ul>	N/A	N/A	N/A

*San*

N/A

Building is comprised of ground plus three upper floors but restaurant is running at Ground floor only (M/s VM Enterprises (The Pindi), C-1/122, Ground Floor, Janak puri, New Delhi-110058)

	<ul style="list-style-type: none"> <li>Upper floors</li> </ul>	N/A	N/A	N/A
<b>5.</b>	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>IS marking</li> </ul>	05 No.'s A.B.C ISI marked	Provided Provided ISI marked	M/R M/R M/R
<b>6.</b>	<b>First-Aid Hose Reels</b>			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	One 30 mtrs. 5 mm	Provided Provided Provided	M/R M/R M/R
<b>7.</b>	<b>Automatic fire detection and alarming system</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
<b>8.</b>	<b>MOEFA</b>	Required	Provided	M/R
<b>9.</b>	<b>Public Address System</b>	Required	Provided	M/R
<b>10.</b>	<b>Automatic Sprinkler System</b>			
		<b>(Restaurant at ground floor only)</b>		
	<ul style="list-style-type: none"> <li>Basement</li> <li>Ground Floor</li> <li>Sprinkler above false ceiling</li> </ul>	N/A N/A N/A	N/A N/A N/A	N/A N/A N/A
<b>11.</b>	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	Required Required Required	100 mm Provided one one	M/R M/R M/R
<b>12.</b>	<b>Yard Hydrants</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	N/A N/A	N/A N/A	N/A N/A
<b>13.</b>	<b>Pumping Arrangements</b>			
	<ul style="list-style-type: none"> <li>Ground Level               <ul style="list-style-type: none"> <li>Discharge of main Pump</li> <li>Head of Main pump</li> <li>Number of main pumps</li> <li>Jockey Pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Starting/Manual Stopping</li> </ul> </li> </ul>	N/A N/A N/A N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A N/A N/A N/A

Sam

N/12

Building is comprised of ground plus three upper floors but restaurant is running at Ground floor only (M/s VM Enterprises (The Pindi), C-1/122, Ground Floor, Janak puri, New Delhi-110058)

	<ul style="list-style-type: none"> <li>➤ Pump House Access</li> <li>• Terrace level</li> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power Supply</li> <li>➤ Auto Starting of pump</li> </ul>	N/A	N/A	N/A
		450 LPM	Provided	M/R
		30 Mtrs	Provided	M/R
		Required	Provided	M/R
		N/A	N/A	N/A
<b>14.</b>	<b>Captive Water Storage for fire fighting</b>			
	<ul style="list-style-type: none"> <li>• Underground tank capacity</li> <li>➤ Draw-off connection</li> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> <li>• Overhead Tank capacity</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		10,000 ltrs	Provided	M/R
<b>15.</b>	<b>Exit Signage.</b>	Required	Provided	M/R
<b>16.</b>	<b>Provision of Lifts.</b>			<b>(No lift)</b>
	<ul style="list-style-type: none"> <li>• Pressurization of Lift Shaft</li> <li>• Pressurization of Lift lobby</li> <li>• Communication In lift Car</li> <li>• Fireman's Grounding Switch</li> <li>• Lift Signage</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
<b>17.</b>	<b>Standby power supply</b>	Required	1.6 KVA	M/R
<b>18.</b>	<b>Refuge Area.</b>			
	<ul style="list-style-type: none"> <li>➤ Total Area</li> <li>➤ Location</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
<b>19.</b>	<b>Fire Control Room</b>			
	<ul style="list-style-type: none"> <li>• Detector System Panel</li> <li>• Flow Switch Panel</li> <li>• PA System Panel</li> <li>• Battery backup</li> <li>• Building Floor Plans</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
<b>20.</b>	<b>Special Fire Protection System for Protection of special Risks, if any:</b>	N/A	N/A	N/A

*San*

N/13

Building is comprised of ground plus three upper floors but restaurant is running at Ground floor only (M/s VM Enterprises (The Pindi), C-1/122, Ground Floor, Janak puri, New Delhi-110058)

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the above substantial compliance of the minimum standards of fire prevention and fire safety measures as required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

*Sandeep*  
*24/2/16*

Signature of Inspecting Officer

Name: - Sandeep Duggal

Designation: - Assistant Divisional Officer

D.O (South West)

Signature of Inspecting Officer

Name: -

Designation: -

