

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.**

E-mail:- cfohq.dlfire@nic.in

Fax:- 011-23412593


No. F.6/DFS/MS/GH/2016/ 52/365

Dated: 08/03/16

FIRE SAFETY CERTIFICATE

Certified that the Guest House **The Daanish Residency** located at 12A/19, WEA, Karol Bagh, New Delhi-110005 is comprised of Basement, ground floor plus four upper floors, using basement as two hall/storage, ground floor as parking, first floor having reception, office, lobby and 05 guest rooms, second floor and third floor each having 08 guest rooms respectively, fourth floor having 07 guest rooms (Total 28 guest rooms), a lift room, staff pantry with staff room in temporary tin shed on terrace was issued NOC by this department vide letter No.F.6/DFS/MS/GH/2013/828 dated 27.02.2013 owned/occupied by Smt. Payal Bajaj. The guest house building was re inspected by the officers concerned of this department on 25.02.2016 in the presence of Sh. Rati Kant (Manager) and found that the owner have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premises is fit for occupancy class residential w.e.f. the date of issue of this certificate for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed overleaf.

Issued on.....at New Delhi.



(DR. G.C. MISRA)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE

Ph:- 011-23414333

Copy to:-

1. Smt. Payal Bajaj (Owner),
Guest House The Daanish Residency, 12A/19,
WEA, Karol Bagh, New Delhi-110005.

9c
7.3.16

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The basement shall be used strictly as per the provisions of the building bye laws.
7. The owner/ occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

N/9 Basement, Ground Floor plus four upper floors.

INSPECTION REPORT

1. Name & address of the building: G-11 The Naanish Residency, 12A/19, WEA, Kandi Bagh, N.D-05.
2. Type of Occupancy: Residential (Guest House)
3. Type of Case: New Case/Renewal
4. Details of Previous NOC: Letter No. F-6/NFS/MS/GH/2013/828 Date 27.02.2013
5. Fire Safety directives letter No: -
6. Date of inspection: 25.02.2016
7. Name of Inspecting Officer: D.O S.K. Tomar & A.D.O P.S. Dahiya
8. Name and designation of officers:
From the building side: Sh. Rati Kant (Manager)
9. Year of Construction: 2008-09
10. Applicant's letter No.: MIL dated MIL

5. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/BBL Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	Accessible	06 mtr	MR
	• Gate width	-	125 cms	MR
	• Width of internal road	-	-	-
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	Two	Two	MR, Old Case
	• Basements	- do -	- do -	MR, - do -
	b. Width of staircases			
	• Upper Floor	-	126 cms, 60 cms	MR, Old Case
	• Basements	-	126 cms, 60 cms	- do -
	c. Protection of exits			
	• Fire check door	-	-	-
	• pressurization	-	-	-
	d. No. of continuous staircases to terrace	-	-	-
	e. Width of Corridor	-	One	-
	f. Door Size	-	122 cms, 146 cms 87 cms x 201 cms	-
3.	Compartmentation			
	• Fire check door	-	-	-
	• Sealing of electrical shafts	-	Sealed	-
	• Fire Rating of shaft door	-	-	-
	• Water Curtain	-	-	-
	• Fire Dampers	-	-	-
4.	Smoke Management System			
	• Basements	30 a/c per hour	Exhaust Fans are Provided	MR
	• Upper floors		Natural Ventilation	MR

11

N/10

		12 a/c per hour	-	-
5.	Fire Extinguishers			
	• Total numbers	IS Nos	Provided	MR
	• Types	ABC, W, CO ₂ , CO ₂	- do -	MR
	• IS marking	ISI marked	ISI Marked	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	One	Provided	MR
	• Length of hose reel hose	30 m	- do -	MR
	• Nozzle diameter	5 mm	- do -	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	-	-	-
	• Location of Main Panel	-	-	-
	• Location of Repeater Panel	-	-	-
	• Alternate source of power	-	-	-
	• Hooters' Location	-	-	-
8.	MOEFA		Required	Provided
9.	Public Address System		- do -	- do -
10.	Automatic Sprinkler System			
	• Basement	Required	Provided	MR
	• Upper Floor	-	-	-
	• Sprinkler above false ceiling	-	-	-
11.	Internal Hydrants			
	• Size of riser/down-comer	-	-	-
	• Number of hydrants per floor	-	-	-
	• Hose Box	-	-	-
12.	Yard Hydrants			
	• Total number of hydrants	-	-	-
	• Hose Box	-	-	-
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	-	-	-
	➤ Head of Main pump	-	-	-
	➤ Number of main pumps	-	-	-
	➤ Jockey Pump out put	-	-	-
	➤ Jockey pump head	-	-	-
	➤ Standby Pump out put	-	-	-
	➤ Standby Pump Head	-	-	-
	➤ Auto Starting/Manual stopping	-	-	-

N/11 12A/19, WEA, Kaxol Bagh,
New Delhi - 110005.

	<ul style="list-style-type: none"> ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	-	-	-
		-	456 LPM	MR, Old Case
		-	30 M	- do -
		Required	Provided	MR
		-	-	-
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	-	-	-
		-	-	-
		-	Provided	MR
		-	-	-
		-	5000 ltr	MR, Old Case
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	-	-	-
		-	-	-
		-	Provided	MR
		Required	- do -	MR
		- do -	- do -	MR
17.	Standby power supply	Required	D.G. Set of 125 KVA	MR
18.	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	-	-	-
		-	-	-
19.	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	-	-	-
		-	-	-
		-	-	-
		-	-	-
		-	-	-
20.	Special Fire Protection System for Protection of special Risks, if any:	-	-	-

N/12

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F.6/DFS/MS/GH/2013/828 dated 27.02.2013 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

S.K. Tomar
27/2/13

Signature of Inspecting Officer

Name S.K. Tomar

Designation Divisional Officer

Dy CFO(S2)
11/3/13

P.S. Dahiya
26/2/13

Signature of Inspecting Officer

Name P.S. Dahiya

Designation Asstt. Divisional Officer.

