

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI- 110001

NO. F.6/DFS/MS/2016/MD2/375

DATED: 08/03/16

FIRE SAFETY CERTIFICATE

Certified that the Industrial building at Plot no.254,FIE Patparganj, Delhi 92, owned/occupied by Sh.Amrish Kumar Goel, comprised of basement, ground plus two upper floors was granted FSC vide letter No.F.6/DFS/MS/2012/1127 dated 28/03/2012.The industrial building was inspected by the officer concerned of this department on 17.03.16 & 29.02.16 in the presence of Sh. Amrish Kumar Goel and found that the industrial building have deemed complied with the fire prevention and fire safety requirements in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 that the building is fit for occupancy Group G " Industrial Building" with effect from 08/03/16 for a period of three years, subject to conditions printed overleaf.

Issued on 08/03/16 at New Delhi by



(Dr.G.C.Misra)  
Chief Fire Officer  
Ph.011-23414333

To,  
Sh.Amrish Kumar Goel  
Plot no.254,FIE Patparganj,  
Delhi-92.

O/c  
H

CONDITIONS:

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation,ventilation,structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This FSC can not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. Basement shall be used as per BBL.
7. "The owner /occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J'[sub rule(1) of rule 37] along with a copy of this certificate,six months prior to its expiry"
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

1. Name & address of the building: Plot No.254, FIE,Patparganj,Delhi -92.
2. Building is comprised of : Basement,Ground + 2, upper floors.
3. Type of Occupancy : Industrial
4. Type of Case : Renewal
5. Details of Previous FSC : F.6/DFS/MS/2012/1127 Dated 28/03/2012
6. Fire Safety direction letter No : Nil
7. Date of Inspection : 17.02.16 & 29.02.16
8. Name of the Inspecting officers :DO Virendra Singh,
9. Name and designation of Officer:  
 from the building side : Shri.Amrish Kumar Goel
10. Year of Construction - : 1998
11. Applicant's letter No : 03.02.16

NO.	Minimum Standards on fire prevention and fire safety U/R33	NBC(Old) Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	• Road width	6 Mtrs	15 Mtrs.	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper Floor	1 No	2 No.	MR
	• Basement	2 nos,	2.nos.	MR
	B. Width of Staircases			
	• Upper Floor	1.25 M	1.30M &1 M	MR
	• Basement	1.25 M	1.30M &1 M	MR
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	1 No.	1No.	MR
	g. Width of Corridor	N/A	N/A	N/A
	h. Door Size	1.0 Mtrs	1.0 Mtrs	MR
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	N/A	N/A	N/A
5.	Fire Extinguishers			
	• Total numbers	09 Nos.	12 Nos.	MR
	• types	ABC & Co2	ABC & Co2	MR
	• IS marking	ISI marked	ISI marked	MR

\* Accepted as per earlier NOC issued.



6	First-aid-Hose Reels.			
	Total numbers of each floor	1no.	1no.	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
8	MOEFA	Required	Provided	MR
9	Public address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	• Basement	Required	Provided	MR
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	100 MM	Provided	MR
	• Number of hydrants per floor	1 NO.	Provided	MR
	• Hose Box	1 NO.	Provided	MR
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.	N/A	N/A	N/A
	• Ground Level	N/A	N/A	N/A
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace Level	Required	Provided	MR
	➤ Discharge of pump	450 LPM	2 Nos.450 LPM	MR
	➤ Head of the Pump	40 M	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR


N19

14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	15,000 Ltrs.	15,000 Ltrs.	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.	N/A	N/A	N/A
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room	N/A	N/A	N/A
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules. The FSC issued vide letter no.F.6/DFS/MS/2012/1127 dated 28/03/2012 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Submitted please.

  
Signature of the Inspecting Officer  
Name:-Virendra Singh  
Designation :-DO(ED)

DCFO(NDZ)

