

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6 / DFS / MS / 2016 / 380

Dated: 10 / 03 / 2016

FIRE SAFETY CERTIFICATE

Certified that the New Green Vally Public School located at B Block, Street no. 111, Sant Nagar, Burari, Delhi comprised of Ground floor & First Floor was granted NOC by this department vide letter No F 6 / DFS / MS / school / 2013/WZ/506 dated 02.07.2013. The premises was re-inspected by the officer concerned of this department on 24.02.2016 in the presence of Smt Prerna Rautela (Principal) and observed that the building is now comprised of ground and two upper floors and temporary shed at terrace (school at ground & First floor only). All the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy Group B Educational with effect from10/03/2016 for a period of three years, subject to compliance of the conditions mentioned below:

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in
8. **The second and third floor of the building is restricted to residential purposes only.**

Issued on10/03/2016... at New Delhi


Dy. Chief Fire Officer
Ph:- 01123846352



Copy to: -

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 54.
2. The Principal/ New Green Vally Public School located at B Block, Street no. 111, Sant Nagar, Burar, Delhi.

INSPECTION REPORT

1. Name & address of the building : New Green Vally Public School, Gali No. 111, B Block, sant Nagar, Burari, New Delhi. (Ground +02 upper floors & temporary shed at terrace level)
2. Type of Occupancy : Educational
3. Type of Case : Old case (**school running at ground and first floor**)
4. Details of previous NOC : F6/DFS/MS/School/2013/WZ/506 dated 02.07.2015
(Ground plus first floor Only)
5. Fire Safety directives letter No : Director of Education Letter dated 01.03.2011.
6. Date of inspection : 24/02/2016
7. Name of the Inspecting Officers : ADO (RN)
8. Name and designation of officers
from the building side : Mrs Prerna Rautela (Principal)
9. Year of Construction : 2009 (2014 addition of hall at second floor)
10. Applicant's letter No. : Nil dated 18.01.2016

Plot Area-209 Sqm Covered area ----418 Sqy at G & 1st Floor), student 210, class room 08

	Minimum Standards on fire prevention and fire safety U/R 33	Dir. Of Education Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	6m	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	02	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.50 m	0.77 to 0.88m, 0.90 to 0.99m	MR Old case
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	02nos	NA
	e. Width of Corridor	NA	NA	NA

	f. Door Size	1.0m	1.0m with door fittings less than 45 students in a room	MR
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	30 a/c per hour	No basement	NA
	• Upper floors	12 a/c per hour	Natural Ventilated	MR
5	Fire Extinguishers			
	• Total numbers	06nos	08nos	MR
	• Types	ABC/Co2	ABC/Co2	MR
	• ISI marking	Yes	Yes	MR
6	First-Aid Hose Reels.			
	• Total numbers on each floor	NA	NA	NA Old case
	• Length of hose reel hose	NA	NA	NA
	• Nozzle diameter	NA	NA	NA
7	Automatic fire detection and alarming system.			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	MOEFA	NA	NA	NA
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	• Basement	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12	Yard Hydrants.			

	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA	NA	NA
		NA	NA	NA
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank Overhead Tank capacity 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
15	Exit Signage.	Required	P	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	N/A	N/A	N/A
		N/A	N/A	N/A
19	Fire Control Room			
	<ul style="list-style-type: none"> Detector System Panel 	N/A	N/A	N/A

N/19

	<ul style="list-style-type: none"> • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

General Requirements for school building premise as per Director of Education Circular:-

1. Escape Route----- clear
2. LPG Cylinders in laboratories-----NA
3. Electrical Wiring—conduit wiring provided
4. Electric meter board---safe place at entrance side
5. Basements as per BBL—NA
6. Emergency Telephone no--- Displayed
7. Generator set -----NA
8. ELCB/MCB--- Provided

The fire protection systems provided in the building were test checked and found in working order at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety required under circular issued by the Director of Education dated 01.03.2011, it is recommended to renewal of Fire Safety Certificate issued vide this department letter of even no.506 dated 02.07.2013 under rule 35 of the Delhi Fire Service Rules 2010.

Signature of the Inspecting Officer

Name :- Rajesh Kumar

Designation:- ADO/RN

11/25/2

DO/NWD
Rajesh