

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI


No. F6/DFS/MS/2016/W2/391

Dated: 11/3/16

FIRE SAFETY CERTIFICATE

Certified that the **Pirates of Grill** located at **Ground & First Floor, C - 12, Vishal Enclave, Rajouri Garden, New Delhi - 110027** in a building comprised of Basement + Ground + 3 Upper Floors was issued FSC vide Letter No.F6/DFS/MS/EH/2012/2220 Dated 20-06-2012. The premises was re inspected by the officers concerned of this department on 22-02-2016 in the presence of **Mr. Kumud Ranjan (Manager - Restaurant)** and found that the said building have deem complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class " Assembly" Group D with effect from 11/3/16 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 11/3/16..... at New Delhi by.


(Dr. G.C. Misra)
Chief Fire Officer,
Ph: 011 - 23414333.

Copy to:

1. Sh. Saurabh Gupta (Authorised Signatory),
Pirates of Grill, C - 12, Vishal Enclave,
Rajouri Garden, New Delhi - 110027.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

Re inspection to see the compliance of shortcomings communicated vide letter no. F6/DFS/MS/2015/1882 dated 17-08-2015. All the shortcomings are found complied.

INSPECTION REPORT

11. Name & address of the building: Pirates of Grill, Ground & First Floor, C – 12, Vishal Enclave, Rajouri Garden, New Delhi – 110027.
12. Type of Occupancy : Class-D (Assembly) (Basement + Ground + 3 Upper Floor)
13. Type of Case : Renewal
14. Details of previous NOC : Letter No.F6/DFS/MS/EH/2012/2220 Dated 20-06-2012
15. Fire Safety directives Letter No. : Nil
16. Date of inspection : 22-02-2016
17. Name of the Inspecting Officer : Mukesh Verma ADO (MN)
18. Name and designation of Officer
from the building side : Mr. Kumud Ranjan (Manager - Restaurant)
19. Year of Construction : 2009
20. Applicant's letter No. : Nil dated nil

S No	Minimum standards on fire prevention and fire safety U/R 33	NBC Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	Required	Provided	MR
		NA	NA	NA
		NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	g. Number of staircases			
	• Upper floors	2	Provided	MR
	• Basements	NA	NA	NA
	h. Width of staircases			
	• Upper floors	Old Case	Old Case	MR
	• Basement	NA	NA	NA
	i. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	j. No of continuous staircase to terrace	NA	NA	NA
	k. Width Of Corridor	NA	NA	NA
	l. Door Size	Old Case	Old Case	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA

	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	Required	Provided	MR
5.	Fire Extinguishers			
	• Total numbers	4	Provided	MR
	• Types	02ABC&02CO ₂	Provided	MR
	• IS marking	Required	Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	1	Provided & found functional	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Found Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	Required	Provided at GF & First Floor & found functional	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basements	NR	NR	NR
	• Upper Floor	Required	Provided at Ground & first floor	MR
	• Sprinkler above false ceiling	Required	Provided	MR
11.	Internal Hydrants:			
	• Size of riser/down- comer	100 mm	Found Provided	MR
	• Number of hydrants per floor	01	Found Provided	MR
	• Hose Box	01	Found Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	NR	NR	NR
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements:			
	• Ground Level			
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA

<ul style="list-style-type: none"> ➤ Auto Staring/Manual stopping ➤ Pump House Access <ul style="list-style-type: none"> • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power supply ➤ Auto starting of pump 	NA	NA	NA
	NA	NA	NA
	450 lpm,225 lpm	Provided & found functional	MR
	36mtr	Provided	MR
	Required	Provided	MR
	Required	Provided	MR
	Required	Provided	MR
14.	Captive water Storage for fire fighting:		
<ul style="list-style-type: none"> • Under ground tank capacity ➤ Draw off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	Not Required	NA	NA
	NA	NA	NA
	NA	NA	NA
	NA	Provided	MR
	5000 litres	Provided	MR
15	Exit Signage	Required	Found Provided
16.	Provision of Lifts		
<ul style="list-style-type: none"> ➤ Pressurization of Lift Shaft ➤ Pressurization of lift lobby ➤ Communication in lift Car ➤ Fireman's Grounding Switch ➤ Lift Signage 	NA	NA	NA
	NA	NA	NA
	NA	NA	NA
	NA	NA	NA
	NA	NA	NA
17.	Standby power supply	Required	Provided
18.	Refuge Area		
<ul style="list-style-type: none"> ➤ Total area ➤ Location 	NA	NA	NA
	NA	NA	NA
19.	Fire control room		
<ul style="list-style-type: none"> ➤ Detector system panel ➤ Flow Switch Panel ➤ PA System Panel ➤ Battery backup ➤ Building Floor Plans 	NA	NA	NA
	NA	NA	NA
	NA	NA	NA
	NA	NA	NA
	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/EH/2012/2220 Dated 20-06-2012 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer

Name

Designation

Mukesh Veema
ADD (M/N)

Signature of the Inspecting Officer

Name

Designation

