

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F6/DFS/MS/LPG/2016/82/414

Dated: 14/3/16

**FIRE SAFETY CERTIFICATE**

Certified that M/s Alka Flame (for storage of L.P.Gas Cylinders) located at Site No.-1, Sec.-7, R.K.Puram, New Delhi-110022, comprised of single storey building owned/occupied by Alka Flame was granted NOC by this department vide letter No.F6/DFS/MS/2013/701 dated: 19/02/2013. The premises was re-inspected by the officer concerned of this department on 03/03/2016 in the presence of Mr. Raj Kumar and found that the said cylinder storage building have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class Group J Hazardous Building(LPG cylinder storage) with effect from 14/3/16 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010.

Issued 14/3/16 at New Delhi by.

  
(Dr. G. C. Misra)  
Chief Fire Officer  
Tel: 011-23414333

Copy to:-

- (1) M/s Alka Flame  
Site No.-1, Sec.-7, R.K.Puram, New Delhi-110022.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. No naked light/flame for any purpose shall be used within the premises.
6. Safety distance shall always be kept free from any storage of material and no dwelling shall be allowed within the licensed premises.
7. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J" [ sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

N/15

**INSPECTION REPORT**

1. Name & address of the building: - M/S Alka Flame, Site No.-1, Sec.-7, R.K.Puram, New Delhi-110022.
2. Type of occupancy:- Storage, Group J Hazardous (for storage of L.P.Gas Cylinders)
3. Type of case:- Renewal
4. Details of previous NOC: - No.F6/DFS/MS/2013/701 dated: 19/02/2013.
5. Fire safety directives No: - N/A.
6. Date of inspection:- 03/03/2016
7. Name of the inspecting officer:- D.B.Mukherjee , ADO(BCP)
8. Name & designation of officer  
from the building side:- Mr. Raj Kumar
9. Year of construction:- 1984
10. Applicant's letter No:- Nil, dated: 28/01/2016,
11. Composition of building: - Single Storey Building.

Old Case

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	NBC/BBL Requirement	Provided at site	Remarks MR/NMR
<b>1.</b>	<b>Access to Building</b>			
	1) Road width	12m	Provided	MR
	2) Gate width	Required	Provided	MR
	3) Width of internal road	N/A	N/A	N/A
<b>2.</b>	<b>Number, Width Type &amp; Arrangement of Exits</b>			
	<b>A. Number of staircases</b>			
	1. Upper floors	N/A	N/A	N/A
	2. Basements	N/A	N/A	N/A
	<b>B. Width of staircase</b>			
	1. Upper floors	N/A	N/A	N/A
	2. Basements	N/A	N/A	N/A
	<b>C. Protection of exits</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	<b>D. No. of continuous staircase to terrace</b>			
		N/A	N/A	N/A
	<b>E. Width of corridor</b>			
		N/A	N/A	N/A
	<b>F. Door size</b>			
		Required	Provided 1mtr	MR
<b>3.</b>	<b>Compartmentation</b>			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
<b>4.</b>	<b>Smoke Management System</b>			
	1) Basements	30 a/c per hour	N/A	N/A
	2) Upper floors	12 a/c per hour	N/A	N/A
<b>5.</b>	<b>Fire Extinguishers</b>			
	1) Total numbers	ISI Marked	10 Nos.	MR
	2) Types		ABC,	MR
	3) ISI marking		Yes	MR
<b>6.</b>	<b>First-Aid Hose Reel</b>			
	1) Total number of each floor	N/A	N/A	N/A
	2) Length of hose reel hose	30 m	N/A	N/A
	3) Nozzle diameter	5 mm	N/A	N/A

<b>7.</b>	<b>Automatic Fire Detection &amp; Alarming System</b>			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
<b>8.</b>	<b>MOEFA</b>	N/A	N/A	N/A
<b>9.</b>	<b>Public Address System</b>	N/A	N/A	N/A
<b>10.</b>	<b>Automatic Sprinkler System</b>			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
<b>11.</b>	<b>Internal Hydrants</b>			
	1) Size of riser/down-comer	N/A	N/A	N/A
	2) Number of hydrants per floor	N/A	N/A	N/A
	3) Hose box	N/A	N/A	N/A
<b>12.</b>	<b>Yard Hydrants</b>			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
<b>13.</b>	<b>Pumping Arrangement</b>			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level	N/A	N/A	N/A
	a) Discharge of pump	N/A	N/A	N/A
	b) Head of pump	N/A	N/A	N/A
	c) Power supply	N/A	N/A	N/A
	d) Auto starting of pump	N/A	N/A	N/A
<b>14.</b>	<b>Captive Water Storage for Fire Fighting</b>			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	N/A	N/A	N/A
<b>15.</b>	<b>Exit Signage.</b>	N/A	N/A	N/A
<b>16.</b>	<b>Provision of Lifts.</b>			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
<b>17.</b>	<b>Stand by Power Supply</b>	N/A	N/A	N/A
<b>18.</b>	<b>Refuge Area</b>			
	Total area location	N/A	N/A	N/A

2/17

19.	<b>Fire Control Room</b>	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	<b>Special Fire Protection System for Protection of special Risk, if any:</b>			MR
	Fire Buckets filled with dry sand, No smoking boards were found displayed in Hindi & English. No loose electric wirings were seen in the premises.			

The fire protection system provided in the building were checked and found functional at the time of inspection.

In view of the compliance of the minimum standards on fire prevention and fire safety measures as required under the rules the NOC issued vide letter No.F6/DFS/MS/2013/701 dated: 19/02/2013, renewal under rules 35 of the Delhi Fire Service Rules 2010 is recommended.

*K. B. A.*  
4/6/2016

Signature of the inspecting officer  
Name: D.B. Mukherjee  
Designation: Asstt. Div. Officer (BCP)