

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F-6/DFS/MS/School/2016/MDZ/406

Dated: 14/03/16

FIRE SAFETY CERTIFICATE

Certified that the EDMC Primary School, Seelampur Ph-III, Shahdara North Zone, Delhi-53, comprised of ground floor plus one upper floor was granted FSC by this department vide Letter No- F.6/DFS/MS/School/2012/3985 dated 25.10.2012. School building was re-inspected by the officer concerned of this department on 03.03.2016 in the presence of Teacher of the school and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with the circular No. F.16/Estate/CC/Fire safety/2011/3298 to 3398 dated 01.03.11 issued by the Director of Education and found that the building having GF+FF is fit for occupancy Group B "Educational Building" with effect from 14.03.16... renewed for a period of three years, subject to conditions printed overleaf.

Issued on...14/03/16.....at New Delhi by


10/3
(Dr. G.C. Misra)

Chief Fire Officer

Ph -011- 23414333

G.C. Misra

To,

The Principal (1st Shift)

EDMC Primary School, 1st Floor (Urdu) Seelampur Ph-III, Shahdara North Zone, Delhi-53.

Copy to:-

1. The Director of Education,
East Delhi Municipal Corporation,
419, Udyog Sadan, Patparganj Industrial Area, Delhi-92
2. The Principal (1st Shift)
EDMC Primary School, Ground Floor (Hindi) Seelampur Ph-III, Shahdara North Zone, Delhi 53.
3. The Principal (2nd Shift)
EDMC Primary School, Ground Floor (Hindi), Seelampur Ph-III, Shahdara North Zone, Delhi-53.
4. The Principal (2nd Shift)
EDMC Primary School, 1st Floor (Urdu), Seelampur Ph-III, Shahdara North Zone, Delhi-53.

CONDITIONS:

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
6. This Fire Safety Certificate can not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : EDMC Primary School, Seelampur Ph-III, Shahdara, North Zone Delhi-53
2. Building is comprised of : **G+1**
3. Type of Occupancy : Educational
4. Type of Case : **Renewal**
5. Details of Previous FSC : F.6/DFS/MS/School/2012/3985 dated 25.10.2012
6. Fire Safety direction letter No : F.16/Estate/CC/Fire safety/2011/3298 to 3398 dated 01.03.11
7. Date of Inspection : 03.03.2016
8. Name of the Inspecting Officers: : Suresh Singh (ADO)
9. Name of the designation of Officer from the building side : Teacher
10. Year of Construction : 2009
11. Applicant's letter No : dated 24.02.2016

S.No	Minimum Standards on fire safety requirements as per circular no. 3298 to 3398 Dated. 01.03.11	Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	Road width	6 m	7 m	MR
	Gate width	N.A.	N.A.	N.A.
	Width of internal road	N.A.	N.A.	N.A.
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	Upper Floor	02 no.	02 no.	MR
	Basement	N.A.	N.A.	N.A.
	B. Width of Staircases			
	Upper Floor	1.5 m	1.4 m each	MR
	Basement	N.A.	N.A.	N.A.
	c. Protection of exits			
	Fire check door	N.A.	N.A.	N.A.
	Pressurization	N.A.	N.A.	N.A.
	e. No. of continuous staircases to terrace	1 no.	1 no	MR
g. Width of Corridor	1.5 m	2.3 m	MR	
h. Door Size	1 m	1 m	MR	
3	Compartmentation			
	Fire check door	N.A.	N.A.	N.A.
	Sealing of electrical shafts	N.A.	N.A.	N.A.
	Fire rating of shaft door	N.A.	N.A.	N.A.
	Water curtain	N.A.	N.A.	N.A.
	Fire Dampers	N.A.	N.A.	N.A.
4	Smoke Management System.			
	Basement	N.A.	N.A.	N.A.
	Upper floor	N.A.	N.A.	N.A.

5.	Fire Extinguisher			
	Total numbers	05 no.	06 no.	MR
	types	CO ₂ & ABC	CO ₂ & ABC	MR
	IS marking	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			
	Total numbers of each floor	N.A.	N.A.	N.A.
	Length of hose reel hose	N.A.	N.A.	N.A.
	Nozzle diameter	N.A.	N.A.	N.A.
7	Automatic fire detection and alarming system.			
	Type of detectors	N.A.	N.A.	N.A.
	Location of main panel	N.A.	N.A.	N.A.
	Location of repeater panel	N.A.	N.A.	N.A.
	Alternate source of power	N.A.	N.A.	N.A.
	Hooters's location	N.A.	NA	NA
8	MOEFA	N.A.	NA	NA
9	Public address System.	N.A.	Provided	MR
10	Automatic Sprinkler System.			
	basement	N.A.	N.A.	N.A.
	upper floor	N.A.	N.A.	N.A.
	sprinkler above false ceiling	N.A.	N.A.	N.A.
11	Internal Hydrants			
	size of riser/down-comer	N.A.	N.A.	N.A.
	Number of hydrants per floor	N.A.	N.A.	N.A.
	Hose Box	N.A.	N.A.	N.A.
12	Yard Hydrants.			
	Total number of hydrants	N.A.	N.A.	N.A.
	Hose Box	N.A.	N.A.	N.A.
13	Pumping Arrangements.			
	• Ground Level	N.A.	N.A.	N.A.
	➤ Discharge of main Pump	N.A.	N.A.	N.A.
	➤ Head of Main Pump	N.A.	N.A.	N.A.
	➤ Number of main pumps	N.A.	N.A.	N.A.
	➤ Jockey pump out put	N.A.	N.A.	N.A.
	➤ Jockey pump head	N.A.	N.A.	N.A.
	➤ Standby pump out put	N.A.	N.A.	N.A.
	➤ Standby pump Head	N.A.	N.A.	N.A.
	➤ Auto Starting /Manual stopping	N.A.	N.A.	N.A.
	➤ Pump House Access	N.A.	N.A.	N.A.
	• Terrace Level	N.A.	N.A.	N.A.
	➤ Discharge of pump	N.A.	N.A.	N.A.
	➤ Head of the Pump	N.A.	N.A.	N.A.
	➤ Power supply	N.A.	N.A.	N.A.
	➤ Auto Starting of pump	N.A.	N.A.	N.A.

N/9

14	Captive Water Storage for Fire Fighting.			
	Underground tank capacity	N.A.	N.A.	N.A.
	Draw-off connection	N.A.	N.A.	N.A.
	Fire service inlet	N.A.	N.A.	N.A.
	Access to tank	N.A.	N.A.	N.A.
	Overhead Tank capacity	N.A.	N.A.	N.A.
15	Exit Signage.			
16	Provision of Lifts.			
	Pressurization of Lift Shaft	N.A.	N.A.	N.A.
	Pressurization of Lift lobby	N.A.	N.A.	N.A.
	Communication in lift car	N.A.	N.A.	N.A.
	Firemen's grounding switch	N.A.	N.A.	N.A.
	Lift Signage	N.A.	N.A.	N.A.
17	Standby power supply			
18	Refuge Area.			
	Total area	N.A.	N.A.	N.A.
	Location	N.A.	N.A.	N.A.
19	Fire Control Room			
	Detector system panel	N.A.	N.A.	N.A.
	Flow switch panel	N.A.	N.A.	N.A.
	PA system panel	N.A.	N.A.	N.A.
	Batter backup	N.A.	N.A.	N.A.
	Building Floor Plans	N.A.	N.A.	N.A.
20	Special Fire Protection systems for protection of special Risks, if any:			
		N.A.	N.A.	N.A.

In view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the Rules the FSC issued vide letter no. F.6/DFS/MS/School/2012/3985 dated 25.10.2012 renewal under the circular No. 3298 to 3398 dated 01.03.11 is recommended.

Singh
4.3.16

Signature of the Inspecting Officer

Name Suresh Singh

Designation ADO (Shah)

DO (EAST)

Submitted for approval please.

Singh