

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F6/DFS/MS/W2/2016/399


Dated: 11 / 03 / 2016

FIRE SAFETY CERTIFICATE

Certified that Moti Mahal Delux Tandoori Trail (A unit of Duck Retail) at GA - 7 & 8, Unitech Metro Walk located at Sector 10, Rohini - 110085 comprised of Ground Floor only occupied by Moti Mahal Delux Tandoori Trail was issued NOC vide this office letter no F6/DFS/MS/2012/EH/2493 dated 10/07/2012. The premise was re-inspected by the officers concerned of this department on 01 / 03 / 2016 in presence of Sh. Ashwani Singh (Manager) and observed that all the fire safety and fire prevention arrangement as provided in the premises is found in good working condition and there is no additional construction. The premises have therefore deemed complied with requirements under Rule 33 of Delhi Fire Service Rules, 2010 and building / premises is fit for occupancy under Class Assembly with effect from 11 / 03 / 2016 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of Delhi Fire Service Rules, 2010.

1. Means of escape shall not be kept locked or bolted from outside and shall be easily open able by guests in an event of emergency.
2. All employees shall be acquainted with the use and maintenance of all the fire fighting installation/equipments.
3. The fire suppression / protection arrangements provided in the restaurant are to minimize losses, if maintained in good working condition. These systems cannot give any guarantee that there will be no fire or losses in the event of one.
4. Any loss of life and property due to non-functional of fire safety arrangements and other installations shall be the responsibility of the licensee.
5. This report may not in any way be treated as regularization of unauthorized construction, if any.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 11/03/2016 at New Delhi by

  
(Dr. G. C Misra)  
Chief Fire Officer  
Ph: 011-23414333

Copy to:

1. The Dy Health Officer, North Delhi Municipal Corporation, Health Department, Rohini Zone, Sector - 5, Rohini, Delhi. (for information)
2. The authorized signatory, Moti Mahal Delux Tandoori Trail (A unit of Duck Retail) at GA - 7 & 8, Unitech Metro Walk, Sector 10, Rohini - 110085

**INSPECTION REPORT**

1. Name & address of the building: Moti Mahal Delux Tandoori Trail (A unit of Duke Retail)  
GA-7 & 8 (GF) Metro Walk, Sector -10, Rohini.
2. Type of Occupancy : Restaurant
3. Type of Case : Renewal ✓
4. Details of previous NOC : F6/DFS/MS/2012/EH/2493 dated 10/07/2012
5. Fire Safety directives letter No : NBC Part IV
6. Date of inspection : 01 /03/2016
7. Name of the Inspecting Officers : DO (NW)
8. Name and designation of officers  
from the building side : Sh. Ashwani Singh (Manager)
9. Year of Construction : 20006-07
10. Applicant's letter No. : DHO/RZ/2015/1620 dated 17/02/2016

	Minimum Standards on fire prevention and fire safety U/R 33	NBC / BBL Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	4.50 mtr	P	M/R
	• Gate width	--	--	--
	• Width of internal road	--	--	--
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper Floors	--	--	--
	• Basements	--	--	--
	b. Width of staircases			
	• Upper Floors	--	--	--
	• Basements	--	--	--
	c. Protection of exits			
	• Fire check door	--	--	--
	• Pressurization	--	--	--
	e. No. of continuous staircases to terrace			
	g. Width of Corridor	--	--	--
	h. Door Size	N.A	1.2 & 1 mtr	NOC Already issued by dept.
3	<b>Compartmentation.</b>			
	• Fire check door	N/A	N/A	N/A

Moti Mahal Delux Tandoori Trail (A unit of Duck Retail), Sector 10, Rohini, Delhi

	<ul style="list-style-type: none"> <li>Sealing of electrical shafts</li> <li>Fire Rating of shaft door</li> <li>Water Curtain</li> <li>Fire Dampers</li> </ul>	--	--	--
4	<b>Smoke Management System.</b>			
	<ul style="list-style-type: none"> <li>Basements</li> <li>Upper floors</li> </ul>	30 a/c per hour 12 a/c per hour	N/A Provided in kitchen	NOC already issued
			N/A	N/A
5.	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>IS marking</li> </ul>	03  ISI marked	04  02 ABC & 02 WCo2 type Yes	M/R M/R M/R
6	<b>First-Aid Hose Reels.</b>			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	R  30 m  5 mm	Provided with mall  P  P	M/R M/R M/R
7	<b>Automatic fire detection and alarming system.</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	-- -- -- -- --	-- -- -- -- --	-- -- -- -- --
8	<b>MOEFA</b>	R	P in restaurant	M/R
9	<b>Public Address System.</b>	--	--	--
10	<b>Automatic Sprinkler System.</b>			
	<ul style="list-style-type: none"> <li>Basement</li> <li>Upper Floor</li> <li>Sprinkler above false ceiling</li> </ul>	-- N/A --	-- Provided with mall & restaurant --	-- --- --
11	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	N/A -- --	N/A -- --	N/A -- --

Moti Mahal Delux Tandoori Trail (A unit of Duck Retail), Sector 10, Rohini, Delhi

12	<b>Yard Hydrants.</b>			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	--	--	--
13	<b>Pumping Arrangements.</b>			
	• Ground Level			
	➤ Discharge of main Pump	4500 LPM	P	M/R
	➤ Head of Main pump	60 m	Provided with Mall	M/R
	➤ Number of main pumps			
	➤ Jockey Pump out put	180 LPM	Provided with Mall	M/R
	➤ Jockey pump head	60m	Provided with Mall	M/R
	➤ Standby Pump out put	4500 LPM	Provided with Mall	M/R
	➤ Standby Pump Head	60m	Provided with Mall	M/R
	➤ Auto Starting/ Manual stopping	R	P	M/R
	➤ Pump House Access	R	P	M/R
	• Terrace level			
	➤ Discharge of pump	--	--	--
	➤ Head of the pump	--	--	--
	➤ Power Supply	--	--	--
	➤ Auto Starting of pump	--	--	--
14	<b>Captive Water Storage for fire fighting.</b>			
	• Underground tank capacity	2,50,000 ltrs	Provided with Mall	M/R
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	30,000 ltr	Provided with Mall	M/R
15	<b>Exit Signage.</b>	R	P in restaurant	M/R
16	<b>Provision of Lifts.</b>			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	--	--	--
	• Communication In lift Car	--	--	--
	• Fireman's Grounding Switch	--	--	--
	• Lift Signage	--	--	--
17	<b>Standby power supply</b>	R	Provided with Mall	M/R
18	<b>Refuge Area.</b>			
	➤ Total Area	N/A	N/A	N/A

Moti Mahal Delux Tandoori Trail (A unit of Duck Retail), Sector 10, Rohini, Delhi

	➤ Location	N/A	N/A	N/A
19	<b>Fire Control Room</b>			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	--	--	--

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F6/DFS/MS/2012/EH/2493 dated 10/07/2012. Renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Signature of the Inspecting Officer

Name

Designation

*DEG/W2*

*C/O*  
*keertee*  
*4/3*

Signature of the Inspecting Officer

Name

Designation

*[Signature]*  
*3/3/16*  
*DO (NN)*

*969/D No (BY)*  
*7/3/16.*