

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F6/MS/DFS/SZ/EH/2016/ 415

Dated: 14/3/16

FIRE SAFETY CERTIFICATE

Certified that the Olive Bar & Kitchen Pvt. Ltd., located at Haveli Sarai No.6-8, Kalka Das Marg, Mehrauli, New Delhi comprised of ground and half upper floor but the restaurant is running at ground floor only was granted FSC by this department vide letter no.F6/DFS/MS/EH/2012/2828 dt.: 02/08/2012. The premises was re-inspected by the officer concerned of this department on 08/03/2016 in the presence of Mr. Thareja and found that the said restaurant have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class Group – D, Assembly Building (Restaurant) with effect from 14/3/16 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010.

Issued 14/3/16 at New Delhi by,


(Dr. G. C. Misra)
Chief Fire Officer
Tel: 011-23414333

Copy to: -

1. The Dy. Health Officer,
SDMC, South Zone,
Aurobindo Marg, Green Park
New Delhi.
2. Olive Bar & Kitchen Pvt. Ltd.
Haveli Sarai No.6-8, Kalka Das Marg,
Mehrauli, New Delhi

7c


Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. The basement shall be used as per the provisions of NBC
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J" [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building:- Olive Bar & Kitchen Pvt. Ltd., Haveli Sarai No.6-8, Kalka Das Marg, Mehrauli, New Delhi
 2. Type of occupancy:- Group – D, Assembly Building, (Restaurant & Bar)
 3. Type of case:- Renewal
 4. Details of previous NOC:- F6/DFS/MS/EH/2012/2828 Dated: 02/08/12
 5. Fire safety directives No.- Nil
 6. Date of inspection:- 08/03/2016
 7. Name of the inspecting officer:- D.B.Mukherjee, A.D.O.(BCP)
 8. Name & designation of officer From the building side:- Mr. Thareja
 9. Year of construction:- 2003
 10. Applicant's letter No:- DHO/SZ/2016/D/2599, dated:17/01/2016
- Building is comprised of ground and half upper floor .Restaurant is running at ground floor only.

Sl. No.	Minimum Standards on Fire Prevention and Fire Safety U/R 33	Requirement BBL	Provided at Site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	09 m	Provided	MR
	2) Gate width	4.5m	Provided	MR
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits:			
	A. Number of staircases			
	1. Upper floors	N/A	N/A	N/A
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	N/A	N/A	N/A
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	N/A	N/A	N/A
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	1.5m(old case)	02 nos. Provided	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
5.	Fire Extinguishers			
	1) Total numbers	ISI Marked	12 Nos.	MR
	2) Types		ABC, Co2 ,Foam	MR
	3) ISI marking		Yes	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	01no.	Provided 03nos.	MR
	2) Length of hose reel hose	30 mm	Provided	MR
	3) Nozzle diameter	5 mm	Provided	MR

7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location			
8.	MOEFA	Required	Provided	MR
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	N/A	N/A	N/A
	2) Number of hydrants per floor	N/A	N/A	N/A
	3) Hose box	N/A	N/A	N/A
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level			
	a) Discharge of main pump	450 lpm	Provided	MR
	b) Head of main pump	35m	Provided	MR
	c) Number of main pump	01	Provided	MR
	d) Jockey pump out put	180lpm	Provided	MR
	e) Jockey pump head	35m	Provided	MR
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	Required	Provided	MR
	2) Terrace level			
	a) Discharge of pump	N/A	N/A	N/A
	b) Head of pump	N/A	N/A	N/A
	c) Power supply	N/A	N/A	N/A
	d) Auto starting of pump	N/A	N/A	N/A
14.	Captive Water Storage for Fire Fighting			
	1) Underground tank capacity	5000 ltrs.	Provided	MR
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	N/A	N/A	N/A
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Standby Power Supply	Required	Provided DG set	MR

Handwritten mark

18.	Refuge Area			
	Total area location	N/A	N/A	N/A
19.	Fire Control Room			
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection systems provided in the restaurant were checked and found functional at the time of inspection.
 Keeping in view of substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to renew Fire Safety Certificate issued vide letter no. F6/DFS/MS/EH/2012/2828 Dated: 02/08/12 under rules 35 of the Delhi Fire Service Rules 2010. Accordingly DFA is prepared and put up for perusal and sign please.

D.B. Mukherjee
 21/3/16

Signature of the inspecting officer
 Name :- D.B. Mukherjee.
 Designation :- Assitt. Div. Officer(BCP).