

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.

E-mail:- cfhq.dlfire@nic.in

No.F.6/DFS/MS/School/2016/SZ/447


Fax: - 011-23412593

Dated: 21/03/16

FIRE SAFETY CERTIFICATE

Certified that the building of **Daisy Dales International School**, A-Block, Vikaspuri, New Delhi-110018, is comprised of basement, ground plus three upper floors. The school was issued NOC by this department vide letter no. F6/DFS/MS/2007/2144 dated 06.8.2007 for ground plus two upper floors. The school is owned/occupied by the school management was inspected by the officer concerned of this department on 07.3.2016 in the presence of Smt. Shineh Suri (Principal) and found that the school management have complied with the fire prevention and fire safety requirements in accordance with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premises is fit for occupancy class educational w.e.f. the date of issue of this certificate for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed as below.

Issued on..... 21/03/16 at New Delhi.


(DR. G.C. MISRA)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE

Copy to:-

1. The Principal,
Daisy Dales International School,
A-Block, Vikaspuri, New Delhi-110018.
2. Director of Education,
Govt. of NCT of Delhi, Old Secretariat,
New Delhi -- 110054.


D.C. Sam
17/3/16

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per the building bye laws.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

Comprised of basement ground plus three upper floors. Earlier FSC was issued in the Name of Kamal Convent School, A-Block Vikaspuri was comprised of ground plus two upper floors.
(Daisy Dales International School, A-Block, Vikaspuri, New Delhi-110018)

INSPECTION REPORT

1. Name & address of the building : Daisy Dales International School, A-Block, Vikaspuri, New Delhi-18.
2. Type of Occupancy : Educational
3. Type of Case : Old/New ✓
4. Details of Previous NOC : F.6/DFS/MS/2007/2144 dated 06.08.2007 (For ground plus two upper floors) ✓
5. Fire Safety directives letter No : N/A
6. Date of inspection : 07.3.2016 ✓
7. Name of Inspecting Officer : A.D.O. Sandeep Duggal
8. Name and designation of officers
From the building side : Smt. Shineh Suri (Principal)
9. Year of Construction : 1996 (G+II) & 2015 (B+G+III) ✓
10. Applicant's letter No. : Letter No. Nil dated 17.02.2016.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/ Dt. of edu. Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	Accessible — —	08 mtrs 4.25 & 4.45 mtrs —	M/R — —
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basement 	02 No's 02 No's	02 No's 02 No's	M/R ✓ M/R
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basements 	1.5 mtrs 1.5 mtrs	1.5 mtrs X 2 1.5 mtrs X 2	M/R ✓ M/R
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	Required N/A	Provided N/A	M/R N/A
	d. No. of continuous staircases to terrace	N/A	One	N/A
	e. Width of Corridor	1.5 mtrs.	1.65 mtrs	M/R
	f. Door Size	100 cms	100 cms X 2	M/R
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	N/A N/A N/A N/A N/A	N/A Sealed N/A N/A N/A	N/A N/A N/A N/A N/A
4.	Smoke Management System			
	<ul style="list-style-type: none"> • Basements 	Required	Exhaust fans Provided	MR ✓

Sm

MS

Comprised of basement ground plus three upper floors. Earlier FSC was issued in the Name of Kamal Convent School, A-Block Vikaspuri was comprised of ground plus two upper floors.
(Daisy Dales International School, A-Block, Vikaspuri, New Delhi-110018)

	<ul style="list-style-type: none"> Upper floors 	N/A	Natural ventilation	N/A
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	14 no's ABC/CO ₂ type ISI marked	Provided Provided ISI marked	M/R M/R M/R
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	One 30 mtrs 5 mm	Provided Provided Provided	M/R M/R M/R
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors (smoke detectors) Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	N/A N/A N/A N/A N/A	Provided Ground floor N/A Provided At exits	N/A N/A N/A N/A N/A
8.	MOEFA	N/A	Provided	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Ground Floor Sprinkler above false ceiling 	Required N/A N/A	Provided N/A N/A	M/R N/A N/A
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	N/A N/A N/A	N/A N/A N/A	N/A N/A N/A
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	N/A N/A	N/A N/A	N/A N/A
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping 	N/A N/A N/A N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A N/A N/A

S. om

Comprised of basement ground plus three upper floors. Earlier FSC was issued in the Name of Kamal Convent School, A-Block Vikaspuri was comprised of ground plus two upper floors.
(Daisy Dales International School, A-Block, Vikaspuri, New Delhi-110018)

	<ul style="list-style-type: none"> ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	N/A	N/A	N/A
		900 LPM	Provided	M/R
		30 mtrs	Provided	M/R
		Required	Provided	M/R
		Required	Provided	M/R
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	Provided	N/A
		N/A	N/A	N/A
		15000 ltrs	Provided	M/R
		Required	Provided	M/R
15.	Exit Signage.			
16.	Provision of Lifts.			(No Lift)
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	125 KVA	N/A
17.	Standby power supply			
18.	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	N/A	N/A	N/A
		N/A	N/A	N/A
19.	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Battery backup • Building Floor Plans 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A

Sam

N/10

Comprised of basement ground plus three upper floors. Earlier FSC was issued in the Name of Kamal Convent School, A-Block Vikaspuri was comprised of ground plus two upper floors.
(Daisy Dales International School, A-Block, Vikaspuri, New Delhi-110018)

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the above substantial compliance of the minimum standards of fire prevention and fire safety measures as required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

Sandeep
10/3/16

Signature of Inspecting Officer

Name:- Sandeep Duggal

Designation:- Asstt. Divisional Officer

D.O. (South West)

K. Kumar
11/3/16

Signature of Inspecting Officer

Name

Designation

