

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.**

E-mail:- cfohq.dlfire@nic.in

Fax:- 011-23412593

No. F.6/DFS/MS/GH/2016/52/446

Dated: 21/03/16

FIRE SAFETY CERTIFICATE

Certified that the **Hotel Horizon Palace** located at 6A/7, WEA, Karol Bagh, New Delhi-110005 is comprised of Ground floor plus three upper floors, using ground floor as reception and one hall, first floor as residence of the owner, second & third floor each having 06 guest rooms respectively (Total 12 guest rooms), a temporary shed on terrace was issued NOC by this department vide letter No.F.6/DFS/MS/GH/2013/455 dated 01.02.2013 owned/occupied by Sh. Vinod Sharma. The guest house building was re-inspected by the officers concerned of this department on 10.03.2016 in the presence of Sh. Vinod Sharma (Owner) and found that the owner have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premises is fit for occupancy class residential w.e.f. the date of issue of this certificate for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed overleaf.

Issued on...21/03/16..... at New Delhi.


(DR. G.C. MISRA)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE
Ph:- 011-23414333

Copy to:-

1. Sh. Vinod Sharma (Owner)
Hotel Horizon Palace, 6A/7, WEA,
Karol Bagh, New Delhi-110005.

O/C Secy
17/3/16

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner/ occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

Ground Floor plus three upper floors.
(2nd & 3rd floor having 06 Guestrooms each Total 12 Guestrooms)

INSPECTION REPORT

1. Name & address of the building : Hotel Horizon Palace, 6A/7, WEA, Kashi Bagh, N.D.-05.
2. Type of Occupancy : Residential (Guest House)
3. Type of Case : New Case/Renewal
4. Details of Previous NOC : Letter No. F.G/DFS/MS/GH/2013/455 Date 01.02.2013
5. Fire Safety directives letter No : _____
6. Date of inspection : 10.03.2016
7. Name of Inspecting Officer : D.O S.K. Tomar & A.D.O Sandeep Nuggal
8. Name and designation of officers
From the building side : Sh. Vinod Sharma (Owner) -
9. Year of Construction : Before 2001
10. Applicant's letter No. : Nil dated Nil (Form J)

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/BBL Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	Accessible	12 mtr	MR
	• Gate width	-	180 cms	MR
	• Width of internal road			
2.	Number, Width, Type & Arrangement of Exits			
a.	Number of staircases			
	• Upper Floors	One	One	MR, Old Case
	• Basements	-	-	No Basement
b.	Width of staircases			
	• Upper Floor	-	110 cms	MR, Old Case
	• Basements	-	-	No Basement
c.	Protection of exits			
	• Fire check door	-	-	-
	• pressurization	-	-	-
d.	No. of continuous staircases to terrace			
		-	One	-
e.	Width of Corridor			
		-	105cms, 265cms	-
f.	Door Size			
		-	89cms x 186cms	-
3.	Compartmentation			
	• Fire check door	-	-	-
	• Sealing of electrical shafts	-	Sealed	-
	• Fire Rating of shaft door	-	-	-
	• Water Curtain	-	-	-
	• Fire Dampers	-	-	-
4.	Smoke Management System			
	• Basements	30 a/c per hour	-	No Basement
	• Upper floors		Natural Ventilation	MR

SAN

		12 a/c per hour	-	-
5.	Fire Extinguishers			
	• Total numbers	Two at each Floor	Provided	MR -
	• Types	CO ₂ , WCO ₂ , ABC	- do -	MR -
	• IS marking	ISI marked	ISI Marked	MR -
6.	First-Aid Hose Reels			
	• Total numbers on each floor	NA	Provided	NA -
	• Length of hose reel hose	30 m	- do -	NA -
	• Nozzle diameter	5 mm	- do -	NA -
7.	Automatic fire detection and alarming system			
	• Type of detectors	-	-	-
	• Location of Main Panel	-	-	-
	• Location of Repeater Panel	-	-	-
	• Alternate source of power	-	-	-
	• Hooters' Location	-	-	-
8.	MOEFA	NA	NA	NA -
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basement	-	-	No Basement
	• Upper Floor	-	-	-
	• Sprinkler above false ceiling	-	-	-
11.	Internal Hydrants			
	• Size of riser/down-comer	-	-	-
	• Number of hydrants per floor	-	-	-
	• Hose Box	-	-	-
12.	Yard Hydrants			
	• Total number of hydrants	-	-	-
	• Hose Box	-	-	-
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	-	-	-
	➤ Head of Main pump	-	-	-
	➤ Number of main pumps	-	-	-
	➤ Jockey Pump out put	-	-	-
	➤ Jockey pump head	-	-	-
	➤ Standby Pump out put	-	-	-
	➤ Standby Pump Head	-	-	-
	➤ Auto Starting/Manual stopping	-	-	-
		-	-	-

san

GA/7, WEA, Karol Bagh,
New Delhi - 110005.

	<ul style="list-style-type: none"> ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	-	-	-
		NA	180 LPM	NA
		NA	30 M	NA
		-	-	-
		-	-	-
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	-	-	-
		-	-	-
		-	-	-
		-	-	-
		NA	1000 Ltr	NA
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	-	-	-
		-	-	-
		NA	Provided	NA
		-	-	Old Lift
		NA	NA	NA
17.	Standby power supply	Required	D.G. Set of 15 KVA	MR
18.	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	-	-	-
		-	-	-
19.	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	-	-	-
		-	-	-
		-	-	-
		-	-	-
		-	-	-
20.	Special Fire Protection System for Protection of special Risks, if any:	-	-	-

Sam

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F.G/DFS/MS/CH/2013/455 dated 01.02.2013 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Note:- The Guest house building is comprised of Ground floor plus three upper floors, Ground floor as reception & hall, first floor as residence of the owner, second & third floor each having 06 Guest rooms respectively (Total 12 Guest rooms).

S.K. Tomar
14/3/16

Signature of Inspecting Officer

Name S.K. Tomar

Designation Divisional Officer

Sandeep
14/3/16

Signature of Inspecting Officer

Name Sandeep Duggal

Designation Asstt. Divisional Officer

By CFO (S2)
[Signature]
16/3/16

