

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F6/DFS/MS/Banquet Hall/2016/MOZ/450

Dated: 21/03/16

FIRE SAFETY CERTIFICATE

Certified that the M/s Khursheeda Palace (Banquet Hall) is running on ground plus one upper floor of the building at C-150, KH. No142/ 2, 101/1 & 128/1, Near Sheshewali Masjid Ghonda, Delhi, which is comprised of ground plus two upper floors owned/occupied by M/s Khursheeda Palace, have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rule, 2010 and verified by the officers concerned of Fire Service on 08.03.2016 in the presence of Sh. Mohd. Zamil, Owner and found that the building having GF+FF is fit for occupancy class D 'Assembly (Banquet Hall)' with effect from ..21/03/16... for a period of three years, in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010, subject to conditions printed overleaf.

Issued on.....21/03/16.....at New Delhi by

(Dr. G.C. Misra)

Chief Fire Officer

Ph -011- 23414333

etc Singh

To,

M/s Khursheeda Palace (BanquetHall),

C-150, KH. No.142/ 2, 101/1 & 128/1, Near Sheshewali Masjid, Ghonda, Delhi

Copy to-

The Dy. Health Officer,

East Delhi Municipal Corporation,

Shahdara (North) Zone, Delhi

CONDITIONS:

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc. may be got verified from the authorities concerned.
6. This Fire Safety Certificate can not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : M/s Khursheeda Palace (BanquetHall), C-150, KH. No. 142/ 2, 101/1 & 128/1, Near Sheshewali Masjid, Ghonda, Delhi
2. Building is comprised of : Banquet is running at ground plus one upper floor of the building which is comprises of ground plus two upper floors.
3. Type of Occupancy : Assembly (Banquet Hall)
4. Type of Case : New Case
5. Details of Previous FSC : Nil
6. Fire Safety direction letter No : NBC Part-IV
7. Date of Inspection : 08.03.2016
8. Name of the Inspecting Officers: : Suresh Singh (ADO)
9. Name of the designation of Officer from the building side : Mohd. Zamil
10. Year of Construction : 2000
11. Applicant's letter No : dated 25.02.2016

S.No	Minimum Standards on fire prevention and fire safety U/R33	Requirement /NBC	Provided at Site	Remarks MR/NMR
1	Access to building			
	Road width	6 m	07 m	MR
	Gate width	NA	NA	NA
	Width of internal road	N.A.	N.A.	N.A.
2	Number, Width, Type and Arrangement of Exits			
❖	a. Number of Staircases			
	Upper Floor	1 no.	03 no.	MR
	Basement	NA	NA	NA
	b. Width of Staircases			
	Upper Floor	2 m	2m, 0.85m,0.85m	MR
	Basement	NA	NA	NA
	c. Protection of exits			
	Fire check door	Required	Provided	MR
	Pressurization	N.A.	N.A.	N.A.
	e. No. of continuous staircases to terrace	1 no.	01 no.	MR
	g. Width of Corridor	N.A.	N.A.	N.A.
h. Door Size	2 m	2m	MR	
i.No. of doors	2 no.	2 no.	MR	
3	Compartmentation.			
	Fire check door	NA	NA	NA
	Sealing of electrical shafts	Required	Provided	MR
	Fire rating of shaft door	N.A.	N.A.	N.A.
	Water curtain	N.A.	N.A.	N.A.
	Fire Dampers	N.A.	N.A.	N.A.
4	Smoke Management System.			
	Basement	Ventilated	Ventilated	MR
	Upper floor	Ventilated	Ventilated	MR

❖ Travel distance is meeting requirement with one staircase having width 2m.

5.	Fire Extinguisher			
	Total numbers	04 no.	04 no.	MR
	types	CO ₂ & ABC	CO ₂ & ABC	MR
	IS marking	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			
	Total numbers of each floor	1 no.	1 no.	MR
	Length of hose reel hose	30 m	30 m	MR
	Nozzle diameter	5 mm	5 mm	MR
7	Automatic fire detection and alarming system.			
	Type of detectors	NA	NA	NA
	Location of main panel	NA	NA	NA
	Location of repeater panel	N.A.	N.A.	N.A.
	Alternate source of power	N.A.	N.A.	N.A.
	Hooters's location	N.A.	N.A.	N.A.
8	MOEFA	Required	Provided	MR
9	Public address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	Basement	NA	NA	NA
	upper floor	N.A.	N.A.	N.A.
	sprinkler above false ceiling	N.A.	N.A.	N.A.
11	Internal Hydrants			
	size of riser/down-comer	100 mm	100 mm	MR
	Total no. of hydrants each floor	01 No.	01 No.	MR
	Hose Box per floor	01 No.	01 No.	MR
12	Yard Hydrants.			
	Total number of hydrants	N.A.	N.A.	N.A.
	Hose Box	N.A.	N.A.	N.A.
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> • Ground Level ➤ Discharge of main Pump ➤ Head of Main Pump ➤ Number of main pumps ➤ Jockey pump out put ➤ Jockey pump head ➤ Standby pump out put ➤ Standby pump Head ➤ Auto Starting /Manual stopping ➤ Pump House Access • Terrace Level ➤ Discharge of pump ➤ Head of the Pump ➤ Power supply ➤ Auto Starting of pump 			
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		450 LPM	450 LPM	MR
		40 m	40 m	MR
		Required	Provided	MR
		Required	Provided	MR

N/7

14	Captive Water Storage for Fire Fighting.			
	Underground tank capacity	NA	NA	NA
	Draw-off connection	N.A.	N.A.	N.A.
	Fire service inlet	N.A.	N.A.	N.A.
	Access to tank	N.A.	N.A.	N.A.
	Overhead Tank capacity	10,000 Liters	15,000 Liters	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	Pressurization of Lift Shaft	N.A.	N.A.	N.A.
	Pressurization of Lift lobby	N.A.	N.A.	N.A.
	Communication in lift car	N.A.	N.A.	N.A.
	Firemen's grounding switch	N.A.	N.A.	N.A.
	Lift Signage	N.A.	N.A.	N.A.
17	Standby power supply	NA	NA	NA
18	Refuge Area.			
	Total area	N.A.	N.A.	N.A.
	Location	N.A.	N.A.	N.A.
19	Fire Control Room			
	Detector system panel	N.A.	N.A.	N.A.
	Flow switch panel	N.A.	N.A.	N.A.
	PA system panel	N.A.	N.A.	N.A.
	Batter backup	N.A.	N.A.	N.A.
	Building Floor Plans	N.A.	N.A.	N.A.
20	Special Fire Protection systems for protection of special Risks, if any:	N.A.	N.A.	N.A.



The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.

Singh
B. 3. 16

Signature of the Inspecting Officer

Name Suresh Singh

Designation ADO (SHAH)

DO (EAST)

Submitted for approval please.