

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001**

NO. F6/DFS/MS/SCHOOL/2016/SZ/ 442

Dated: 21/03/16

**FIRE SAFETY CERTIFICATE**

Certified that the Sanjeevan Public School, D-276, Dashrathpuri, New Delhi-110058, comprised of ground plus one floor having four class rooms at ground floor & three class room at first floor, owned/occupied by Sanjeevan Public School, have complied with the fire prevention and fire safety requirements in accordance with Directorate of Education GNCT of Delhi Circular No. Estate/CC/Fire Safety/2011/3298 dated 01.03.2011 and verified by the officer concerned of Fire Service on 3.3.2016 in presence of Smt. Ritu Gupta Manager of the school, and that the building is fit for occupancy class B "Educational building" with effect from 21/03/16 for a period of **three years** in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 printed overleaf.

Issued on 21/03/16 at New Delhi by

  
18/3  
(Dr. G C Misra)  
Chief Fire Officer  
Ph.011-23414333  
SVC

Copy to,

1. Director (Education) SDMC, 23<sup>rd</sup> floor, Civic Centre, Minto Road, New Delhi.
2. Manager, Sanjeevan Public School, D-276, Dashrathpuri, New Delhi-110058.

## CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.

N/4

### INSPECTION REPORT

1	Name & address of the building	Sanjeevan Public School, D-276, Dashrathpuri, New Delhi-110058.		
2	Type of Occupancy	Educational Building "B"		
3	Type of case	New		
4	Details of previous NOC	Nil		
5	Fire safety directives letter No	Directorate Of Education Circular. No. F.16/Estate/CC/Fire Safety/2011/3298 dated 01.03.2011.		
6	Date of inspection	3.3.2016		
7	Name of the inspecting Officers :	ADO S.P. Bhardwaj		
8	Name and designation of officers from the building side	Smt. Ritu Gupta (Manager)		
9	Year of construction	2009		
10	Applicant's letter No.	Nil dated. 16.2.2016	<b>Ground Plus One upper floor having four Rooms at Ground &amp; Three Rooms at First Floor.</b>	

S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement/ DOE Circular dated 01.03.2011	Provided at site	Remarks MR / NMR
--------	---	--	------------------	------------------

<b>1</b>	<b>Access to building</b>			
	1) Road width	Accessible	Accessible (6 Mtrs.)	MR ✓
	2) Gate width	Approachable	Abute on Road (2 Mtrs.)	MR ✓
	3) Width of internal road	N/A	N/A	N/A

<b>2</b>	<b>Number, width Type &amp; arrangement of exits</b>			
	<b>a. Number of staircases</b>			
	1. Upper floors	One	Two	MR ✓
	2. basements	N/A	N/A	N/A
	<b>b. Width of staircase</b>			
	1. Upper floors	1.5 Mtrs.	1 Mtr. & Another 1 Mtr.	MR ✓
	2. basements	N/A	N/A	N/A
	<b>c. Protection of exits</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	<b>d. No. of continuous staircase to terrace</b>	N/A	N/A	N/A
	e. Width of corridor	1.1 Mtr.	1.1 Mtr. to 2 Mtrs.	MR ✓
	f. Door size	1 Mtr.	1 Mtr.	MR ✓

<b>3</b>	<b>Compartmentation.</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A

<b>4</b>	<b>Smoke Management system.</b>			
	basement	N/A	N/A	N/A
		12 ac charge		
	upper floors		Ventilated	MR ✓

<b>5</b>	<b>Fire Extinguishers</b>			
	total numbers	2 Nos. each floor	4 Nos	MR ✓
	Types	Co2 Or ABC	ABC	MR ✓

<b>6</b>	<b>First-Aid Hose Reels.</b>			
	total numbers on each floor	N/A	N/A	N/A
	Length of Hose reel hose	N/A	N/A	N/A
	Nozzle Diameter	N/A	N/A	N/A
<b>7</b>	<b>Automatic fire detection and alarming system</b>			
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
<b>8</b>	<b>MOEFA</b>	N/A	N/A	N/A
<b>9</b>	<b>Public Address System.</b>	N/A	N/A	N/A
<b>10</b>	<b>Automatic Sprinkler System.</b>			
	basement	N/A	N/A	N/A
	upper floors	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
<b>11</b>	<b>Internal Hydrants</b>			
	Size of riser/down-corner	N/A	N/A	N/A
	Number of Hydrants per floor	N/A	N/A	N/A
	hose Box	N/A	N/A	N/A
<b>12</b>	<b>Yard Hydrants.</b>			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
<b>13</b>	<b>Pumping arrangements</b>			
	<b>1. Ground level</b>			
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	<b>2. Terrace level</b>			
	a. Discharge of pump	N/A	N/A	N/A
	b. head of the pump	N/A	N/A	N/A
	c. Power supply	N/A	N/A	N/A
	d. Auto starting of pump	N/A	N/A	N/A
<b>14</b>	<b>Captive water storage for fire fighting</b>			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	N/A
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	N/A	N/A	N/A
<b>15</b>	<b>Exit Signage.</b>	N/A	N/A	N/A
<b>16</b>	<b>Provision of lifts.</b>			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A

2/6

17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.	Not Required		
	total area			
	location			
19	Fire control room			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any:	ABC		

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view the substantial compliance of minimum standards on fire safety required as per Director of Education Circular no. F/16/Estate/CC/Fire Safety/2011/3298 dated 1.3.2011, grant of Fire Safety Certificate is recommended under Rule 35 of the Delhi Fire Service, Rules 2010.

Accordingly DFA is put up for approval and signature please.

*S.P. Bhardwaj*  
14/3/16  
Signature of the Inspecting Officer

Name S.P. Bhardwaj

Designation ADO (Dwarka)