

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001


NO.F6/DFS/MS/School/2016/SZ/ 445

Dated: 21/03/16

FIRE SAFETY CERTIFICATE

Certified that the Sarvodaya Kanya Vidyalaya , Village Deendarpur, New Delhi-110043 comprised of ground plus one upper floor was granted NOC by this office vide letter no. F6/DFS/MS/2011/School/3595/ dated 16.12.2011. The building have been re-inspected by the officer concerned of this department on 10.3.2016 in presence of Smt. Kamud Walia (Principal) and found that school building have deemed complied with the fire prevention and fire safety requirements in accordance with Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by Directorate of Education, Govt. of NCT of Delhi , and that the building is fit for occupancy class B "Educational building" with effect from 21/03/16... for a period of **three** years, in accordance with rule 36 unless renewed 37 or sooner cancelled under rule 40 subject to compliance of the conditions under rule 38, of the Delhi Fire Service, Rules 2010, printed overleaf.

Issued on 21/03/16 at New Delhi by



(Dr. G C Misra)

Chief Fire Officer

Ph.011-23414333

97C

Swy

Copy to:

1. Director (Education), SDMC, 15th floor, SPM Civic Centre, Minto Road, New Delhi.
2. Incharge, M C Primary School, Daulat Pur, New Delhi-110043.

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.

INSPECTION REPORT

1	Name & address of the building	Sarvodaya Kanya Vidhalaya , Vill. Deendarpur, New Delhi-110043.		
2	Type of Occupancy	Educational Building "B"		
3	Type of case	Renewal		
4	Details of previous NOC	No.F6/DFS/MS/2011/School/3595 dated 16.12.2011		
5	Fire safety directives letter No	Edu. Circular. No. F.16/Estate/CC/Fire Safety/2011/3298 dated 01.03.2011.		
6	Date of inspection	10.3.2016		
7	Name of the inspecting Officers :	ADO S.P. Bhardwaj		
8	Name and designation of officers from the building side	Smt. Kumud Walia (Principal)		
9	Year of construction	Before 2010		
10	Applicant's letter No.	SKV/ 137 Dated 18.2.2016	(Ground plus one upper floor)	

S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR / NMR
		DOE Circular		

1	Access to building			
	1) Road width	Accessible	9 Mtrs.	MR
	2) Gate width	Accessible	5 Mtrs.	MR
	3) Width of internal road	N/A	N/A	N/A

2	Number, width Type & arrangement of exits			
	a. Number of staircases			
	1. Upper floors	Four	Four	MR
	2. basements	N/A	N/A	N/A
	b. Width of staircase			
	1. Upper floors	146,189,170,172 Cms.	146,189,170,172 Cms.	MR
	2. basements	N/A	N/A	N/A
	c. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	N/A	N/A	N/A
	e. Width of corridor	180 Cms.	180 Cms.	MR
	f. Door size	1 Mtr.	1 Mtr.	MR

3	Compartmentation.			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A

4	Smoke Management system.			
	basement	30 a/c per hour 12 a/c per hour	N/A	N/A
	upper floors		Natural Vent.	MR

5	Fire Extinguishers			
	total numbers		14 Nos.	MR
	Types	One Co2 OR ABC For	Co2 & ABC	MR

6	First-Aid Hose Reels.			
	total numbers on each floor	N/A	N/A	N/A
	Length of Hose reel hose	N/A	N/A	N/A
	Nozzle Diameter	N/A	N/A	N/A
7	Automatic fire detection and alarming system			
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	basement	N/A	N/A	N/A
	upper floors	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	Size of riser/down-corner	N/A	N/A	N/A
	Number of Hydrants per floor	N/A	N/A	N/A
	hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
13	Pumping arrangements			
	1. Ground level			
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	2. Terrace level			
	a. Discharge of pump	N/A	N/A	N/A
	b. head of the pump	N/A	N/A	N/A
	c. Power supply	N/A	N/A	N/A
	d. Auto starting of pump	N/A	N/A	N/A
14	Captive water storage for fire fighting			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	N/A
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	N/A	N/A	N/A
15	Exit Signage.	N/A	N/A	N/A
16	Provision of lifts.			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A

4/7

17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.	Not Required		
	total area			
	location			
19	Fire control room			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any:	Co2		

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view the deemed compliance of minimum standards on fire prevention and fire safety required under the rules, renewal of FSC issued vide letter no.F6/DFS/MS/School/2013/3595 dated. 16.12.2011 is recommended under rules 37 of the Delhi Fire Service Rules 2010.

Accordingly DFA is put up for approval and signature please.

Sury
10/3/16

Signature of the Inspecting Officer

Name S.P. Bhardwaj

Designation ADO (Dwarka)