

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F6/MS/DFS/ SZ/Hospital/ 2016/ 452

Dated: 22/03/16

FIRE SAFETY CERTIFICATE


Certified that the Seeds of Innocence Fertility & Maternity Hospital (Formerly Geetanjali Nursing Home (P) Ltd.), 3, MMTC/STC Colony, Geetanjali Enclave, New Delhi-110017 comprised of basement, ground, mezzanine plus three upper floors was granted FSC by this department vide letter no. F6/ DFS/ MS/ 94/Hospital/1068 dated 20/07/1994. The hospital building was re-inspected by the officer concerned of this department on 04.03.2016 in the presence of Mr. Sunil and found that the said premises have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class Group-G Institutional Building (Hospital) with effect from ~~22/03/16~~ for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010.

Issued ~~22/03/16~~ at New Delhi by.


(Dr. G. C. Misra)
Chief Fire Officer
Tel: 011-23414333

Copy to:

Dr.Gauri Aggarwal
Seeds of Innocence
3,MMTC/STC Colony, Geetanjali Enclave,
New Delhi-110017


21/3/2016

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. The basement shall be used strictly as per the provisions of Building Bye laws.
3. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
4. The trained fire fighting staff should be available round the clock.
5. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J" [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building:- Seeds of Innocence Fertility Clinic,3, MMTC/STC Colony, Geetanjali Enclave, New Delhi-110016
2. Type of occupancy:- Institutional Building G (Hospital)
3. Type of case: - Renewal
4. Details of previous NOC: - F6/DFS/MS/94/Hospital/1068,Dated 20/07/1994 & F6/MS/DFS/Hospital/2005/780 dated:12/04/2005.
5. Fire safety directives No.- F6/DFS/MS/94/Hospital/424,Dated 23/03/1994.
6. Date of inspection:- 04/03/2016
7. Name of the inspecting officer:- D.B.Mukherjee, A.D.O.(BCP)
8. Name & designation of officer from the building side: - Mr. Sunil
9. Year of construction:- 1994
- 10.Applicant's letter No:- Nil dated 10/02/2016
11. Composition of Building : **Basement, Ground, Mezzanine + 03 Upper Floors .**

Fertility Center is running at 1st to 3rd floor .

(OLD CASE)

Sl. No	Minimum Standards on fire Prevention and fire safety U/R 33	BBL/NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	Required	Provided	MR
	2) Gate width	5m	Provided	MR
	3)Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	01 no. (Old Case)	01 no. Provided	MR (Old Case)
	2. Basements	01 no. (Old Case)	01 no. Provided	MR (Old Case)
	B. Width of staircase			
	1. Upper floors	1.10m (Old Case)	1.10m	MR (Old Case)
	2. Basements	1m (Old Case)	1m	MR (Old Case)
	C. Protection of exits			
	1. Fire check door	Required	Provided	MR
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	Required	01 nos. provided	MR
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	1m(Old Case)	Provided	MR
3.	Compartmentation			
	1) Fire check door	Required	Provided	MR
	2) Sealing of electrical shafts	Required	Provided	MR
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	30 a/c per hour	Exhaust Fan Provided	MR
	2) Upper floors	12 a/c per hour	Natural Ventilation	MR
5.	Fire Extinguishers			
	1) Total numbers	ISI Marked	10 nos.	MR
	2) Types		ABC, Co2	MR
	3) ISI marking		Yes	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	01no.	Provided	MR
	2) Length of hose reel hose	30m	30m	MR
	3) Nozzle diameter	5mm	5mm	MR

2/19 2016

7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	Smoke/Heat	Smoke Detector Provided	MR
	2) Location of main panel	Ground Floor	Provided	MR
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	Required	Battery Backup Provided	MR
	5) Hooter's Location	Every Floor	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	1) Basement	Required	Provided	MR
	2) Upper floors	Required	Provided	MR
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	150mm	Provided	MR
	2) Number of hydrants per floor	One	Provided	MR
	3) Hose box	One	Provided	MR
12.	Yard Hydrants			
	1) Total number of hydrants	07nos	07nos	MR
	2) Hose box	07nos	07no	MR
13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	450 lpm	Provided	MR
	b) Head of pump	38m	Provided	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	10,000 Ltr	10,000Ltr	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	Required	Provided	MR
	d) Fireman's switch	Required	Provided	MR
	e) Lift signage	Required	Provided	MR
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area			
	Total area location	N/A	N/A	N/A

✓

2/15 12/17

19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A
<p>The fire protection system provided in the building were tested and found functional at the time of inspection. In view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules the FSC issued vide letter No. F6/ DFS/ MS/ 94/Hospital/1068 dated 20/07/1994, renewal under rules 35 of the Delhi Fire Service Rules 2010 is recommended.</p>				

[Handwritten Signature]
7/31/16

Signature of the inspecting officer
Name: - D.B.Mukherjee.
Designation:- A D O (BCP)

DO (Somen)

[Handwritten Signature]
8/31/16