

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**


No. F6/MS/DFS/EH/SZ/2016/ 469

Dated: 28/03/16

FIRE SAFETY CERTIFICATE

Certified that the T.G.I Fridays (U/O M/S Bistro Hospitality Pvt. Ltd.), located at 302-304, 1st Floor, Promenade DLF Place, Vasant Kunj, New Delhi-70 comprised of 2 tier basement, ground & 02 upper floors but the restaurant is running at second floor was granted FSC by this department vide letter no. F6/DFS/MS/EH/2013/171 Dated: 10/04/2013. The premises was re-inspected by the officer concerned of this department on 14/03/2016 in the presence of Mr. Ashwani and observed that the said restaurant have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class Group-D (Restaurant) with effect from 28/03/16.... for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010.

Issued ~~28/03/16~~ at New Delhi by.


(Dr. G. C. Misra)
Chief Fire Officer
Tel: 011-23414333



Copy to:

Mr. Ranjit Kumar Nayak
Bistro Hospitality Pvt. Ltd.
C-32A, 3rd Floor, Nathu Singh Market Masoodpur,
Vasant Kunj, New Delhi-110070

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. The basement shall be used as per the provisions of BBL.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J" [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in

Mly

INSPECTION REPORT

1. Name & address of the building:- T.G.I. Friday's,(Unit of M/s Bistro Hospitality Pvt. Ltd.),302-304,1st Floor,Promenade DLF Vasant Kunj,New Delhi-110070.
2. Type of occupancy:- Group – D Assembly Building
3. Type of case:- Renewal
4. Details of previous NOC:-No. F6/MS/DFS/EH/2010/1591 dated 31/05/10
5. Fire safety directives No.- No
6. Date of inspection:- 29/03/13
7. Name of the inspecting officer:-A.D.O. S.S. Kaushik
8. Name & designation of officer
From the building side:- Mr. Ashwani Kumar
9. Year of construction:- Not known
- 10.Applicant's letter No:-Nil dated 21/03/13 Basement,Ground + 2 upper Floor(restaurant is on 2nd floor only)

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement NBC	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	14 mtr.	Provided	MR
	2) Gate width	N/A	N/A	N/A
	3)Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	2 Nos.	2 Nos.Near Restaurant	MR
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	Yes	150 cms. each	MR
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	Yes	Provided	MR
	2. Pressurization	Yes	Provided	MR
	D. No. of continuous staircase to terrace	2 Nos.	2 Nos.	MR
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	N/A	3 exit provided	MR
3.	Compartmentation			
	1) Fire check door	Yes	Provided	MR
	2) Sealing of electrical shafts	Yes	Provided	MR
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	30 a/c per hour	N/A	N/A
	2) Upper floors	12 a/c per hour	Exhaust fan	N/A
5.	Fire Extinguishers			

Maesky

M/S

	1) Total numbers	ISI Marked	10 Nos.	MR
	2) Types		ABC, Co2 & W.Co2	MR
	3) ISI marking		Yes	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	Yes	2 Nos.	MR
	2) Length of hose reel hose	30 m	Yes	MR
	3) Nozzle diameter	5 mm	Yes	MR
7.	Automatic Fire Detection & Alarming System:- Provided & maintained by mall management			
	1) Type of detectors	----do-----	----do-----	----do-----
	2) Location of main panel	----do-----	----do-----	----do-----
	3) Location of repeater panel	----do-----	----do-----	----do-----
	4) Alternate source of power	----do-----	----do-----	----do-----
	5) Hooter's Location	----do-----	----do-----	----do-----
8.	MOEFA	Yes	Provided	MR
9.	Public Address System	Yes	Provided	MR
10.	Automatic Sprinkler System	Provided & maintained by mall management		
	1) Basement	----do-----	----do-----	----do-----
	2) Upper floors	----do-----	----do-----	----do-----
	3) Sprinkler above false ceiling	----do-----	----do-----	----do-----
11.	Internal Hydrants	:- Provided & maintained by mall management		
	1) Size of riser/down-comer	----do-----	----do-----	----do-----
	2) Number of hydrants per floor	----do-----	----do-----	----do-----
	3) Hose box	----do-----	----do-----	----do-----
12.	Yard Hydrants :- Provided & maintained by mall management			
	1) Total number of hydrants	----do-----	----do-----	----do-----
	2) Hose box	----do-----	----do-----	----do-----
13.	Pumping Arrangement	Provided & maintained by mall management		
	1) Ground level	----do-----	----do-----	----do-----
	a) Discharge of main pump	----do-----	----do-----	----do-----
	b) Head of main pump	----do-----	----do-----	----do-----
	c) Number of main pump	----do-----	----do-----	----do-----
	d) Jockey pump out put	----do-----	----do-----	----do-----
	e) Jockey pump head	----do-----	----do-----	----do-----
	f) Stand by pump output	----do-----	----do-----	----do-----
	g) Stand by pump head	----do-----	----do-----	----do-----
	h) Auto starting/Manual stopping	----do-----	----do-----	----do-----
	2) Terrace level	----do-----	----do-----	----do-----
	a) Discharge of pump	----do-----	----do-----	----do-----
	b) Head of pump	----do-----	----do-----	----do-----
	c) Power supply	----do-----	----do-----	----do-----

Mansingh

	d) Auto starting of pump	----do-----	----do-----	----do-----
14.	Captive Water Storage for Fire Fighting :- Provided & maintained by mall management			
	1) Under ground tank capacity	----do-----	----do-----	----do-----
	a) Draw-off connection	----do-----	----do-----	----do-----
	b) Fire service inlet	----do-----	----do-----	----do-----
	c) Access to tank	----do-----	----do-----	----do-----
	d) Over head tank capacity	----do-----	----do-----	----do-----
15.	Exit Signage.	Yes	Provided	MR
16.	Provision of Lifts.	Provided & maintained by mall management		
	a) Pressurization of lift shaft	----do-----	----do-----	----do-----
	b) Pressurization of lift lobby	----do-----	----do-----	----do-----
	c) Communication in lift car	----do-----	----do-----	----do-----
	d) Fireman's switch	----do-----	----do-----	----do-----

	e) Lift signage	----do-----	----do-----	----do-----
17.	Stand by Power Supply	Yes	Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	Provided & maintained by mall management	N/A	N/A
	a) Detector system panel	----do-----	----do-----	----do-----
	b) Flow switch panel	----do-----	----do-----	----do-----
	c) PA system panel	----do-----	----do-----	----do-----
	d) Battery backup	----do-----	----do-----	----do-----
	e) Building floor plan	----do-----	----do-----	----do-----
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection system provided in the building were checked and found functional at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rules 35 of the Delhi Fire Service Rules 2010/-----

Accordingly DFA is put up please.

Signature of the inspecting officer

Signature of the inspecting officer

Name:- D.P. Bharadwaj.

Name:- S.S. Kaushik

Designation:- Divisional Officer

Designation:- Assistant Divisional Officer.