

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001**

NO. F6/DFS/MS/School/2016/SZ/ 511

Dated: 01/04/16

FIRE SAFETY CERTIFICATE

Certified that the Divine Modern Public School, RZN – 1, H-229, Street no. 9 Raj Nagar-II, Palam Colony New Delhi 110045, comprised of Ground + 2 Upper Floors was granted NOC by this department vide letter No. F6/MS/DFS//2006/2512 Dated 14.09.2006. The school building was re-inspected by the officer concerned of this department on 26.03.2016 in the presence of Smt. Parvati (Headmistress) and found that the premises have deemed complied with the fire prevention and fire safety requirements in accordance with Directorate of Education GNCT of Delhi circular no. Estate/CC/Fire Safety/2011/3298 dated 01.03.2011, and that the school building is fit for occupancy of class B "Educational Building" with effect from 01/04/16 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, subject to compliance of the conditions, printed overleaf.

Issued on 01/04/16 at New Delhi by


(Dr. G C Misra)
Chief Fire Officer
Ph.011-23414333

Copy to:

- 1 Director of Education, SDMC, 23rd Floor Civic Center, Minto Road New Delhi.
- 2 The Headmistress, Divine Modern Public School, RZN – 1, H-229, Street no. 9 Raj Nagar- II, Palam Colony, New Delhi 110045.

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.

INSPECTION REPORT

1	Name & address of the building	Divine Modern Public School, RZN - 1, H 229, Street no.9, Raj Nagar - II Palam Colony New Delhi 110045		
2	Type of Occupancy	Educational Building "B"		
3	Type of case	Renewal		
4	Details of previous NOC	F6/MS/DFS//2006/2512 Dated 14.09.2006		
5	Directives letter no.	Directorate of Edu. Circular. No. 262-363 dated 17.01.2005 & F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01.03.2011.		
6	Date of inspection	26.03.2016		
7	Name of the inspecting Officers :	ADO S.P. Bhardwaj		
8	Name and designation of officers from the building side	Mrs. Parvati (Headmistress)		
9	Year of construction	2006		
10	Applicant's letter No.	DMPS/1/16, dated 18.03.2016	<u>Ground + 2 Upper Floors</u>	

S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement / Circular DOE, dated 17.01.2005 & 01.03.2011	Provided at site	Remarks MR / NMR
1	Access to building			
	1) Road width	Accessible	6 m.	MR ✓
	2) Gate width	Accessible	2.54 & 1.25 m. (Abute on road)	MR ✓
	3) Width of internal road	N/A	N/A.	N/A
2	Number, width Type & arrangement of exits			
	a. Number of staircases			
	1. Upper floors	2 Nos.	2 Nos.	MR ✓
	2. basements	N/A	N/A	N/A
	b. Width of staircase			
	1. Upper floors	1.5 m	1.07 to 118 Cms. & 85 Cms.	MR being Old Case
	2. basements	N/A	N/A	N/A
	c. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	Required	One	MR ✓
	e. Width of corridor	1.01 m.	1.25 to 2.41 m.	MR ✓
	f. Door size	1 m.	1 m.	MR ✓
3	Compartmentation.			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
4	Smoke Management system.			
	basement	N/A	N/A	N/A
	upper floors		N/A	N/A
5	Fire Extinguishers			
	total numbers	2 Nos. each floor	6 Nos.	MR ✓
	Types	Co2,ABC	ABC	MR ✓
	ISI marking	ISI Marked	Provided	MR ✓

6	First-Aid Hose Reels.			
	total numbers on each floor	One	One	MR
	Length of Hose reel hose	30 m.	30 m.	MR
	Nozzle Diameter	5 mm	5 mm	MR
7	Automatic fire detection and alarming system			
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	Provided	N/A
9	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	basement	N/A	N/A	N/A
	upper floors	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	Size of riser/down-corner	N/A	N/A	N/A
	Number of Hydrants per floor	N/A	N/A	N/A
	hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
13	Pumping arrangements			
	1. Ground level			
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	2. Terrace level			
	a. Discharge of pump	220 LPM	220 LPM	MR being Old Case
	b. head of the pump	40 m.	40 m.	MR
	c. Power supply	Required	Provided	MR
	d. Auto starting of pump	Required	Provided	MR
14	Captive water storage for fire fighting			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	N/A
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	2500 Ltrs.	2500 Ltrs.	MR being Old Case
15	Exit Signage.	Required	Provided	MR
16	Provision of lifts.			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A


N/8

17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.	Not Required		
	total area			
	location			
19	Fire control room			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Battery backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any:	ABC		

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view deemed compliance of the minimum standards on fire prevention and fire safety required under the rules, renewal of Fire Safety Certificate issued vide letter no. F6/MS/DFS//2006/2512 Dated 14.09.2006 is recommended, under Rule 37 of the Delhi Fire Service Rules 2010.

Accordingly DFA is put up for approval and signature please.


Signature of the Inspecting Officer

Name S.P. Bhardwaj

Designation ADO (Dwarka)