

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI- 110001

No. F6/DFS/MS/Indl/2016/NP2/523

Dated: 04/04/16

FIRE SAFETY CERTIFICATE

Certified that the Uttam Toyota at Plot no.94,FIE,Patparganj, Delhi-92, owned/occupied by M/s Uttam Toyata, comprising of basement, ground plus one upper floor was granted FSC vide letter no.F6/DFS/MS/Indl./2012/628 dated 24.02.12.The Industrial building was inspected by the officer concerned of this department on 26.03.2016 in the presence of Sh.Kuldeep Singh (DGM) and found that the Industrial building have deemed complied with the fire prevention and fire safety requirements in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 and that the building is fit for occupancy Group "Industrial Building" with effect from ...04/04/16... for a period of three years, subject to conditions printed overleaf.

Issued on .....04/04/16..... at New Delhi by



(Dr.G.C.Misra)  
Chief Fire Officer  
Ph.011-23414333

To,  
M/s Uttam Toyota  
Plot no.94,FIE,Patparganj,  
Delhi-92



### CONDITIONS:

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation,ventilation,structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety certificate can not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. Basement shall be used as per BBL.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. "The owner /occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form'J'[sub rule(1) of rule 37] along with a copy of this certificate,six months prior to its expiry"

1. Name & address of the building : Uttam Toyota. at Plot No. -94, FIE, Patparganj Ind. area, Delhi -92.
2. Building Comprised of : B,G+1 upper floor
3. Type of Occupancy : Industrial Building (Show room)
4. Type of Case : **Renewal**
5. Details of Previous FSC : F.6/DFS/MS/Indl./2012/628 dated 24.02.12
6. Fire Safety directives No : Nil
7. Date of Inspection : 21.03.2016
8. Name of the Inspecting Officer : DO Virendra Singh
9. Name of the designation of Officer  
From the building side : Sh.Kuldeep Singh (DGM)
10. Year of Construction : 1998
11. Applicant's letter No. : Nil dated 10.03.16

	Minimum Standards on fire prevention and fire safety U/R33	Existing/BBL Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	• Road width	12 Mtrs	60 Mtrs.	MR
	• Gate width	4.5Mtrs.	5 Mtrs.	MR
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper Floor	1 no.	1 no.	MR
	• Basement	1 no.	1 no.	MR
	B. Width of Staircases			
	• Upper Floor	1.20 M	1.10 M	❖ MR
	• Basement	1.20 M	1.10 M	❖ MR
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	1 nos.	1 no.	MR
	g. Width of Corridor	N/A	N/A	N/A
	h. Door Size	1.0 M	1.2 M	MR
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	N/A	N/A	N/A
5.	Fire Extinguisher			
	• Total numbers	05 nos.	10 nos.	MR
	• Types	ABC & Co2	ABC & Co2	MR
	• IS marking	ISI marked	ISI marked	MR

∴ Existing Building NOC & FSC already issued on 24.2.12.

6	First-aid-Hose Reels.			
	<ul style="list-style-type: none"> <li>Total numbers of each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	01 no.	01 no.	MR
		30 m	30 m	MR
		5 mm	5 mm	MR
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of main panel</li> <li>Location of repeater panel</li> <li>Alternate source of power</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Hooters's location</li> </ul>	N/A	N/A	N/A
8	MOEFA	N/A	Provided	MR
9	Public address System.	N/A	provided	MR
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> <li>Basement</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>upper floor</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>sprinkler above false ceiling</li> </ul>	N/A	N/A	N/A
11	Internal Hydrants			
	<ul style="list-style-type: none"> <li>size of riser/down-comer</li> </ul>	N/A	100 mm	MR
	<ul style="list-style-type: none"> <li>Number of hydrants per floor</li> </ul>	N/A	1 no.	MR
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	N/A	1 no.	MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	N/A	N/A	N/A
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> <li>Ground Level</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Discharge of main Pump</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Head of Main Pump</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Number of main pumps</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Jockey pump out put</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Jockey pump head</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Standby pump out put</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Standby pump Head</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Auto Starting /Manual stopping</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Pump House Access</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Terrace Level</li> </ul>			
	<ul style="list-style-type: none"> <li>➤ Discharge of pump</li> </ul>	450 LPM	900 LPM	MR
	<ul style="list-style-type: none"> <li>➤ Head of the Pump</li> </ul>	35 Mtrs.	38 mtrs.	MR
	<ul style="list-style-type: none"> <li>➤ Power supply</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Auto Starting of pump</li> </ul>	N/A	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	<ul style="list-style-type: none"> <li>Underground tank capacity</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Draw-off connection</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Fire service inlet</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Access to tank</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Overhead Tank capacity</li> </ul>	5000 Ltrs.	5000 Ltrs.	MR
15	Exit Signage.	Required	Provided	MR

16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	Provided	MR
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules .The NOC issued vide letter no. :F.6/DFS/MS/Indl./2012/628 Dated 24.02.12 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

*Submitted please.*

*Virendra Singh*  
 28/7/16  
 Signature of the Inspecting Officer  
 Name:-Virendra Singh  
 Designation :-DO(ED)

Dy.CFO(NDZ)

