

FORM 'H'  
FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[Refer sub - rule (1) of rule 35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI - 110001


No: F.6/DFS/MS/School/2016/ W2/501

Dated: 01/04/16

**FIRE SAFETY CERTIFICATE**

Certified that the building of **Govt. Sarvodaya Co-ed Vidyalaya (Without Hall)**, located at **H - Block, Karampura, Delhi - 110015** comprised of 1 Block of Ground & 3 Blocks of Ground + 1 Upper Floor only, owned and occupied by **Sarvodaya Co-ed Vidyalaya** have complied with the fire prevention and fire safety requirements in accordance with the Circular No-F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education and verified by the officers concerned of Fire Service on 23-02-2016 in the presence of **Sh. Ajit (Caretaker)** and that the building / premises is fit for the occupancy class "Educational" Group B Sub Division B - 1 with effect from 01/04/16 for a period of three years subject to compliance of the conditions mentioned below:-

Issued on 01/04/16 at New Delhi.

  
(Dr. G.C. Misra)  
Chief Fire Officer,  
Ph.: 011 - 23414333.

Copy to:-

1. The Principal,  
Govt. Sarvodaya Co-ed Vidyalaya,  
H - Block, Karampura, Delhi - 110015.  
Following fire safety directives must be adhered to:-
1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The Hall/ Auditorium shall not be used for any purpose till Fire safety clearance is received from this department.

o/c @  
28/3/16

Re inspection to see the compliance of shortcomings communicated vide letter no. F6/DFS/MS/School/2015/121 dated 15-01-2015. All the shortcomings are found complied.

**INSPECTION REPORT**

1. Name & address of the building: Govt. Sarvodaya Co-ed Vidyalaya, (**Without Hall**), located at H – Block, Karampura, New Delhi – 110015.
2. Type of Occupancy : Educational Total 4, Block ( 3 Block Ground+1, & 1 Block Ground Floor )
3. Type of Case : New ✓
4. Details of previous NOC : Nil
5. Fire Safety directives Letter No. : 3298-3398 dated 01.03.2011
6. Date of inspection : 26-02-2016
7. Name of the Inspecting Officer : Mukesh Verma, ADO (MN)
8. Name and designation of Officer  
from the building side :Mr. Ajit (Caretaker)
9. Year of Construction : 1960, D – Block in 2013
10. Applicant’s letter No. : 862 dated - 04-02-2016

Area of School – 10535 sqm
Covered Area –5568 sqm
Class Rooms –52
Student of School -1002
A, C & D Block=G+I Upper Floor ✓
B Block=Ground Floor only ✓

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL/Cr.No.3298-3398 dt. 01.03.11 Requirements	Provided at site	Remarks MR/NMR
1.	Access of building	✓		
	• Road width	Accessible	Provided	MR
	• Gate width	Accessible	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	(A- Block) - 1	Provided	MR
	• Basements	(C&D Block) - 1		
	b. Width of staircases	NA	NA	NA
	• Upper floors	1.5 mtr	A-Block 2X163cm, C & D Block 145 cm, 154 cm	MR (C & D Block are inter connected) ✓
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA

-N/12-

	d. No of continuous staircase to terrace	1	A-Block -2 C&D Block-1	NA
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	2X1 mtr for class rooms having students more than 45	Provided in all class rooms	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5.	Fire Extinguishers			
	• Total numbers	22 nos.	29 Provided	MR
	• Types	ABC & CO <sub>2</sub>	Provided	MR
	• IS marking	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	NA	Provided	NA
	• Length of hose reel hose	NA	Provided	NA
	• Nozzle diameter	NA	Provided	NA
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down- comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements:			

<ul style="list-style-type: none"> <li>• Ground Level</li> <li>• Discharge of main pump</li> <li>➤ Head of main pump</li> <li>➤ Number of main pumps</li> <li>➤ Jockey pump out put</li> <li>➤ Jockey pump head</li> <li>➤ Standby Pump out put</li> <li>➤ Standby Pump Head</li> <li>➤ Auto Staring/Manual stopping</li> <li>➤ Pump House Access</li> <li>• Terrace level</li> <li>➤ Discharge of pump</li>   <li>➤ Head of the pump</li> <li>➤ Power supply</li> <li>➤ Auto starting of pump</li> </ul>	NA	NA	NA
	NA	NA	NA
	NA	NA	NA
	NA	NA	NA
	NA	NA	NA
	NA	NA	NA
	NA	NA	NA
	NA	NA	NA
	NA	NA	NA
	NR	2X450 lpm Provided but non functional	NR
	NR	40 m Provided	NR
	NR	Provided	NR
NR	Provided	NR	
14. Captive water Storage for fire fighting:			
<ul style="list-style-type: none"> <li>• Under ground tank capacity</li> <li>➤ Draw off connection</li> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> <li>• Overhead Tank capacity</li> </ul>	NA	NA	NA
	NA	NA	NA
	NA	NA	NA
	NA	NA	NA
	NR	10,000 litres Provided	MR
NR	Not Provided	NR	
15. Exit Signage	NR	NR	NR
16. Provision of Lifts			
<ul style="list-style-type: none"> <li>➤ Pressurization of Lift Shaft</li> <li>➤ Pressurization of lift lobby</li> <li>➤ Communication in lift Car</li> <li>➤ Fireman's Grounding Switch</li> <li>➤ Lift Signage</li> </ul>	NA	NA	NA
	NA	NA	NA
	NA	NA	NA
	NA	NA	NA
	NA	NA	NA
17. Standby power supply	NR	NR	NR
18. Refuge Area			
<ul style="list-style-type: none"> <li>➤ Total area</li> <li>➤ Location</li> </ul>	NA	NA	NA
	NA	NA	NA
19. Fire control room			
<ul style="list-style-type: none"> <li>➤ Detector system panel</li> <li>➤ Flow Switch Panel</li> <li>➤ PA System Panel</li> <li>➤ Battery backup</li> <li>➤ Building Floor Plans</li> </ul>	NA	NA	NA
	NA	NA	NA
	NA	NA	NA
	NA	NA	NA
	NA	NA	NA
20. Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

-N/M-

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/issue shortcomings as noted at serial numbers .....

**Note: FSC is recommended for the school building without Hall as requested by the Principal of the school.**

Signature of the Inspecting Officer

Signature of the Inspecting Officer

Name Mukesh Verma

Name

Designation ADO (M/N)

Designation

DO (West)