

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F.6/DFS/MS/school/2016/W2/490

Dated: 31 / 03 / 2016

FIRE SAFETY CERTIFICATE

Certified that **Govt. Sarvodaya Kanya Vidhyalaya, Pooth Kalan, Delhi- 86** comprised of **Three Blocks, Gr. + One upper floor** owned/occupied by **Govt. Sarvodaya Kanya Vidhyalaya** has already been issued fire safety certificate **vide letter no. F.6/DFS/MS/2011/School/608 dated 13/02/2013.** The premises was re-inspected by the officer from this department on dated **08/03/2016** in the presence of **Smt. Raj Kumari (Principal)** all the fire prevention & fire safety arrangements as provided in the premises found in good working condition. The premises have therefore deem complied with the requirements of **Circular No F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011** issued by Director of Education and the building / premise is fit for occupancy of **Group Class B (Educational)** with effect from **31 / 03 / 2016** for a period of **three years**, subject to compliance of the conditions mentioned below:

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on **WWW.dfs.Delhigovt.nic.in**

Issued on 31/3/16 at New Delhi by


(Dr. G.C.Mishra)
Chief Fire Officer
Ph: 011-23414333



Copy to:

1. The Principal, Govt. Sarvodaya Kanya Vidhyalaya, Pooth Kalan, Delhi- 86.
2. The Director of Education, Old Secretariat, Delhi.

INSPECTION REPORT

Previous= Five blk-A,B & D-Gr.+ One
C -block- Gr. Porta cabin, E-blk-Cimant roof shed
Present-Four blk-A,B & D-Gr. + One upper floors &
C -block- Gr. Porta cabin

1. Name & address of the building : Govt. Sarvodaya Kanya Vidhyalaya, Pooth Kalan, Delhi- 86
 2. Type of Occupancy : Educational
 3. Type of Case : Renewal
 4. Details of previous NOC : Letter No. F.6/DFS/MS/2011/School/608 dated 13/02/2013
 5. Fire Safety directives letter No : Dir of Edu. Cir 01/03/2011
 6. Date of inspection : 08/03/2016
 7. Name of the Inspecting Officers : ADO (BW)
 8. Name and designation of officers
from the building side : Smt. Raj Kumari (Principal)
 9. Year of Construction : 1970,1983 & 2008
 10. Applicant's letter No. : SKV/PK/2016/3063 dated 08/02/2016
- Plot Area:20,000 sq mtr Covered Area:3040 sq mtr No. of Students:3278 NO. of Class Rooms:61 and 03 labs

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Dir. Of Edu. Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	Accessible	MR
	• Gate width	Accessible	Accessible	MR
	• Width of internal road	—	—	—
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	—	—	—
	• Upper Floors	Blk-A-01 Blk-B & D-02 each	05	MR
	• Basements	—	—	—
	b. Width of staircases	—	—	—
	• Upper Floors	1.50 mtr each	Blk-A-1.80 mtr Blk-B & D-1.50 mtr each	MR
	• Basements	—	—	—
	c. Protection of exits	—	—	—
	• Fire check door	—	—	—
	• Pressurization	—	—	—
	e. No. of continuous staircases to terrace	—	—	—
	g. Width of Corridor	—	—	—
	h. Door Size	—	—	—
		1.00 mtr	1.00 mtr with Door fitting Double Door	MR

3	Compartmentation.	—	—	—
	• Fire check door	—	—	—
	• Sealing of electrical shafts	—	—	—
	• Fire Rating of shaft door	—	—	—
	• Water Curtain	—	—	—
	• Fire Dampers	—	—	—
4	Smoke Management System.			
	• Basements	30 a/c per hour	—	—
	• Upper floors	12 a/c per hour	—	—
5	Fire Extinguishers			
	• Total numbers	15 ABC/CO2	20 06	MR
	• Types	ISI marked	ABC Co2	MR
	• IS marking		Yes	MR
6	First-Aid Hose Reels.			
	• Total numbers on each floor	30 m 5 mm	—	—
	• Length of hose reel hose		—	—
	• Nozzle diameter		—	—
7	Automatic fire detection and alarming system.			
	• Type of detectors	—	—	—
	• Location of Main Panel	—	—	—
	• Location of Repeater Panel	—	—	—
	• Alternate source of power	—	—	—
	• Hooters' Location	—	—	—
8	MOEFA	—	—	—
9	Public Address System.	—	—	—
10	Automatic Sprinkler System.			
	• Basement	—	—	—
	• Upper Floor	—	—	—
	• Sprinkler above false ceiling	—	—	—
11	Internal Hydrants			
	• Size of riser/down-comer	—	—	—
	• Number of hydrants per floor	—	—	—
	• Hose Box	—	—	—

12	Yard Hydrants.			
	• Total number of hydrants	—	—	—
	• Hose Box	—	—	—
13	Pumping Arrangements.			
	• Ground Level	—	—	—
	➤ Discharge of main Pump	—	—	—
	➤ Head of Main pump	—	—	—
	➤ Number of main pumps	—	—	—
	➤ Jockey Pump out put	—	—	—
	➤ Jockey pump head	—	—	—
	➤ Standby Pump out put	—	—	—
	➤ Standby Pump Head	—	—	—
	➤ Auto Starting/ Manual stopping	—	—	—
	➤ Pump House Access	—	—	—
	• Terrace level	—	—	—
	➤ Discharge of pump	—	—	—
	➤ Head of the pump	—	—	—
	➤ Power Supply	—	—	—
	➤ Auto Starting of pump	—	—	—
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	—	—	—
	➤ Draw-off connection	—	—	—
	➤ Fire service inlet	—	—	—
	➤ Access to tank	—	—	—
	• Overhead Tank capacity	—	—	—
15	Exit Signage.	—	—	—
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	—	—	—
	• Pressurization of Lift lobby	—	—	—
	• Communication In lift Car	—	—	—
	• Fireman's Grounding Switch	—	—	—
	• Lift Signage	—	—	—
17	Standby power supply	—	—	—

N/12

18	Refuge Area.			
	➤ Total Area	—	—	—
	➤ Location	—	—	—
19	Fire Control Room			
	• Detector System Panel	—	—	—
	• Flow Switch Panel	—	—	—
	• PA System Panel	—	—	—
	• Batter backup	—	—	—
	• Building Floor Plans	—	—	—
20	Special Fire Protection Systems for Protection of special Risks, if any:	—	—	—

Note:-General requirements for school as per Director of Education Circular dated...01/03/2011

1. Escape route.....**Clear**.....
2. LPG cylinders in laboratories ...No.....
3. Electric wiring **Conduit & Concealed**.....**MCB****Provided**.....
Electric circuit..... **ELCB... Provided**.....
4. Electric meter board **Not below S/C**
5. Basement use as per BBL 1983..... **N/A**
6. Emergency telephone no. board.....**Displayed**.....
7. Generator set.....**No**.....

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F.6/DFS/MS/2011/School/608 dated 13/02/2013. Renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended

Signature of the Inspecting Officer

Signature of the Inspecting Officer

Name

Name

Designation

Designation

DO (N/12)
Rajesh
11/3/16

11/3/16
APO (B/12)

11/3/16