

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**  
Fax: 23412593 E-mail: [cfohq.dlfire@nic.in](mailto:cfohq.dlfire@nic.in), Tel:- 011-23414333

NO.F6/DFS/MS/Ind./2016/ SZ/ 533

Dated: 07/04/16

**FIRE SAFETY CERTIFICATE**

Certified that M/s Atex Overseas Pvt. Limited, Plot No. D-185, Okhla Industrial Area, Phase-1, New Delhi comprised of two tier basements, ground plus two upper floors owned/occupied by M/s Atex Overseas Pvt. Limited have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officers concerned of Fire Service on 18-03-2016 in the presence of Mr. Chiripal and that the building/premises is fit for occupancy class Industrial with effect from 07/04/16 for a period of 03 (three) years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 07/04/16 at New Delhi by

  
(Dr. G.C. MISRA)  
Chief Fire Officer

Copy to: -

1. The Authorised Signatory, M/s Atex Overseas Pvt. Limited, Plot No. D-185, Okhla Industrial Area, Phase-1, New Delhi
2. The Executive Engineer (Bldg.)-I, SDMC, 8<sup>th</sup> floor, Civic Centre, Minto Road, New Delhi-110002.

**Conditions for the validity of fire safety certificate**

- a. All the fire safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities rendering non-functional shall be the responsibility of the management.
- b. Building Sanctioning authority may verify any deviation with regard to the construction / occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
- c. The staffs shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
- d. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on website [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

### INSPECTION REPORT

1. Name & address of the building: M/s Atex Overseas Pvt. Ltd., D-185, Okhla Industrial Area, Phase-I, New Delhi-110020
2. Type of Occupancy : Industrial
3. Type of Case : New Case
4. Details of previous NOC : N/A
5. Fire Safety directives letter No : F.6/DFS/MS/BP/2013/292 dated 20.09.2013.
6. Date of inspection : 18.03.2016
7. Name of the Inspecting Officers : Dharampal Bhardwaj, DO(SZ), M.K. Chattopadhyay, ADO (M. Road)
8. Name and designation of officers from the building side : Mr. Chiripal
9. Year of Construction : 2012-13
10. Applicant's letter No. : nil dated 02.03.2016

The building is comprised of 02 tier basements, ground plus two upper floors.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	06 mts	Provided	MR
	• Gate width	4.5 mts	Provided	MR
	• Width of internal road	Required	Provided	MR
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	-	-	-
	• Upper Floors	02	02	MR
	• Basements	02	02	MR
	b. Width of staircases	-	-	-
	• Upper Floors	1.50 mts each	Provided (1.5 mts)	MR
	• Basements	1.50 mts each	Provided (1.5 mts)	MR
	c. Protection of exits	-	-	-
	• Fire check door	Required	Provided	MR
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	02	02	MR
	g. Width of Corridor	1.50 mts	Provided	MR
	h. Door Size	1.50 mts	Provided	MR
3	<b>Compartmentation.</b>			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A



	<ul style="list-style-type: none"> <li>• Fire Dampers</li> </ul>	N/A	N/A	N/A
4	<b>Smoke Management System.</b>			
	<ul style="list-style-type: none"> <li>• Basements</li> </ul>	30 a/c per hour	Provided	MR
	<ul style="list-style-type: none"> <li>• Upper floors</li> </ul>	12 a/c per hour	N/A	N/A
5	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>• Total numbers</li> </ul>	16	Provided	MR
	<ul style="list-style-type: none"> <li>• Types</li> </ul>	ABC , CO <sub>2</sub> type	Provided	MR
	<ul style="list-style-type: none"> <li>• IS marking</li> </ul>	ISI marked	Provided	MR
6	<b>First-Aid Hose Reels.</b>			
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> </ul>	01	Provided	MR
	<ul style="list-style-type: none"> <li>• Length of hose reel hose</li> </ul>	30 m	Provided	MR
	<ul style="list-style-type: none"> <li>• Nozzle diameter</li> </ul>	5 mm	Provided	MR
7	<b>Automatic fire detection and alarming system.</b>			
	<ul style="list-style-type: none"> <li>• Type of detectors</li> </ul>	Required	Provided (smoke, heat)	MR
	<ul style="list-style-type: none"> <li>• Location of Main Panel</li> </ul>	Required at GF	Provided	MR
	<ul style="list-style-type: none"> <li>• Location of Repeater Panel</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>• Alternate source of power</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>• Hooters' Location</li> </ul>	Required	Provided	MR
8	<b>MOEFA</b>	Required	Provided	MR
9	<b>Public Address System.</b>	N/A	N/A	N/A
10	<b>Automatic Sprinkler System.</b>			
	<ul style="list-style-type: none"> <li>• Basement</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>• Upper Floor</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>• Sprinkler above false ceiling</li> </ul>	N/A	N/A	N/A
11	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>• Size of riser/down-comer</li> </ul>	100 mm	Provided	MR
	<ul style="list-style-type: none"> <li>• Number of hydrants per floor</li> </ul>	Required	Provided (1 nos.)	MR
	<ul style="list-style-type: none"> <li>• Hose Box</li> </ul>	Required	Provided (1 nos.)	MR
12	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>• Total number of hydrants</li> </ul>	Required	Provided (3 nos.)	MR
	<ul style="list-style-type: none"> <li>• Hose Box</li> </ul>	Required	Provided (3 nos.)	MR
13	<b>Pumping Arrangements.</b>			
	<ul style="list-style-type: none"> <li>• Ground Level</li> </ul>	----	----	----
	<ul style="list-style-type: none"> <li>➤ Discharge of main Pump</li> </ul>	2280 & 2850 LPM	Provided	MR





	➤ Head of Main pump	60 mts	Provided	MR
	➤ Number of main pumps	02	Provided	MR
	➤ Jockey Pump out put	180, 280 LPM	Provided	MR
	➤ Jockey pump head	60 mts	Provided	MR
	➤ Standby Pump out put	2280 LPM	Provided	MR
	➤ Standby Pump Head	60 mts	Provided	MR
	➤ Auto Starting/ Manual stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace level	-	-	-
	➤ Discharge of pump	900 LPM	Provided	MR
	➤ Head of the pump	40 mts	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	<b>Captive Water Storage for fire fighting.</b>			
	• Underground tank capacity	1,00,000 lts	Provided	MR
	➤ Draw-off connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	20, 000 lts	Provided	MR
15	<b>Exit Signage.</b>	Required	Provided	MR
16	<b>Provision of Lifts.</b>			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	Required	Provided	MR
	• Fireman's Grounding Switch	Required	Provided	MR
	• Lift Signage	Required	Provided	MR
17	<b>Standby power supply</b>	Required	Provided	MR
18	<b>Refuge Area.</b>			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	<b>Fire Control Room</b>			
	• Detector System Panel	Required	Provided	MR
	• Flow Switch Panel	Required	Provided	MR
	• PA System Panel	N/A	N/A	N/A

	<ul style="list-style-type: none"> <li>Batter backup</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Building Floor Plans</li> </ul>	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any	Required	Provided 02 ABC type fire extinguishers near elect. Panel	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection. *All the Shortcomings have been rectified by the management.*

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to renew Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

  
 21/8/16  
 DHARMPAL BHARDWAJ  
 Divisional Officer (SZ)

  
 19/8/2016  
 M.K.CHATTOPADHYAY  
 Asstt. Div. Officer (M. Road)