

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI


No. F6/DFS/MS/EH/2016/W2/484

Dated: 01/04/16

FIRE SAFETY CERTIFICATE

Certified that the **Essence** at A-13, Vishal Enclave, Rajouri Garden, Najafgarh Road, Delhi, comprised of Basement, Ground Floor & Three Upper Floors was Granted Fire Safety Certificate by this department vide letter No. F6/DFS/MS/EH/2012/1854 dated 22/05/2012. The premises was re-inspected by the officers concerned of this department on 21/03/2016 in the presence of Manager of the Restaurant and found that the building have deemed complied with the Fire prevention and Fire Safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010. Hence the Fire Safety Certificate is renewed and premises is fit for occupancy class "Assembly" (Group D) with effect from 01/04/16 for a period of three years subject to conditions printed overleaf.

Issued on 01/04/16 at New Delhi by.


Dr. G.C. Misra
Chief Fire Officer
Delhi Fire Service
Tele. No. - 23414333

Copy to :-

1. Manager, 13 West Restaurant & Bar, A-13, Vishal Enclave, Rajouri Garden, Najafgarh Road, Delhi.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1), of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

INSPECTION REPORT

N-13

1. Name & address of the building: **Essence, A-13, Vishal Enclave, Rajouri Garden, Najafgarh Road, Delhi.**
2. Type of Occupancy : Class-D (Assembly)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/EH/2012/1854 dated 22/05/2012
5. Fire Safety directives Letter No. : F-6/DFS/MS/EH/08/1204 dated 24/04/08
6. Date of inspection : 21/03/2016
7. Name of the Inspecting Officer : Sunil Chawdhary (D.O. West)
8. Name and designation of Officer
from the building side : Manager
9. Year of Construction :
10. Applicant's letter No. : -Nil

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 mtr	40 mtr approx.	MR
	• Gate width	NR	NR	NR
	• Width of internal road	NR	NR	NR
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	2	MR
	• Basements	2	2	MR
	b. Width of staircases			
	• Upper floors	Old Case	70 cm Approx.	Old Case MR
	• Basements	Old Case	70 cm Approx.	Old Case MR
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	Required	Provided	MR
	d. No of continuous staircase to terrace	02	02	MR
	e. Width Of Corridor	Halls only	Halls only	MR
	f. Door Size	2.00mtr	Provided	MR
3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	NR	NR	NR
	• Fire Rating of shaft door	NR	NR	NR
	• Water Curtain	NR	NR	NR
	• Fire Dampers	NR	NR	NR
4.	Smoke managements System			
	• Basements	Required	Exhaust Fan Provided	MR
	• Upper floors	Required	Natural Ventilation	MR
5.	Fire Extinguishers			
	• Total numbers	16	18	MR


N-14

6.	First - Aid Hose Reels			
	• Total numbers on each floor	1	Provided	MR
	• Length of hose reel hose	30Mtr.	Provided	MR
	• Nozzle diameter	5mm.	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detector	NR	Provided	MR
	• Location of Main Panel	Ground Floor	Provided	MR
	• Location of Repeater	Each Floor	Provided	NR
	• Panel	Required	Provided	NR
	• Alternate source of power	Required	Provided	NR
	• Hooters' Location	Required	Provided	NR
8.	MOEFA	Required	Provided	NR
9.	Public Address System	Required	Provided	NR
10.	Automatic Sprinkler System			
	• Basements	Required	Provided	NR
	• Upper Floor	NR	NR	NR
	• Sprinkler above false ceiling	NR	NR	NR
11.	Internal Hydrants			
	• Size of riser/down-comer	100 mm	Provided	MR
	• Number of hydrants per floor	1	Provided	MR
	• Hose Box	1	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	NR	NR	NR
	• Hose Box	NR	NR	NR
13.	Pumping Arrangements			
	• Ground Level			
	• Discharge of main pump	NR	NR	NR
	➤ Head of main pump	NR	NR	NR
	➤ Number of main pumps	NR	NR	NR
	➤ Jockey pump out put	180 LPM	Provided	MR
	➤ Jockey pump head	70 mtr	Provided	MR
	➤ Standby Pump out put	NR	NR	NR
	➤ Standby Pump Head	NR	NR	NR
	➤ Auto Starting/Manual stopping	NR	NR	NR
	➤ Pump House Access	NR	NR	NR
	• Terrace level			
	➤ Discharge of pump	900 LPM	Provided	MR
	➤ Head of the pump	70 mtr	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	NR
14.	Captive water Storage for fire fighting			
	• Underground tank capacity	NR	NR	NR
	➤ Draw of connection	Required	Provided	M/R
	➤ Fire service inlet	Required	Provided	M/R
	➤ Access to tank	Required	Provided	NR

15	Exit Signage	Required	Provided	M/R
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	Required	Provided	NR
	➤ Fireman's Grounding Switch	Required	Provided	NR
	➤ Lift Signage	Required	Provided	NR
17.	Standby power supply	NR	Provided	MR
18.	Refuge Area	NR	NR	
	➤ Total area	NR	NR	NR
	➤ Location	NR	NR	NR
19.	Fire control room			
	➤ Detector system panel	Required	Provided	NR
	➤ Flow Switch Panel	Required	Provided	NR
	➤ PA System Panel	Required	Provided	NR
	➤ Battery backup	Required	Provided	NR
	➤ Building Floor Plans	Required	Provided	NR
20.	Special Fire Protection Systems for Protection of special Risks, if any;	Required	Provided	NR

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection. MCB and Conduit Metal Wiring has also been provided.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. F6/DFS/MS/EH/2012/1854 dated 22/05/2012 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.


28/3

Signature of the Inspecting Officer

Name : Sunil Chawdhary

Designation : D.O. (West)