

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.

No.F.6/DFS/MS/School/2016/ 52/554

Dated: 08/04/16

FIRE SAFETY CERTIFICATE

Certified that the building of **Salwan Montessori School** located at Rajendra Nagar, New Delhi-110060 is comprised of ground floor plus one upper floor was issued NOC by this department vide letter No.F.6/DFS/MS/2010/1482 dated 20.05.2010. The School building was re- inspected by the officers concerned of this department on 29.03.2016 in the presence of Sh. Madan Mohan (School Engg.) and found that the school management have deemed complied with the fire prevention and fire safety requirements in accordance with the Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education and that the building/ premises is fit for occupancy class "Educational" w.e.f. the date of issue of this certificate for a period of three years, subject to compliance of the conditions printed overleaf.

Issued on.....08/04/16.....at New Delhi.



DIRECTOR
DELHI FIRE SERVICE

O/C San
06/4/16

Copy to:-

1. The Principal,
Salwan Montessori School,
Rajendra Nagar, New Delhi-110060.
2. Director of Education,
Govt. of NCT of Delhi, Old Secretariat,
New Delhi - 110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner/ occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

w/2
Ground Floor plus One upper floor (Block A)

INSPECTION REPORT

1. Name & address of the building : Salwan Montessori School, Rajinder Nagar,
2. Type of Occupancy : Educational (School) N.D-60
3. Type of Case : New Case/Renewal
4. Details of Previous NOC : Letter No. F.G/DFS/MS/2010/1482 Date 20.05.2010
5. Fire Safety directives letter No : -
6. Date of inspection : 29.03.2016
7. Name of Inspecting Officer : A.O S.K. Tomar & A.D.O Sandeep Duggal
8. Name and designation of officers
From the building side : Sh. Madan Mohan (School Engg.)
9. Year of Construction : Before 2010
10. Applicant's letter No. : SMS/8135/2015-2016 dated 08.03.2016

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Dist. 7 Education Cls Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	Accessible	08 mtr	MR ✓
	• Gate width	-	390cms (02Nos)	-
	• Width of internal road	NA	NA	NA
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	One	Two	MR ✓
	• Basements	-	-	No Basement
	b. Width of staircases			
	• Upper Floor	150cms	150cms (02Nos)	MR
	• Basements	-	-	No Basement
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace			
		NA	NA	NA
	e. Width of Corridor	150 cms	165 cms	MR ✓
	f. Door Size	100 cms	117 cms (02Nos)	MR ✓
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke Management System			
	• Basements	30 a/c per hour	-	No Basement
	• Upper floors		Natural Ventilation	MR ✓

Saw

A/3

		12 a/c per hour	-	-
5.	Fire Extinguishers			
	• Total numbers	05 Nos	Provided	MR
	• Types	ABC, CO ₂	- do -	MR
	• IS marking	ISI marked	ISI Marked	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	NA	Provided	NA
	• Length of hose reel hose	30 m	- do -	NA
	• Nozzle diameter	5 mm	- do -	NA
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	Provided	NA
9.	Public Address System	NA	- do -	NA
10.	Automatic Sprinkler System			
	• Basement	-	-	No Basement
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	• Size of riser/down-comer	NA	100mm	NA
	• Number of hydrants per floor	NA	Two	NA
	• Hose Box	NA	- do -	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/Manual stopping	NA	NA	NA

CAV

	<ul style="list-style-type: none"> ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	NA	NA	NA
		NA	420LPM, 180LPM	NA
		NA	46M Each	NA
		NA	Provided	NA
		NA	NA	NA
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	NA	NA	NA
		NA	NA	NA
		NA	Provided	NA
		NA	NA	NA
		NA	5000 Ltr	NA
15.	Exit Signage.	NA	NA	NA
16.	Provision of Lifts:			(No Lift)
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	NA	NA	NA
		NA	NA	NA
19.	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
20.	Special Fire Protection System for Protection of special Risks, if any:	NA	NA	-NA

N/S

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F.G/DFS/MS/2010/1482 dated 20.05.2010 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

S.K. Tomar
30/3/16

Signature of Inspecting Officer

Name S.K. Tomar

Designation Divisional Officer

Sandeep
29/3/16

Signature of Inspecting Officer

Name Sandeep Duggal

Designation Asstt. Divisional Officer