

c/30

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No: F-6/DFS/MS / PFW/2016/W2/ 529

Dated: 04/04/16

FIRE SAFETY CERTIFICATE

Certified that **Sh. Ashok Kumar Aggarwal** Located at **Shop no 2, Shahzada Bagh, Delhi** in a building comprised of Ground Floors owned/ occupied by **Sh. Ashok Kumar Aggarwal** have complied with the guidelines issued by Delhi Police under Delhi Police Act and verified by the officer concerned of this department on 08-03-2016 in the presence of **Sh. Ashok Kumar Aggarwal** and the building/ premises is fit for occupancy Class Group F Mercantile Building Sub Division F – 1 w.e.f. date of issue of this certificate for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of Delhi Fire Service Rules, 2010.

Issued on 04/04/16 at New Delhi.



(G.C. Mishra)
Chief Fire Officer
Delhi Fire Service.

Following fire safety directives must be adhered to:

1. All the means of escape/ entry/ exit shall be kept free from any obstruction.
2. All the fire protection measures shall be maintained in perfect working conditions all the times as seen during inspection.
3. All the staff members must know the correct method operation of firefighting system.
4. Any lapse rendering firefighting system/ equipment nonfunctional shall be risk and responsibility of the management.
5. This inspection report may not in any way be treated as regularization of unauthorized construction, if any.
6. The NOC is for fireworks only.

Copy to:


1. The Addl. Commissioner of Police (Lic.),
1st Floor, P.S. Defence Colony, New Delhi.
(Ref. No. (PFW/23)/2016/2389-91/Addl.CP/Lic.(Expl.), dated 23-02-2016
- 2 Sh. Ashok Kumar Aggarwal s/o Late Sh. Chaman Lal, B-1447 Shastri Nagar, Delhi

19/11
INSPECTION PERFORMA (PART - B)
(TO BE FILLED IN TRIPLICATE BY THE INSPECTING OFFICER)

DATE:

TIME:

S.NO.	POINT OF INSPECTION	NORM AS PER GUIDELINES/ VR COMMITTEE REPORT	REMARKS OF THE INSPECTING OFFICER
1.	Type of construction and floor area and floor level	<ol style="list-style-type: none"> 1. Minimum floor area 9 m² 2. Pucca construction 3. Premises not under staircase/ means of exit 4. Business permissible only at ground floor 5. Business from pavement of road prohibited 	Provided Provided Provided Ground Floor Only Prohibited
2.	Entrance & exit to the licensed premises	The licensed premises shall have independent entrance and exit	Provided
3.	Type and distance of surrounding risk	The premises shall be situated at a distance of 15m from any such premises used for similar exclusive/ inflammable or hazardous materials	Provided
4.	Nature of business run in the licensed premises	The premises in which fire works are kept shall be used only for possession and sale of fire works and no other purpose	No other business allowed
5.	Type of Electrical wiring and electrical fittings	<ol style="list-style-type: none"> 1. Preferably concealed or through conduit 2. The electrical fittings should be flame/ spark proof 	Provided Provided
6.	Extension of shop for business	prohibited	Prohibited
7.	Approach road	The road width on the sides of which premises is located should be 12m	Provided
8.	Fire Protection arrangements <ol style="list-style-type: none"> 1. Extinguishers (type & no.) 2. Sand/ Water buckets 3. Water Drum 	<ol style="list-style-type: none"> 1. All the extinguishers shall have ISI mark 2. No. of fire extinguishers & type shall be in accordance with the risk & area of the premises 3. Minimum 2 buckets each of sand & water shall be provided 	Provided 4 nos. (2 ABC 5kg, 2 CO2 4.5 Kg) Provided
9.	Any other point that is contrary to the safety of people	NIL	NIL


 Signature of Inspecting Officer
 Designation;- Asst. Div. Officer/Waz Pur

GRANT OF NOC FOR SALE/ STORAGE OF FIRE WORKS

(In areas other than walled city and congested areas)

INSPECTION REPORT (PART - A)

(To be filled by the Inspecting Officer)

1. Name and Address of the licensee: Sh. Ashok Kumar Aggarwal s/o Late Sh. Chaman Lal, B-1447 Shastri Nagar, Delhi
2. Address of the licensed premises: Shop no 2, Shahzada Bagh, Delhi
3. License No. and validity period: New
4. Authority by which license was issued last: New
5. Name and Designation of the Inspecting Officer: Sh. Udai vir singh ADO (WP)
6. Date and time of inspection: 16/03/2016
7. Period for which license is to be renewed and the authorized quantity: 1500 kg (300 kg fireworks + 1200 kg Chinese/ Sparkles)
8. Recommendations of the inspecting officer for issue/ rejection of NOC with reasons: Recommended



Remarks of DO

Remarks of DCFO

Remarks of CFO

*NOC is issued subject to the condition that status quo shall be maintained and the conditions laid down under Indian Explosives Rules 1983/ conditions laid down by MCD/ Police are complied with.

Dated:

[Signature]
17/3/16
ADO/WP
(Signature of Inspecting Officer)
Designation

Issue NOC/ Reject

[Signature]

Chief Fire Officer,
Delhi Fire Service.

739/Def/W2
28/3/16