

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110 001.

No.F.6/DFS/MS/School/2016/SZ | 537

Dated: 07/04/16

FIRE SAFETY CERTIFICATE

Certified that the building of Meena Public School, Q-52, Vikas Vihar, Uttam Nagar, New Delhi-110059, is comprised of ground plus two upper floors but school is running at ground plus one upper floor. The school is owned/occupied by the school management was inspected by the officer concernec. of this department on 23.3.2016 in the presence of Sh. V.D Kinger (Chairman) and found that the school management have complied with the fire prevention and fire safety requirements in accordance with the Circular No. F.16/Estate/CC/Fire Safety/2011/298 to 3398 dated 01.03.2011 issued by the Director of Education and that the school building/ premises **(Ground plus one upper floor)** is fit for occupancy class "Educational" w.e.f. the date of issue of this certificate for a period of three years, subject to compliance of the conditions printed as under.

Issued on.....07/04/16.....at New Delhi.

  
DIRECTOR  
DELHI FIRE SERVICE

Copy to:-

1. The Principal,  
Meena Public School, Q-52, Vikas Vihar,  
Uttam Nagar, New Delhi-59.
2. Director of Education,  
Govt. of NCT of Delhi, Old Secretariat,  
New Delhi - 110054.

ACCAD  
07/04/16

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

N)

Ground plus two upper floors but school is running at ground plus one upper floor.  
(Meena Public School, Q-52, Vikas Vihar, Uttam Nagar, New Delhi-110059)

### INSPECTION REPORT

1. Name & address of the building : Meena Public School, Q-52, Vikas Vihar, Uttam Nagar, New Delhi-59
2. Type of Occupancy : Educational
3. Type of Case : New
4. Details of Previous NOC : N/A (shortcoming given vide letter no. F6/MS/DFS/06/2452 dated 11.09.2006)
5. Fire Safety directives letter No : N/A
6. Date of inspection : 23.3.2016
7. Name of Inspecting Officer : A.D.O. Sandeep Duggal
8. Name and designation of officers  
From the building side : Sh. V.D Kinger (Chairman)
9. Year of Construction : 1992
10. Applicant's letter No. : MPS/No.FireSafety/2016 dated 16.3.2016

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Dt. of education Requirement	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	Accessible	05 mtrs  1.5 mtrs	M/R (06 mtrs. road is one length hose away)  — —
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	<ul style="list-style-type: none"> <li>• Upper Floors</li> <li>• Basements</li> </ul>	01 No.	02 No's	M/R ✓
	b. Width of staircases			
	<ul style="list-style-type: none"> <li>• Upper Floor</li> <li>• Basements</li> </ul>	—	78 cms & 90 cms	M/R ✓
	c. Protection of exits			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Pressurization</li> </ul>	N/A	N/A	No basement
	d. No. of continuous staircases to terrace			
	e. Width of Corridor			
	f. Door Size			
		N/A	N/A	N/A
		N/A	N/A	N/A
		—	65 & 200 cms	—
		—	90 cms	M/R, students are less than 45 in each class room
3.	<b>Compartmentation</b>			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
4.	<b>Smoke Management System</b>			

San

Ground plus two upper floors but school is running at ground plus one upper floor.  
(Meena Public School, Q-52, Vikas Vihar, Uttam Nagar, New Delhi-110059)

	<ul style="list-style-type: none"> <li>Basement</li> </ul>	N/A	N/A	No basement
	<ul style="list-style-type: none"> <li>Upper floors</li> </ul>	—	Natural ventilation	M/R ✓
<b>5.</b>	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>IS marking</li> </ul>	06 no's ABC/CO2 type	Provided	M/R ✓
			Provided	M/R ✓
		ISI marked	ISI marked	M/R ✓
<b>6.</b>	<b>First-Aid Hose Reels</b>			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
<b>7.</b>	<b>Automatic fire detection and alarming system</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
<b>8.</b>	<b>MOEFA</b>	N/A	N/A	N/A
<b>9.</b>	<b>Public Address System</b>	N/A	Provided	N/A
<b>10.</b>	<b>Automatic Sprinkler System</b>			
	<ul style="list-style-type: none"> <li>Basement</li> <li>Ground Floor</li> <li>Sprinkler above false ceiling</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
<b>11.</b>	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
<b>12.</b>	<b>Yard Hydrants</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
<b>13.</b>	<b>Pumping Arrangements</b>			
	<ul style="list-style-type: none"> <li>Ground Level <ul style="list-style-type: none"> <li>Discharge of main Pump</li> <li>Head of Main pump</li> <li>Number of main pumps</li> <li>Jockey Pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> </ul> </li> </ul>			
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A

Sau

23/4

Ground plus two upper floors but school is running at ground plus one upper floor.  
(Meena Public School, Q-52, Vikas Vihar, Uttam Nagar, New Delhi-110059)

	➤ Auto Starting/Manual Stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	N/A	180 LPM	N/A
	➤ Head of the pump	N/A	Provided	N/A
	➤ Power Supply	N/A	N/A	N/A
	➤ Auto Starting of pump	N/A	N/A	N/A
<b>14.</b>	<b>Captive Water Storage for fire fighting</b>			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	N/A	2000 ltrs Provided	N/A
<b>15.</b>	<b>Exit Signage.</b>	N/A	N/A	N/A
<b>16.</b>	<b>Provision of Lifts. (No Lift)</b>			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
<b>17.</b>	<b>Standby power supply</b>	N/A	N/A	N/A
<b>18.</b>	<b>Refuge Area.</b>			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
<b>19.</b>	<b>Fire Control Room</b>			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
<b>20.</b>	<b>Special Fire Protection System for Protection of special Risks, if any:</b>	N/A	N/A	N/A

San

Ground plus two upper floors but school is running at ground plus one upper floor.  
(Meena Public School, Q-52, Vikas Vihar, Uttam Nagar, New Delhi-110059)

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the above substantial compliance of the minimum standards of fire prevention and fire safety measures as required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

Note:- The school building is in a Gali having width 05 mtrs. & it is 30 meters (i.e. one length of hose) away from the road having width 06 mtrs, which is approachable to fire fighting vehicles. The premises is comprised of ground plus two upper floors but school is running at ground plus one upper floor, there are less than 45 students in each class room and the School is running since 1992 as per the letter submitted by Manager of the school (placed at C-13).

  
Signature of Inspecting Officer

Name:- Sandeep Duggal

Designation:- Asstt. Divisional Officer

  
Signature of Inspecting Officer

Name

Designation

D.O. (South West)



  
K. Kumar  
28/3/16