

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110 001

No. F6/DFS/MS/FW/2016/52/588

Dated: 18/04/16

FIRE SAFETY CERTIFICATE

Certified that M/S Kirti Prakash Gautam Fire Works, located at Shop No. 49A/1, Mohammad Pur, New Delhi-110066 wants to run the trade of sale and possession of Fire Works at ground floor of the building comprised of ground floor only, owned / occupied by Sh. Kirti Prakash Gautam have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officers concerned of Fire Service on 15.03.2016 in the presence of Sh. Kirti Prakash, Owner and that the shop is fit for occupancy class Fireworks Storage with effect from 18/04/2016 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 18/04/2016 at New Delhi by.


(Atul Garg)

Dy. Chief Fire Officer

T.No.011-26189168

Copy to:- 1. Joint. Commissioner of Police (Lic.), First Floor, P.S. Defence Colony New Delhi-49.
2. M/S Kirti Prakash Gautam Fire Works, Shop No. 49A/1, Mohammad Pur, New Delhi-110066.

Conditions for the validity of fire safety certificate are as under:-

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. The employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All fire fighting equipments shall be maintained in perfect working condition all time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate, six month prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : M/S Kirti Prakash Gautam Fire Works, Shop No. 49A/1, Mohammad Pur, New Delhi-110066.
2. Type of Occupancy : Storage and sale of Fireworks.
3. Type of Case : New Case
4. Details of Previous NOC : Nil.
5. Fire Safety direction letter No : NIL.
6. Date of Inspection : 15.03.16
7. Name of the Inspecting Officers: : Vedpal (ADO)
8. Name and designation of Officer from the building side : Mr. Kirti Prakash Gautam (Owner).
9. Year of Construction : 1999
10. Applicant's letter No : No.(PFW/20)/2016/2385-87/Joint C.P/Lic (Expl), dated 23.02.16.

S.No	Point of Inspection	Requirement	Provided at Site	Remarks MR/NMR
1	Type of construction and floor area & floor level			
	a. Minimum floor area	9m2	9 m2	MR
	b. Construction	Pucca	Provided	MR
	c. Premises Location	Not under the staircase / Mean of escape	Provided	MR
	d. Business permissible only at ground floor	Required	Provided	MR.
	e. Business from pavement of road prohibited	Prohibited	Yes	MR
2	Entrance & Exits to the licensed premises			
	The licensed premises shall have independent entrance and exit.	Required	Provided (Yes)	MR
3	Type and distance of the surrounding risk			
	The premises shall be situated at a distance of 15 m from any such premises used for similar explosives / inflammable or hazardous materials.	Required 15 m	Provided	MR
4.	Nature of business run in the licensed premises			
	The premises in which fireworks are kept shall be used only for possessing and sale for fireworks and no other purposes.	Required	Provided (Yes)	MR
5.	Type of electrical wiring and electrical fittings.			
	a. Preferably concealed or through conduit	Required	Provided	MR
	b. All electrical fitting should be flame / spark proof	Required	Provided with casing & capping	MR

Dey

N/4

M/S Kirti Prakash Gautam Fire Works, Shop No. 49A/1, Mohammad Pur, New Delhi-110066.

6.	Extension of shop for business			
	Prohibited	Prohibited	Yes	MR
7.	Approach road			
	The road width on the side of which premises is located should be 12 m.	12 m	12 m	MR
8.	Fire protection arrangement.			
	a. Extinguishers (Type & No's.)	02 no. water type & 1no. of ABC / Co2 Type	Provided	MR
	b. Sand and Water Buckets	2 nos.	Provided	MR
	c. Water Drum (s)	1 no.	Provided	MR
9.	Any other point that is contrary to the safety of people. The premises is more than 3.66 meters away vertically from HT Line and more than 1.83 meters away horizontally from the same.			MR

Keeping in view the substantial non compliance of the minimum standards on fire prevention and fire safety required under rules, it is recommended to issue shortcomings as noted at serial number 4. Reply letter on same lines is put up for kind consideration please.


 8/4/16

Signature of the Inspecting Officer

Name Vedpal

Designation ADO

Divisional Officer (South)

 11/4/16