

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001**

No F 6 / DFS / MS / 2016 / *School/w2/583*

Dated: *13/04/2016*

**FIRE SAFETY CERTIFICATE**

Certified that M.C. Pry. School, Sector-5A, Rohini, Delhi comprised of two blocks of Ground floor and ground plus 01 upper floor was granted FSC by this department vide letter no. No.F6/DFS/MS/2013/SCHOOL/277 dated 17.01.2013. The premises was re-inspected by the officer concerned of this department on 11.03.2016 in presence of Mrs Jyotsna, Principal and observed that all the fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education vide letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy class Group B Educational with effect from ~~13/04/16~~ for a period of three years, subject to compliance of the conditions mentioned below:

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [WWW.dfs.Delhigovt.nic.in](http://WWW.dfs.Delhigovt.nic.in)

Issued on ...*13/04/16*..... at New Delhi

  
(Dr G C Misra)  
Director

Ph:-011-23414000  
*ohk*

Copy to :-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 54
2. The Principal M.C.Pry.School, Sec-5A, Rohini. Delhi-110085.

N/7

**INSPECTION REPORT**

- 1. Name & address of the building : M.C.Primary School, Sec-5A, Rohini, Delhi-85.  
Type of Occupancy : Educational (02 blocks--Ground Floor & G+1 Floor only ) ✓
  - 2. Type of Case : Renewal ✓
  - 3. Details of previous NOC : F6/DFS/MS/2012/School/277 dated 17-01-2013
  - 4. Fire Safety directives letter No : Director of Education Letter dated 01.03.2011.
  - 5. Date of inspection : 11/03/2016
  - 6. Name of the Inspecting Officers : Rajesh Kumar, ADO (RN)
  - 7. Name and designation of officers from the building side : Smt.Jyotsna, Principal
  - 9. Year of Construction : 1998, 2004, 2010
  - 10. Applicant's letter No. : Nil dated.09-02-16
- Plot Area-4050sqm Covered area ----2104sqm, No of student—1135nos, Total class room --31 nos

	Minimum Standards on fire prevention and fire safety U/R 33	Dir. Of Education/ NBC Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	Accessible	12m	MR
		NA	3.7m (old case)	NA
		NA	NA	NA
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	<b>a. Number of staircases</b>			
	<ul style="list-style-type: none"> <li>• Upper Floors</li> <li>• Basements</li> </ul>	02 nos	GF Blk-01 no G+1 blk—02 nos	MR
		NA	NA	NA
	<b>b. Width of staircases</b>			
	<ul style="list-style-type: none"> <li>• Upper Floors</li> <li>• Basements</li> </ul>	1.50m	2X2m 1.50m	MR
		NA	NA	NA
	<b>c. Protection of exits</b>			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Pressurization</li> </ul>	NA	NA	NA
		NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
f. Door Size	1M	1M	MR	

3	<b>Compartmentation.</b>			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	<b>Smoke Management System.</b>			
	• Basements	30 a/c per hour	No basement	NA
	• Upper floors	12 a/c per hour	Natural Ventilated	MR
5	<b>Fire Extinguishers</b>			
	• Total numbers	08nos	10nos	MR
	• Types	ABC/Co2	ABC-10	MR
	• ISI marking	Yes	Yes	MR
6	<b>First-Aid Hose Reels.</b>			
	• Total numbers on each floor	NA	NA	NA
	• Length of hose reel hose	NA	NA	NA
	• Nozzle diameter	NA	NA	NA
7	<b>Automatic fire detection and alarming system.</b>			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	<b>MOEFA</b>			
9	<b>Public Address System.</b>			
10	<b>Automatic Sprinkler System.</b>			
	• Basement	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	<b>Internal Hydrants</b>			
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA


	• Hose Box	NA	NA	NA
12	<b>Yard Hydrants.</b>			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	<b>Pumping Arrangements.</b>			
	• Ground Level			
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/ Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power Supply	NA	NA	NA
	➤ Auto Starting of pump	NA	NA	NA
	14	<b>Captive Water Storage for fire fighting.</b>		
• Underground tank capacity		NA	NA	NA
➤ Draw-off connection		NA	NA	NA
➤ Fire service inlet		NA	NA	NA
➤ Access to tank		NA	NA	NA
• Overhead Tank capacity		NA	NA	NA
		NA	NA	NA
15	<b>Exit Signage.</b>			
16	<b>Provision of Lifts.</b>			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A

N/16

17	<b>Standby power supply</b>	N/A	N/A	N/A
18	<b>Refuge Area.</b>			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	<b>Fire Control Room</b>			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in director of education Circular dated 01.03.2011, it is recommended to renewal of fire safety certificate issued vide this department letter of even no. 277 dated 17.01.2013.

  
 Signature of the Inspecting Officer  
 Name: - Rajesh Kumar  
 Designation: - ADO/RN

