

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001.

No. F6/DFS/MS/Banquet/2016/WZ/ 586

Dated: 13/04/16

FIRE SAFETY CERTIFICATE

Certified that the **M/s Raj Kumar Banquet** located at **3rd Floor Commercial Complex Plot No-2 Community Centre Block-B, Shop in Park Mall, Shalimar Bagh, Delhi- 110088** in a mall comprised of Lower Basement + Upper Basement + Ground + 3 upper floors owned/occupied by **M/S Raj Kumar Banquet** have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules. 2010 and verified by the officer concerned of Fire Service on 05-04-2016 in the presence of Sh. S Williams (Manager) and that the building/premises is fit for occupancy Assembly group D with effect from 13/04/16 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 13/04/16 at New Delhi by


(Dr.G.C.MISRA)
Director
Delhi Fire Service
Tel . -011-23414000

Following fire safety directives must be adhered to:

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition at all times and lapse rendering non-functional of fire safety measures, managements shall be responsible.
4. Any deviations w.r.t. construction, electric installation etc. may be got verified from the concerned building sanctioning authorities.
5. Basement shall be used as per NBC Part-IV.
6. The NOC may not be treated in any case for regularizations of unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
8. The third floor shall not be used for any purpose and kept sealed.
9. "The owner occupier shall apply for renewal of this fire safety certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry".

Copy to:

1. Sh. S Williams(Manager),M/S Raj Kamal Banquet, Commercial Complex Plot no 2.Community Centre, Block 'B' Shop in Park Mall 3rd Floor, Shalimar Bagh Delhi-110088.

INSPECTION REPORT

1. Name & address of the building: M/S Raj Kamal Banquet, Commercial Complex Plot No -2 Community Centre Block –B Shop in Park Mall 3 rd Floor, Shalimar Bagh, Delhi – 110088.
2. Type of Occupancy : **Banquet (Assembly) At 3rd Floor Shop in Park Mall**
3. Type of Case :New
4. Details of previous NOC ; Letter No. F6/DFS/MS/2015/wz/647 dated 30-04-2015
(**Issued to mall**)
5. Fire Safety directives Letter No. : Nil
6. Date of inspection : 05-04-2016.
7. Name of the Inspecting Officer : DO (West) & ADO (WP)
8. Name and designation of Officer
from the building side : Sh. S Williams
9. Year of Construction : 2006
10. Applicant's letter No. : DHO/RZ/2016/1598 Dated 11-02-2016

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	212 m	Provided	MR
	• Gate width	6 m	Provided	MR
	• Width of internal road	6 m	Provided	MR
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	7	Provided	MR
	• Basements	NA	Provided	NA
	b. Width of staircases			
	• Upper floors	7x150cm	provided	MR
	• Basements	NA	Provided	NA
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	Required	Provided	MR
	d. No of continuous staircase to terrace	Required	Provided	MR
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	2x2m & 1x1m	Provided	MR(For Banquet)

3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door 	Required	Provided	MR
	<ul style="list-style-type: none"> • Sealing of electrical shafts 	Required	Provided	MR
	<ul style="list-style-type: none"> • Fire Rating of shaft door 	Required	Provided	MR
	<ul style="list-style-type: none"> • Water Curtain 	NA	Provided	NA
	<ul style="list-style-type: none"> • Fire Dampers 	NA	NA	NA
4.	Smoke managements System	Common with Mall		
	<ul style="list-style-type: none"> • Basements 	NA(for Banquet)	Provided	NA
	<ul style="list-style-type: none"> • Upper floors 	12 a/c per hour	Provided	MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers 	08(For Banquet) ABC, CO2 & WCO2 ISI marked	Provided	MR
	<ul style="list-style-type: none"> • Types 		Provided	MR
	<ul style="list-style-type: none"> • IS marking 		Provided	MR
6.	First – Aid Hose Reels	Common With Mall		
	<ul style="list-style-type: none"> • Total numbers on each floor 	5	Provided	MR
		36 m	Provided	MR
	<ul style="list-style-type: none"> • Length of hose reel hose 	5 mm	Provided	MR
	<ul style="list-style-type: none"> • Nozzle diameter 			
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> • Type of detectors 	Smoke & Heat	Provided	MR
	<ul style="list-style-type: none"> • Location of Main Panel 	Required	Provided	MR
	<ul style="list-style-type: none"> • Location of Repeater Panel 	Required	Provided	MR
	<ul style="list-style-type: none"> • Alternate source of power 	Required	Provided	MR
	<ul style="list-style-type: none"> • Hooters' Location 	Required	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> • Basements 	NA	Provided	NA
	<ul style="list-style-type: none"> • Upper Floor 	Required	Provided	MR
	<ul style="list-style-type: none"> • Sprinkler above false ceiling 	Required	Provided	MR
11.	Internal Hydrants Common With Mall			
	<ul style="list-style-type: none"> • Size of riser/down-comer 	150 mm	Provided	MR
		5	Provided	MR
	<ul style="list-style-type: none"> • Number of hydrants per floor 	Required	Provided	MR
	<ul style="list-style-type: none"> • Hose Box 			
12.	Yard Hydrants(Common With Mall)			
	<ul style="list-style-type: none"> • Total number of hydrants 	NA	Provided	NA
	<ul style="list-style-type: none"> • Hose Box 	NA	Provided	NA

13.	Pumping Arrangements(Common With Mall)			
	<ul style="list-style-type: none"> • Ground Level • Discharge of main pump ➤ Head of main pump ➤ Number of main pumps ➤ Jockey pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Staring/Manual stopping ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power supply ➤ Auto starting of pump 	2850 lpm	Provided	MR
		70 m	Provided	MR
		2	Provided	MR
		180 lpm	Provided	MR
		70 m	Provided	MR
		2850 lpm	Provided	MR
		75 m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
14.	Captive water Storage for fire fighting(Common With Mall)			
	<ul style="list-style-type: none"> • Under ground tank capacity ➤ Draw of connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	2,00,000 litres	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		30, 000 litres	Provided	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts(Common With Mall)			
	<ul style="list-style-type: none"> ➤ Pressurization of Lift Shaft ➤ Pressurization of lift lobby ➤ Communication in lift Car ➤ Fireman's Grounding Switch ➤ Lift Signage 	NA	NA	NA
		NA	NA	NA
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	<ul style="list-style-type: none"> ➤ Total area ➤ Location 	NA	NA	NA
		NA	NA	NA
19.	Fire control room (Common With Mall)			
	<ul style="list-style-type: none"> ➤ Detector system panel ➤ Flow Switch Panel ➤ PA System Panel ➤ Battery backup ➤ Building Floor Plans 	Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR

20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	Provided	NA
-----	--------------------------------------------------------------------------	----	----------	----

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/issue shortcomings as noted at serial numbers Nil.....

Signature of the Inspecting Officer

Name *Uday Kir Singh*

Designation *ADOLP*

Signature of the Inspecting Officer *6/11*

Name *Sunil Chaudhary*

Designation *DOLE*